Table 2-1, Summary of Compliance Requirements

Florida Power and Light Company
Cape Canaveral Energy Center

Permit No.: 0090006-010-AV
Facility ID No.: 0090006

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
009	Unit 3A – one nominal 265 MW CTG with supplementary-fired HRSG
010	Unit 3B – one nominal 265 MW CTG with supplementary-fired HRSG
011	Unit 3C – one nominal 265 MW CTG with supplementary-fired HRSG

Pollutant Name or Parameter	Fuels	Compliance Method	Base Date *	Test Duration	CMS	See permit condition(s)
Carbon Monoxide	Oil	CEMS			Yes	**A.21.**
	Gas	CEMS			Yes	
Niitrogen Oxides	Oil	CEMS			Yes	**A.21.**
	Gas	CEMS			Yes	
Sulfuric Acid Mist/Sulfur Dio	Oil	recordkeeping				**A.23.**
	Gas					
Particulate Matter/PM10	Oil	recordkeeping				**A.23.**
	Gas					