DeSoto County Generating Company, LLC

DeSoto County Energy Park

Facility ID No. 0270016
Desoto County

Title V Air Operation Permit Renewal

Draft/Proposed Permit No. 0270016-009-AV
(Renewal of Title V Air Operation Permit No. 0270016-007-AV)

Permitting Authority:

State of Florida
Department of Environmental Protection
Division of Air Resource Management
Office of Permitting and Compliance
2600 Blair Stone Road

Mail Station #5505
Tallahassee, Florida 32399-2400

Telephone: (850) 717-9000
Fax: (850) 717-9097

Compliance Authority:

State of Florida
Department of Environmental Protection
Southwest District Office

13051 N. Telecom Parkway
Temple Terrace, Florida 33637-0926

Telephone: (813) 632-7600
Fax: (813) 632-7665

Title V Air Operation Permit Renewal

Draft/Proposed Permit No. 0270016-009-AV

Table of Contents

Section **Page Number**

Placard Page ii

I. Facility Information.
A. Facility Description. I.-1
B. Summary of Emissions Units. I.-1
C. Applicable Requirements. I.-23

II. Facility-wide Conditions. II.-1

III. Emissions Units and Conditions.
A. E.U. ID Nos. 001 & 002:
Two Simple-Cycle Combustion Turbines. III.A.-1
B. E.U. ID No. 005: 13.5 mmBtu/hr Indirect Fuel-fired Natural Gas Heater. III.B.-1

IV. Acid Rain Part. IV.1
A. E.U. ID Nos. 001 & 002:
Two Simple-Cycle Combustion Turbines. A.1

V. Clean Air Interstate Rule (CAIR) Part. V.1
A. E.U. ID Nos. 001 & 002:
Two Simple-Cycle Combustion Turbines. A.1

VI. Appendices. VI.-1

Appendix 40 CFR 60 Subpart A, NSPS General Provisions (version dated 02/05/2010).
Appendix 40 CFR 60, Subpart Dc, Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units (version dated 08/14/2009).
Appendix 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines (version dated 07/08/2004).

Appendix A, Glossary.
Appendix I, List of Insignificant Emissions Units and/or Activities.
Appendix RR, Facility-wide Reporting Requirements.
Appendix TR, Facility-wide Testing Requirements.
Appendix TV, Title V General Conditions.

Referenced Attachments. ..... At End
Table 1, Summary of Air Pollutant Standards and Terms.
Table 2, Summary of Compliance Requirements.
Table H, Permit History.

Florida Department of Environmental Protection

Bob Martinez Center
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Rick Scott
Governor

Jennifer Carroll
Lt. Governor

Herschel T. Vinyard Jr.
Secretary

PERMITTEE:
DeSoto County Generating Company, LLC
DeSoto County Energy Park

Draft/Proposed Permit No. 0270016-009-AV
DeSoto County Energy Park
Facility ID No. 0270016
Project: Title V Air Operation Permit Renewal

The purpose of this permit is to renew the Title V air operation permit for the above referenced facility. This existing facility is located in Desoto County at 3800 Northeast Roan Street, Arcadia, Florida; UTM Coordinates are: Zone 17, 419.75 km East and 3011.5 km North; and, Latitude: 27° 13' 30" North and Longitude: 81° 48' 42" West.

This Title V air operation permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213 and 62-214. The above named permittee is hereby authorized to operate the facility in accordance with the terms and conditions of this permit.

Effective Date: January 1, 2013
Renewal Application Due Date: May 20, 2017
Expiration Date: December 31, 2017

Syed Arif
2012.09.27
12:49:30 -04'00'

for Jeffery F. Koerner, Program Administrator
Office of Permitting and Compliance
Division of Air Resource Management

JFK/sa/sms

Subsection A. Facility Description.

This existing facility consists of two, dual-fuel, nominal 170 megawatt (MW) General Electric model PG7241FA combustion turbine-electrical generators with evaporative inlet coolers. The combustion turbine units can operate in simple cycle mode and intermittent duty mode. The units are equipped with dry low NOx (DLN-2.6) combustors and water injection capability. Also included in this permit are miscellaneous insignificant emissions units and/or activities.

The facility is owned and operated by DeSoto County Generating Company, LLC.

Subsection B. Summary of Emissions Units.

E.U. ID No.	Brief Description
Regulated Emissions Units	
001	Nominal 170 MW Simple Cycle Turbine
002	Nominal 170 MW Simple Cycle Turbine
Unregulated Emissions Units and/or Activities	
005	13.5 mmBtu/hr Indirect Fuel-fired Natural Gas Heater

Subsection C. Applicable Requirements.

Based on the Title V air operation permit application renewal received on May 22, 2012, this facility is not a major source of hazardous air pollutants (HAP). This facility is classified as a Prevention of Significant Deterioration (PSD) major facility. A summary of important applicable requirements is shown in the following table.

Applicable Requirement	E.U. ID No(s).
Rule 62-212.400, F.A.C., Prevention of Significant Deterioration (PSD)	001 & 002
Rule 62-212.400(6), F.A.C., Best Available Control Technology (BACT)	001 & 002
40 CFR 60, Subpart A, New Stationary Source Performance Standards (NSPS) General Provisions	001 & 002
NSPS - 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines	001 & 002
Acid Rain, Phase II SO_2	001 & 002
Rule 62-296.470, F.A.C., Clean Air Interstate Rule	001 & 002
Rule 62-210.300, F.A.C., Permits Required	005
40 CFR 60, Subpart A, New Stationary Source Performance Standards (NSPS) General Provisions	005
40 CFR 60, Subpart Dc, Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units	005

The following conditions apply facility-wide to all emission units and activities:

FW1. Appendices. The permittee shall comply with all documents identified in Section VI., Appendices, listed in the Table of Contents. Each document is an enforceable part of this permit unless otherwise indicated. [Rule 62-213.440, F.A.C.]

Emissions and Controls

FW2. Not federally enforceable. Objectionable Odor Prohibited. No person shall cause, suffer, allow or permit the discharge of air pollutants, which cause or contribute to an objectionable odor. An "objectionable odor" means any odor present in the outdoor atmosphere which by itself or in combination with other odors, is or may be harmful or injurious to human health or welfare, which unreasonably interferes with the comfortable use and enjoyment of life or property, or which creates a nuisance. [Rules 62-296.320(2) & 62-210.200 (Definitions), F.A.C.]

FW3. General Volatile Organic Compounds (VOC) Emissions or Organic Solvents (OS) Emissions. The permittee shall allow no person to store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds or organic solvents without applying known and existing vapor emission control devices or systems deemed necessary and ordered by the Department. [Rule 62-296.320(1), F.A.C.]

{Permitting note: Nothing is deemed necessary and ordered at this time.}

FW4. General Visible Emissions. No person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity equal to or greater than 20% opacity. EPA Method 9 is the method of compliance pursuant to Chapter 62-297, F.A.C. This regulation does not impose a specific testing requirement. [Rule 62-296.320(4)(b), F.A.C.]

FW5. Unconfined Particulate Matter. No person shall cause, let, permit, suffer or allow the emissions of unconfined particulate matter from any activity, including vehicular movement; transportation of materials; construction; alteration; demolition or wrecking; or industrially related activities such as loading, unloading, storing or handling; without taking reasonable precautions to prevent such emissions. Reasonable precautions to prevent emissions of unconfined particulate matter at this facility include:

a. Paving and maintenance of roads, parking areas and yards.
b. Application of water or chemicals to control emissions from such activities as demolition of buildings, grading roads, construction, and land clearing.
c. Application of asphalt, water, oil, chemicals or other dust suppressants to unpaved roads, yards, open stock piles and similar activities.
d. Removal of particulate matter from roads and other paved areas under the control of the owner or operator of the facility to prevent reentrainment, and from buildings or work areas to prevent particulate from becoming airborne.
e. Landscaping or planting of vegetation.
f. Use of hoods, fans, filters, and similar equipment to contain, capture, and/or vent particulate matter.
g. Confining abrasive blasting where possible.
h. Enclosure or covering of conveyor systems.
i. Posting and enforcing a speed limit for vehicles traveling on roadways on site.

[Rule 62-296.320(4)(c), F.A.C.; and, proposed by applicant in the Title V air operation permit renewal application received on May 22, 2012.]

Annual Reports and Fees

See Appendix RR, Facility-wide Reporting Requirements, for additional details.

FW6. Annual Operating Report. The permittee shall submit an annual report that summarizes the actual operating rates and emissions from this facility. Annual operating reports shall be submitted to the Compliance Authority by April 1st of each year. [Rule 62-210.370(3), F.A.C.]

FW7. Annual Emissions Fee Form and Fee. The annual Title V emissions fees are due (postmarked) by March 1st of each year. The completed form and calculated fee shall be submitted to: Major Air Pollution Source Annual Emissions Fee, P.O. Box 3070, Tallahassee, Florida 32315-3070. The forms are available for download by accessing the Title V Annual Emissions Fee On-line Information Center at the following Internet web site: http://www.dep.state.fl.us/air/emission/tvfee.htm. [Rule 62-213.205, F.A.C.]

FW8. Annual Statement of Compliance. The permittee shall submit an annual statement of compliance to the compliance authority at the address shown on the cover of this permit within 60 days after the end of each calendar year during which the Title V air operation permit was effective. [Rules 62-213.440(3)(a)2. & 3. and (b), F.A.C.]

FW9. Prevention of Accidental Releases (Section 112(r) of CAA). If and when the facility becomes subject to 112(r), the permittee shall:

a. Submit its Risk Management Plan (RMP) to the Chemical Emergency Preparedness and Prevention Office (CEPPO) RMP Reporting Center. Any Risk Management Plans, original submittals, revisions or updates to submittals, should be sent to: RMP Reporting Center, Post Office Box 10162, Fairfax, VA 22038, Telephone: 703/227-7650.

b. Submit to the permitting authority Title V certification forms or a compliance schedule in accordance with Rule 62-213.440(2), F.A.C.

[40 CFR 68.]

Subsection A. Emissions Units 001 & 002
Two Simple-Cycle Combustion Turbines

The specific conditions in this section apply to the following emissions unit(s):

E.U. ID No.	Brief Description
001	Nominal 170 MW Simple Cycle Turbine
002	Nominal 170 MW Simple Cycle Turbine

These emissions units are two, dual-fuel, nominal 170 megawatt (MW) General Electric Model PG7241FA combustion turbine-electrical generators with evaporative inlet coolers. The combustion turbine units can operate in simple cycle mode and intermittent duty mode. The units are fired primarily by natural gas, with fuel oil used as a back-up fuel. The units were designed and constructed with dry low NOx (DLN-2.6) burner technology and water injection capability for the control of nitrogen oxides (NOx) emissions. A continuous emissions monitoring system (CEMS) monitors NOx emissions from the combustion turbines. The advanced burner design reduces incomplete combustion and minimizes carbon monoxide (CO), particulate matter (PM/PM_{10}), and volatile organic compound (VOC) emissions. The use of inherently clean fuels and good operating practices also reduces air pollutant emissions.

E.U. ID Nos. 001 & 001 began operation on April 12, 2002 and April 23, 2002, respectfully. The stack parameters for E.U. ID Nos. 001 & 002 are identical: height, 75 feet; diameter, 23 feet; exit temperature, 1,113 degrees F; and, actual stack gas flow rate, 2,646,000 acfm.

{Permitting note(s): These emissions units are regulated under Acid Rain, Phase II; NSPS - 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines, adopted and incorporated by reference in Rule 62-204.800(8)(b), F.A.C.; Rule 62-212.400, F.A.C., Prevention of Significant Deterioration (PSD) [PSD-FL-284]; Rule 62-212.400(6), F.A.C., Best Available Control Technology (BACT) Determination dated June 29, 2000; and, Rule 62-296.470, F.A.C., Clean Air Interstate Rule (CAIR).}

Equipment & Source Obligation

A.1. Source Obligation - BACT Determination dated June 29, 2000. In accordance with Rule 62-212.400(12), F.A.C. (and 40 CFR 51.166(j)(4)), the Best Available Control Technology (BACT) determination shall be reviewed and modified as appropriate in the event of a plant conversion. This paragraph states: "For phased construction project, the determination of best available control technology shall be reviewed and modified as appropriate at the latest reasonable time which occurs no later than 18 months prior to commencement of construction of each independent phase of the project. At such time, the owner or operator of the applicable stationary source may be required to demonstrate the adequacy of any previous determination of best available control technology for the source." This reassessment will also be conducted for this project if there are any increases in heat input limits, hours of operation, oil firing, low or baseload operation (e.g., conversion to combined-cycle operation), short-term or annual emission limits, annual fuel heat input limits or similar changes. [40 CFR 51.166(j)(4); Rule 62-212.400(12), F.A.C.; and, PSD-FL-284/0270016-001-AC, Specific Condition II.7.]

Essential Potential to Emit (PTE) Parameters

A.2. Hours of Operation. The two stationary gas turbines shall operate no more than an average of 3,390 hours per unit during any calendar year. The two stationary gas turbines shall operate no more than an average of 1,000 hours per unit on fuel oil during any calendar year. No single combustion turbine shall operate more than 5,000 hours in a single year. [Rule 62-210.200 (Definitions - Potential to Emit (PTE), F.A.C.; 62-212.400 (BACT), and, PSD-FL-284/0270016-001-AC, Specific Condition III.13.]

A.3. Permitted Capacity. The nominal heat input rates, based on the lower heating value (LHV) of each fuel to each Unit (001 and 002) at ambient conditions of 59 degrees F temperature, 60% relative humidity, 100% load, and 14.7 psi pressure shall not exceed 1,612 million Btu per hour (MMBtu/hr) when firing natural gas, nor 1,806 MMBtu/hr when firing No. 2 or superior grade of distillate fuel oil. Heat input rates will vary

depending upon gas turbine characteristics, ambient conditions, alternate methods of operation, and evaporative cooling. The permittee shall provide manufacturer's performance curves (or equations) that correct for site conditions to the Permitting and Compliance Authorities upon request. Operating data may be adjusted for the appropriate site conditions in accordance with the performance curves and/or equations on file with the Department. [Rules 62-4.160(2), 62-210.200 (Definitions - PTE) & 62-212.400 (BACT), F.A.C.; and, PSD-FL-284/0270016-001-AC, Specific Condition III.8. & PSD-FL-284C/0270016-006-AC, Specific Condition III.8.]

A.4. Emissions Unit Operating Rate Limitation After Testing. See the related testing provisions in Appendix TR, Facility-wide Testing Requirements. [Rule 62-297.310(2), F.A.C.]

A.5. Methods of Operation - Fuels. Only pipeline natural gas or a maximum of 0.05%, by weight, sulfur fuel oil No. 2, or superior grade of distillate fuel oil, shall be fired in these units. [Rules 62-4.160(2), 62-210.200 (Definitions - PTE), 62-212.400 (BACT), 62-213.410, 62-213.440(1), F.A.C.; and, PSD-FL-284/0270016-001-AC, Specific Condition III.7.]

{Permitting note: The limitation of this specific condition is more stringent than the NSPS sulfur dioxide limitation and thus assures compliance with 40 CFR 60.333 and 60.334.}

A.6. Fuel Oil Usage. The amount of back-up fuel (fuel oil) burned at the site (in BTU's) shall not exceed the amount of natural gas (primary fuel) burned at the site (in BTU's) during any consecutive 12-month period. During any consecutive 12-month period that includes an episode where natural gas availability is limited (e.g., gas supply is scheduled and flowing to the facility, but is subsequently interrupted and discontinued; gas supply is requested based on apparent availability, but is not able to be scheduled due to actual unavailability; and gas transportation is known to be restricted such that no request to schedule supplies would reasonably be fulfilled), the amount of back-up fuel (fuel oil) burned at the site (in BTU's) may exceed the amount of natural gas (primary fuel) burned at the site (in BTU's) for that consecutive 12-month period. The permittee shall provide quarterly documentation of the episodes to the compliance authority. The documentation shall include the dates of the episodes, the reasons provided by the supplier for limited natural gas availability, and the duration of each episode during that quarter. [Rules 62-4.160(2), 62-210.200 (Definitions - PTE) & 62-212.400 (BACT), F.A.C.; and, PSD-FL-284/0270016-001-AC, Specific Condition III.14. & PSD-FL-284C/0270016-006-AC, Specific Condition III.14.]

Air Pollution Control Technologies and Measures

A.7. Dry Low NOx (DLN) Systems. The dry low NOx (DLN-2.6) combustors shall be used on the stationary combustion turbines to control nitrogen oxides (NOx) emissions while firing natural gas. The system shall be maintained and tuned in accordance with the manufacturer's recommendations. [Rules 62-4.070, and 62-210.650, F.A.C.; and, PSD-FL-284/0270016-001-AC, Specific Condition III.15.]

A.8. DLN Systems. The DLN systems shall each be maintained to minimize NOx emissions and CO emissions, consistent with normal operation and maintenance practices. Operation of the DLN systems in the diffusion-firing mode shall be minimized when firing natural gas. [Rules 62-4.070(1)&(3), and 62-210.650, F.A.C.; and, PSD-FL-284/0270016-001-AC, Specific Condition III.17.]

A.9. Water Injection Systems. The water injection systems shall be used when firing No. 2 or superior grade distillate fuel oil for control of NOx emissions. The systems shall be maintained and tuned in accordance with the manufacturer's recommendations. [Rules 62-4.070(1)&(3), and 62-210.650, F.A.C.; and, PSD-FL-284/0270016-001-AC, Specific Conditions III.16. & 17.]

A.10. Operating Procedures. Operating procedures shall include good operating practices and proper training of all operators and supervisors. The good operating practices shall meet the guidelines and procedures as established by the equipment manufacturers or facility determined best practices after approval by the Department. The permittee shall submit the facility determined best practices to the Department prior to implementing the practices. All operators of air pollution control devices shall be properly trained in plant

specific equipment. [Rule 62-4.070(1)&(3) and 62-212.400 (BACT), F.A.C.; and, PSD-FL-284/0270016-001-AC, Specific Condition III.11. & PSD-FL-284C/0270016-006-AC, Specific Condition III.11.]

Emission Limitations and Standards

{Permitting note: Table 1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

Unless otherwise specified, the averaging times for Specific Conditions **A.11. - A.16.** are based on the specified averaging time of the applicable test method.

The emission limitations and standards in Specific Conditions **A.11. - A.16.** apply to each individual unit.

A.11. Nitrogen Oxides (NOx) Emissions.

a. While firing natural gas the emission rate of NOx in the exhaust gas shall not exceed 9 ppmvd @ 15% O_2 on a 24-hr block average (of valid hours during which the unit is operated only) as measured by the continuous emissions monitoring system (CEMS). Refer to Specific Condition **A.20.** for a discussion of the valid hours contributing to the block average.

   In addition, NOx emissions calculated as NO_2 shall not exceed 64.1 lbs/hr (at ISO conditions) and 9 ppmvd @ 15% O_2 as demonstrated by the initial "new and clean" GE performance stack test.

b. While firing fuel oil the concentration of NOx in the exhaust gas shall not exceed 42 ppmvd @ 15% O_2 on the basis of a 3-hr block average (of valid hour hours during which the unit is actually operated only) as measured by the continuous emissions monitoring system (CEMS). In addition, NOx emissions calculated as NO_2 shall not exceed 351 lbs/hr (at ISO conditions) and 42 ppmvd @ 15% O_2 to be demonstrated by stack test.

c. The permittee shall develop a NOx reduction plan when the hours of oil firing reach the allowable limit of 1,000 hours per year. This plan shall include a testing protocol designed to establish the maximum water injection rate and the lowest NOx emissions possible without affecting the actual performance of the gas turbine. The testing protocol shall set a range of water injection rates and attempt to quantify the corresponding NOx emissions for each rate and noting any problems with performance. Based on the test results, the plan shall recommend a new NOx emissions limiting standard and shall be submitted to the permitting authority and compliance authority for review. If the Department determines that a lower NOx emissions standard is warranted for oil firing, Permit PSD-FL-284/0270016-001-AC shall be revised.

[Rule 62-212.400 (BACT), F.A.C.; and, PSD-FL-284/0270016-001-AC, Specific Condition III.19.]

A.12. Carbon Monoxide (CO) Emissions. The concentration of CO in the stack exhaust gas shall exceed neither 12 ppmvd nor 42.5 lbs/hr (at ISO conditions) while firing gas, and neither 20 ppmvd nor 71.4 lbs/hr (at ISO conditions) while firing fuel oil. The permittee shall demonstrate compliance with these limits by stack test using EPA Method 10. [Rule 62-212.400 (BACT), F.A.C.; and, PSD-FL-284/0270016-001-AC, Specific Condition III.20.]

A.13. Volatile Organic Compounds (VOC) Emissions. The concentration of VOC in the stack exhaust gas with the combustion turbine operating on natural gas shall exceed neither 1.4 ppmvd nor 2.8 lbs/hr (at ISO conditions), and neither 7 ppmvw nor 16.2 lbs/hr (at ISO conditions) while operating on oil as demonstrated by initial stack test using EPA Method 18, 25 or 25A. [Rule 62-212.400 (BACT), F.A.C.; and, PSD-FL-284/0270016-001-AC, Specific Condition III.21.]

A.14. Sulfur Dioxide (SO_2) Emissions. SO_2 emissions shall be limited by firing pipeline natural gas (sulfur content less than 1 grain per 100 standard cubic feet) or by firing No. 2 or superior grade distillate fuel oil with a maximum of 0.05 percent sulfur, by weight, for 1,000 hours per year per unit. Emissions of SO_2 (at ISO conditions) shall not exceed 5 lbs/hr (natural gas) and 98.7 lbs/hr (fuel oil) as measured by applicable

compliance methods described below. [40 CFR 60 Subpart GG; Rules 62-4.070, 62-212.400 (BACT), and 62-204.800(7), F.A.C.; and, PSD-FL-284/0270016-001-AC, Specific Condition III.22.]

A.15. Particulate Matter (PM/PM_{10}). PM/PM_{10} emissions shall not exceed 10 lbs/hr when operating on natural gas and shall not exceed 17 lbs/hr when operating on fuel oil. Visible emissions testing shall serve as a surrogate for PM/PM_{10} compliance testing. [Rule 62-212.400 (BACT), F.A.C.; and, PSD-FL-284/0270016-001-AC, Specific Condition III.23.]

A.16. Visible Emissions (VE). VE emissions shall serve as a surrogate for PM/PM_{10} emissions and shall not exceed 10% opacity. [Rules 62-4.070(1)&(3), 62-212.400 (BACT), and 62-204.800(7), F.A.C.; and, PSD-FL-284/0270016-001-AC, Specific Condition III.24.]

Excess Emissions

Rule 62-210.700 (Excess Emissions), F.A.C., cannot vary any requirement of an EG, NSPS or NESHAP provision.

A.17. Excess Emissions Allowed - Startup, Shutdown or Malfunction. Excess emissions resulting from startup, shutdown, or malfunction shall be permitted provided that best operational practices are adhered to and the duration of excess emissions shall be minimized. Excess emissions occurrences shall in no case exceed two hours in any 24-hour period for other reasons unless specifically authorized by the Department for longer duration. Operation below 50% output shall be limited to 2 hours per unit cycle (breaker closed to breaker open). [Rules 62-210.700(1)&(2), F.A.C.; and, PSD-FL-284/0270016-001-AC, Specific Condition III.25.]

A.18. Excess Emissions Prohibited. Excess emissions entirely or in part by poor maintenance, poor operation, or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction, shall be prohibited pursuant to Rule 62-210.700, F.A.C. These emissions shall be included in the 24-hr average for NOx. [Rule 62-210.700(4), F.A.C.; and, PSD-FL-284/0270016-001-AC, Specific Condition III.26.]

Continuous Emissions Monitoring Systems (CEMS)

{Permitting note: The following continuous monitors are installed on these units: NOx and O_2.}

A.19. NOx CEMS. The permittee shall calibrate, maintain, and operate a CEMS in the stack to measure and record the NOx emissions from these units. Upon request from U.S. EPA or the Department, the CEMS emission rates for NOx on these units shall be corrected to ISO conditions to demonstrate compliance with the NOx standard established in 40 CFR 60.332. [Rules 62-204.800, 62-210.700, 62-4.130, 62-4.160(8), F.A.C.; 40 CFR 75 & 40 CFR 60.7; and, PSD-FL-284/0270016-001-AC, Specific Condition III.40.]

A.20. Continuous Compliance with the NOx Emission Standards/Limits. Continuous compliance with the NOx emission limits shall be demonstrated with the CEMS based on the applicable averaging time of 24-hr block average. Based on CEMS data, a separate compliance determination is conducted at the end of each operating day and a new average emission rate is calculated from the arithmetic average of all valid hourly emission rates from the previous operating day. A valid hourly emission rate shall be calculated for each hour in which at least two NOx concentrations are obtained at least 15 minutes apart. Valid hourly emission rates shall not include periods of start up, shutdown, or malfunction unless prohibited by Rule 62-210.700, F.A.C. These excess emissions periods shall be reported as required in Specific Conditions **A.17.** and **A.18.**

All continuous emissions monitoring systems (CEMS) shall be in continuous operation except for breakdowns, repairs, calibration checks, and zero and span adjustments. These CEMS shall meet minimum frequency of operation requirements: one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period. Data recorded during periods of continuous monitoring system breakdowns, repairs, calibration checks, and zero and span adjustments shall not be included in the data average.

[Rules 62-4.070(1)&(3) and 62-210.700, F.A.C., 40 CFR 75 and 40 CFR 60.13; and, PSD-FL-284/0270016-001-AC, Specific Condition III.30.]

A.21. CEMS in lieu of Water-to-Fuel Ratio. The NOx CEMS shall be used in lieu of the water/fuel monitoring system for reporting excess emissions in accordance with 40 CFR 60.334(c)(1), Subpart GG. The calibration of the water/fuel monitoring device required in 40 CFR 60.335 (c)(2) will be replaced by the 40 CFR 75 certification tests of the NOx CEMS. [PSD-FL-284/0270016-001-AC, Specific Condition III.42.]

A.22. Continuous Monitoring Certification and Quality Assurance Requirements. The monitoring devices shall comply with the certification and quality assurance, and any other applicable requirements of Rule 62-297.520, F.A.C., 40 CFR 60.13, including certification of each device in accordance with 40 CFR 60, Appendix B, Performance Specifications, and 40 CFR 60.7(a)(5) or 40 CFR Part 75. Quality assurance procedures must conform to all applicable sections of 40 CFR 60, Appendix F or 40 CFR 75. [PSD-FL-284/0270016-001-AC, Specific Condition III.43.]

Monitoring Requirements

A.23. Natural Gas Monitoring Schedule. A custom fuel monitoring schedule pursuant to 40 CFR 75 Appendix D for natural gas may be used in lieu of the daily sampling requirements of 40 CFR 60.334 (b)(2) provided the following requirements are met:

a. The permittee shall apply for an Acid Rain permit within the deadlines specified in 40 CFR 72.30.
b. The permittee shall submit a monitoring plan, certified by signature of the Designated Representative, that commits to using a primary fuel of pipeline supplied natural gas (sulfur content less than 1 gr/100 scf pursuant to 40 CFR 75.11(d)(2)).
c. Each unit shall be monitored for SO_2 emissions using methods consistent with the requirements of 40 CFR 75 and certified by the U.S. EPA.
d. This custom fuel monitoring schedule will only be valid when pipeline natural gas is used as a primary fuel. If the primary fuel for these units is changed to a higher sulfur fuel, SO_2 emissions must be accounted for as required pursuant to 40 CFR 75.11(d).

[PSD-FL-284/0270016-001-AC, Specific Condition III.44.]

A.24. Custom Fuel Monitoring Schedule - Natural Gas. Pursuant to 40 CFR 60.334(b)(2), a custom fuel monitoring schedule shall be followed for the natural gas fired at this facility and shall be as follows:

a. Monitoring of fuel nitrogen content shall not be required when natural gas is the only fuel being fired in the turbines.
b. Sulfur Monitoring.
   (1) Analysis for fuel sulfur content of the natural gas fired at this facility shall be conducted using one of the approved ASTM reference methods for the measurement of sulfur in gaseous fuels, or an approved alternate method. The reference methods are ASTM D1072-80, ASTM D3031-81, ASTM D3246-81 and ASTM D4084-82, as referenced in 40 CFR 60.335(b)(2).
   (2) If, after monitoring required in item 2.b. above, the sulfur content shows little variability and, calculated as sulfur dioxide, represents consistent compliance with the sulfur dioxide emission limits specified under 40 CFR 60.333, and the fuel sulfur limits of this permit, sample analysis shall be conducted twice per year. This monitoring shall be conducted during the first and third quarters of each calendar year.
   (3) Should any sulfur analysis, as required in items 2.b. or 2.c. above indicate noncompliance with the sulfur limits of 40 CFR 60.333 or this permit, the owner or operator shall notify the Department of such excess emissions and the custom schedule shall be re-examined by the U.S. Environmental Protection Agency (EPA). Sulfur monitoring shall be conducted weekly during the interim period when this custom schedule is being re-examined.
c. If there is a change in fuel supply, the owner or operator shall notify the Department and U.S. EPA of such change for re-examination of this custom schedule. A substantial change in fuel quality shall be

considered as a change in fuel supply. Sulfur monitoring shall be conducted weekly during the interim period when this custom schedule is being re-examined.

d. Records of sample analysis and fuel supply pertinent to this custom fuel monitoring schedule for natural gas shall be retained for a period of five years, and shall be available at the facility for inspection by personnel of the Department or U.S. EPA.

[Effective on 01/01/2008, by Permit No. 0270016-007-AV, Specific Condition III.A.31.]

A.25. Fuel Oil Monitoring Schedule. The following monitoring schedule for No. 2 or superior grade fuel oil shall be followed: For all bulk shipments of No. 2 fuel oil received at this facility an analysis which reports the sulfur content of the fuel shall be provided by the fuel vendor. The analysis shall also specify the methods by which the analyses were conducted and shall comply with the requirements of 40 CFR 60.334(h). [PSD-FL-284/0270016-001-AC, Specific Condition III.45. & PSD-FL-284C/0270016-006-AC, Specific Condition III.45.]

Test Methods and Procedures

A.26. Common Testing Requirements. Unless otherwise specified, tests shall be conducted in accordance with the requirements and procedures specified in Appendix TR, Facility-Wide Testing Requirements, of this permit. [Rule 62-297.310, F.A.C.]

A.27. Test Methods. Required tests shall be performed in accordance with the following reference method(s):

Method(s)	Description of Method(s) and Comment(s)
EPA Methods 1-4	Traverse Points, Velocity and Flow Rate, Gas Analysis, and Moisture Content
EPA Methods 6, 6A, 6B or 6C	Methods for Determining SO_2 Emissions
EPA Method 7E	Determination of NOx Emissions
EPA Method 9	Visual Determination of the Opacity of Emissions (VE)
EPA Method 10	Determination of CO Emissions
EPA Method 18, 25 and/or 25A	Determination of Volatile Organic Concentrations (VOC)
EPA Method 20	Determination of NOx, SO_2 and Diluent Emissions from Stationary Gas Turbines

The above methods are described in Chapter 62-297, F.A.C. and/or 40 CFR 60, Appendix A, and adopted by reference in Rule 62-204.800, F.A.C. No other methods may be used unless prior written approval is received from the Department. [Chapter 62-297, F.A.C.]

A.28. Annual Compliance Test. Unless otherwise specified by this permit, during each federal fiscal year (October 1st to September 30th), Emissions Unit ID Nos. 001 and 002 shall be tested to demonstrate compliance with the emission limitations and standards for NOx and VE. The NOx RATA test data may be used to demonstrate compliance with the annual test requirement, provided the testing requirements (notification, procedures and reporting) of Chapter 62-297, F.A.C. are met. [Rule 62-297.310(7), F.A.C.; and, PSD-FL-284/0270016-001-AC, Specific Conditions III.1., 28. & 29.]

A.29. Compliance Test Prior To Renewal. Prior to permit renewal, Emissions Unit ID Nos. 001 and 002 shall be tested to demonstrate compliance with the emission limitations and standards for NOx, CO (except as provided in Specific Condition **A.30.**), and VE. The NOx RATA test data may be used to demonstrate compliance with the renewal test requirement, provided the testing requirements (notification, procedures and reporting) of Chapter 62-297, F.A.C. are met. [Rule 62-297.310(7)(a)3., F.A.C.; and, PSD-FL-284/0270016-001-AC, Specific Conditions III.1., 28. & 29.]

A.30. CO Testing. By this permit, emissions compliance testing for CO may be performed on only one unit, alternating the unit tested each 5 years. See Specific Condition **TR7.** [Rule 62-297.310(7)(a)4., F.A.C.]

A.31. CO & NOx Testing after Replacing Combustors and Restarting a Unit. Within 60 days of replacing combustors and restarting a unit, the permittee shall conduct an EPA Method 10 test to determine compliance with the CO emissions standard for firing natural gas. NOx CEMS data collected during each of the CO test runs shall be averaged and reported in the test report. The results of this test may be used to satisfy the requirement for an annual CO emissions test. [Rule 62-297.310, F.A.C.; PSD-FL-284/0270016-001-AC, Specific Condition III.28.; PSD-FL-284B/0270016-004-AC, Specific Condition III.29.; and, PSD-FL-284C/0270016-006-AC, Specific Condition III.29.]

A.32. Compliance with CO Emission Standards/Limits. An initial test for CO shall be conducted concurrently with the initial NOx test, as required. The initial NOx and CO test results shall be the average of three valid one-hour runs. Compliance testing for CO may be conducted at less than capacity when compliance testing is conducted concurrent with the annual RATA testing for the NOx CEMS required pursuant to 40 CFR 75. [PSD-FL-284/0270016-001-AC, Specific Conditions III.1., 28., 29. & 32.]

A.33. Compliance with the SO_2 and PM/PM_{10} Emission Standards/Limits. Notwithstanding the requirements of Rule 62-297.340, F.A.C., the use of pipeline natural gas, is the method for determining compliance for SO_2 and PM_{10}. For the purposes of demonstrating compliance with the 40 CFR 60.333 SO_2 standard, ASTM methods D4084-82 or D3246-81 (or equivalent) for sulfur content of gaseous fuel shall be utilized in accordance with the EPA-approved custom fuel monitoring schedule or natural gas supplier data may be submitted or the natural gas sulfur content referenced in 40 CFR 75 Appendix D may be utilized. However, the applicant is responsible for ensuring that the procedures in 40 CFR 60.335 or 40 CFR 75 are used when determination of fuel sulfur content is made. Analysis may be performed by the owner or operator, a service contractor retained by the owner or operator, the fuel vendor, or any other qualified agency pursuant to 40 CFR 60.335(e) (1998 version). [PSD-FL-284/0270016-001-AC, Specific Condition III.31.]

A.34. Compliance with the VOC Emission Standards/Limits. An initial test was required to demonstrate compliance with the VOC emission limit. Thereafter, the CO emission limit and periodic tuning data shall be employed as surrogate and no annual testing is required. [PSD-FL-284/0270016-001-AC, Specific Condition III.33.]

A.35. VOC and the Short-term NOx BACT Standard/Limit Testing. Initial tests were required under the AC/PSD permits for VOC and the short-term NOx BACT limits. In accordance with Rule 62-297.310(7), F.A.C., the Department may require the initial tests required under the AC/PSD permit to be repeated after a modification (and shakedown period not to exceed 100 days after restart) of a combustion turbine. [Rule 62-297.310, F.A.C.; PSD-FL-284/0270016-001-AC, Specific Condition III.28.; PSD-FL-284B/0270016-004-AC, Specific Condition III.29.; and, PSD-FL-284C/0270016-006-AC, Specific Condition III.29.]

Recordkeeping and Reporting Requirements

See Appendix RR, Facility-wide Reporting Requirements, for additional reporting requirements.

A.36. Reporting Schedule. The following report shall be submitted to the Compliance Authority:

Report	Reporting Deadline(s)	Related Condition(s)
Excess Emissions from Malfunctions, if requested by the Compliance Authority	Every 3 months (quarter)	**A.38.**
NSPS Excess Emissions and Monitoring System Performance	Every 6 months (semi-annual), except when more frequent reporting is specifically required	**A.37., A.38. & A.40.**

[Rule 62-210.700(6), F.A.C.; 40 CFR 60, Subparts A & GG.]

A.37. CEMS for Reporting Excess Emissions. Excess Emissions and Monitoring System Performance Reports shall be submitted as specified in 40 CFR 60.7(c). CEMS monitor downtime shall be calculated and reported according to the requirements of 40 CFR 60.7(c)(3) and 40CFR 60.7(d)(2). Periods when NOx emissions (ppmvd @ 15% oxygen) are above the BACT standards, listed in Specific Conditions No. **A.11.**, shall be reported to the compliance authority within one working day (verbally) followed up by a written explanation not later than three (3) working days (alternatively by facsimile within one working day). [PSD-FL-284/0270016-001-AC, Specific Condition III.41.]

A.38. Excess Emissions from Malfunction, Startup, Shutdown & Malfunction. If excess emissions occur due to malfunction, the owner or operator shall notify the Compliance Authority within one working day of: the nature, extent, and duration of the excess emissions; the cause of the excess emissions; and the actions taken to correct the problem. In addition, the Department may request a written summary report of the incident. Following the NSPS format (also known as Figure 1) in 40 CFR 60.7, Subpart A (See Appendix 40 CFR 60 Subpart A), periods of startup, shutdown, malfunction, shall be monitored, recorded, and reported as excess emissions when emission levels exceed the permitted standards listed in Specific Conditions No. **A.11.** [Rules 62-4.130, 62-204.800, 62-210.700(6), F.A.C.; 40 CFR 60.7; and, PSD-FL-284/0270016-001-AC, Specific Condition III.27.]

A.39. Other Reporting Requirements. See Appendix RR, Facility-Wide Reporting Requirements, for additional reporting requirements. [Rule 62-213.440, F.A.C.]

NSPS 40 CFR 60 Requirements

A.40. NSPS Requirements - Subpart A. This emissions unit shall comply with all applicable requirements of 40 CFR 60, Subpart A, General Provisions, including:

40 CFR 60.7, Notification and Recordkeeping
40 CFR 60.8, Performance Tests
40 CFR 60.11, Compliance with Standards and Maintenance Requirements
40 CFR 60.12, Circumvention
40 CFR 60.13, Monitoring Requirements
40 CFR 60.19, General Notification and Reporting Requirements,

which have been adopted by reference in Rule 62-204.800(8)(d), F.A.C.; except that the Secretary is not the Administrator for purposes of 40 CFR 60.4, 40 CFR 60.8(b)(2) and (3), 40 CFR 60.11(e)(7) and (8), 40 CFR 60.13(g), (i) and (j)(2), and 40 CFR 60.16. This emissions unit shall comply with all applicable provisions of **Appendix 40 CFR 60 Subpart A** included with this permit, which includes applicable requirements that apply in general to all emission units regulated under 40 CFR 60, Subpart A. This appendix also contains useful information like definitions (see 40 CFR 60.2) and units and abbreviations (see 40 CFR 60.3). [Rule 62-204.800(8)(d), F.A.C.]

A.41. NSPS Requirements - Subpart GG. Except as otherwise provided in this permit, the combustion turbine shall comply with all applicable provisions of 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines, adopted by reference in Rule 62-204.800(8)(b), F.A.C., except that the Secretary is not the Administrator for purposes of 40 CFR 60.334(b)(2) and 40 CFR 60.335(f)(1). The Subpart GG requirement to correct test data to ISO conditions applies, but such correction is not required to demonstrate compliance with the non-NSPS permit standard(s). These emissions units shall comply with **Appendix 40 CFR 60 Subpart GG** attached to this permit. [Rule 62-204.800(8)(b)39., F.A.C.]

Subsection B. Emissions Units 005
13.5 mmBtu/hr Indirect Fuel-fired Natural Gas Heater

The specific conditions in this section apply to the following emissions unit(s):

E.U. ID No.	Brief Description
005	13.5 mmBtu/hr Indirect Fuel-fired Natural Gas Heater

The heater is used to prevent the natural gas supply to the combustion turbines from freezing.

{Permitting note(s): The heater even though it does not generate steam is subject to NSPS 40 CFR 60, Subpart Dc because it heats a heat transfer fluid, which indirectly heats the medium (natural gas). The heater is not considered a process heater that would have otherwise been specifically exempt from NSPS 40 CFR 60, Subpart Dc per the definitions in 40 CFR 60.41c.

The heater is only subject to the NSPS 40 CFR 60, Subpart Dc recordkeeping requirements specifically at 40 CFR 60.48c(g)(2) & (i). A "unit-specific applicable requirement" is defined by Rule 62-210.200(317), F.A.C. Rule 62-210.200(317)(b)2., F.A.C. considers recordkeeping and reporting requirements to not be "unit-specific applicable requirements." Since only recordkeeping requirements from the NSPS 40 CFR 60, Subpart Dc apply to the heater, the heater is considered to be an "unregulated emissions unit" (see page 29 of DEP Form No. 62-210.900(1) - Instructions). The heater is therefore an "unregulated emissions unit."}

Recordkeeping Requirements

B.1. Recordkeeping Requirements from NSPS 40 CFR 60, Subpart Dc. The owner or operator of each affected emissions unit (heater) shall record and maintain records of the natural gas combusted by the heater during each calendar month. The records shall be retained for a period of at least 5 (five) years following the date of such record. [40 CFR 60.48c(g)(2) & (i); and, Rule 62-213.440, F.A.C.]

NSPS 40 CFR 60 Requirements

B.2. NSPS Requirements - Subpart A. This emissions unit shall comply with all applicable requirements of 40 CFR 60, Subpart A, General Provisions, including:

40 CFR 60.7, Notification and Recordkeeping
40 CFR 60.8, Performance Tests
40 CFR 60.11, Compliance with Standards and Maintenance Requirements
40 CFR 60.12, Circumvention
40 CFR 60.13, Monitoring Requirements
40 CFR 60.19, General Notification and Reporting Requirements,

which have been adopted by reference in Rule 62-204.800(8)(d), F.A.C.; except that the Secretary is not the Administrator for purposes of 40 CFR 60.4, 40 CFR 60.8(b)(2) and (3), 40 CFR 60.11(e)(7) and (8), 40 CFR 60.13(g), (i) and (j)(2), and 40 CFR 60.16. This emissions unit shall comply with all applicable provisions of **Appendix 40 CFR 60 Subpart A** included with this permit, which includes applicable requirements that apply in general to all emission units regulated under 40 CFR 60, Subpart A. This appendix also contains useful information like definitions (see 40 CFR 60.2) and units and abbreviations (see 40 CFR 60.3). [Rule 62-204.800(8)(d), F.A.C.]

B.3. NSPS Requirements - Subpart Dc. Except as otherwise provided in this permit, this emissions unit shall comply with all applicable provisions of 40 CFR 60, Subpart Dc, Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units, adopted by reference in Rule 62-204.800(8)(b)4., F.A.C., except that the Secretary is not the Administrator for purposes of 40 CFR 60.48c(a)(4). This emissions unit shall comply with **Appendix 40 CFR 60 Subpart Dc** included with this permit, which includes applicable requirements that apply in general to all emission units regulated under 40 CFR 60, Subpart Dc. This appendix also contains useful information like definitions (see 40 CFR 60.41c) and reporting & recordkeeping requirements (see 40 CFR 60.48c). [Rule 62-204.800(8)(b)4., F.A.C.]

Subsection B. Emissions Units 005
13.5 mmBtu/hr Indirect Fuel-fired Natural Gas Heater

{Permitting note: NSPS 40 CFR 60, Subpart Dc does not specify any emission standards for units that combust only natural gas. Only the requirements for notification and recordkeeping apply.}

SECTION IV. ACID RAIN PART.

Federal Acid Rain Provisions

Operated by: DeSoto County Generating Company, LLC
Plant Name: DeSoto County Energy Park
ORIS Code: 55422

This Subsection addresses Acid Rain, Phase II SO_2.

The emissions units listed below are regulated under Phase II SO_2 of the federal Acid Rain Program.

E.U. ID No.	EPA Unit ID#	Brief Description
001	CT1	Nominal 170 MW Simple Cycle Turbine
002	CT2	Nominal 170 MW Simple Cycle Turbine

1. Acid Rain Part Application. The Phase II SO_2 Acid Rain Part application submitted for this facility, as approved by the Department, is a part of this permit. The owners and operators of these Phase II acid rain units must comply with the standard requirements and special provisions set forth in the application listed below:

U.S. EPA Form No. 7610-16 (Revised 12-2009), signed by the Designated Representative on May 29, 2012, which is included at the end of this subsection.
[Chapter 62-213, F.A.C.; and, Rule 62-214.320, F.A.C.]

2. Sulfur Dioxide (SO_2) Emission Allowances. SO_2 emissions from sources subject to the Federal Acid Rain Program (Title IV) shall not exceed any allowances that the source lawfully holds under the Federal Acid Rain Program. Allowances shall not be used to demonstrate compliance with a non-Title IV applicable requirement of the Act.

a. No permit revision shall be required for increases in emissions that are authorized by allowances acquired pursuant to the Federal Acid Rain Program, provided that such increases do not require a permit revision pursuant to Rule 62-213.400(3), F.A.C.
b. No limit shall be placed on the number of allowances held by the source under the Federal Acid Rain Program.
c. Allowances shall be accounted for under the Federal Acid Rain Program.
[Rule 62-213.440(1)(c)1., 2. & 3., F.A.C.]

3. Comments, Notes, and Justifications. The U.S. EPA form is more current than the DEP Form effective 03/16/2008.

United States
Environmental Protection Agency
Acid Rain Program

OMB No. 2060-0258
Approval expires 11/30/2012

Acid Rain Permit Application

For more information, see instructions and 40 CFR 72.30 and 72.31.

This submission is: ~ new ~ revised (~) for Acid Rain permit renewal

STEP 1

Identify the facility name, State, and plant (ORIS) code.

Desoto County Energy Park Facility (Source) Name	Florida State	55422 Plant Code

STEP 2

Enter the unit ID# for every affected unit at the affected source in column "a."

a	b
Unit ID#	Unit Will Hold Allowances in Accordance with 40 CFR 72.9(c)(1)
CT1 (EU 001)	Yes
CT2 (EU 002)	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes

EPA Form 7610-16 (Revised 12-2009)

Error! AutoText entry not defined.
Facility (Source) Name (from STEP 1)

Acid Rain - Page 2

STEP 3

Read the standard requirements.

Permit Requirements

(1) The designated representative of each affected source and each affected unit at the source shall:

(i) Submit a complete Acid Rain permit application (including a compliance plan) under 40 CFR part 72 in accordance with the deadlines specified in 40 CFR 72.30; and

(ii) Submit in a timely manner any supplemental information that the permitting authority determines is necessary in order to review an Acid Rain permit application and issue or deny an Acid Rain permit;

(2) The owners and operators of each affected source and each affected unit at the source shall:

(i) Operate the unit in compliance with a complete Acid Rain permit application or a superseding Acid Rain permit issued by the permitting authority; and

(ii) Have an Acid Rain Permit.

Monitoring Requirements

(1) The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75.

(2) The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the source or unit, as appropriate, with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.

(3) The requirements of 40 CFR part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.

Sulfur Dioxide Requirements

(1) The owners and operators of each source and each affected unit at the source shall:

(i) Hold allowances, as of the allowance transfer deadline, in the source's compliance account (after deductions under 40 CFR 73.34(c)), not less than the total annual emissions of sulfur dioxide for the previous calendar year from the affected units at the source; and

(ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.

(2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.

(3) An affected unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:

(i) Starting January 1, 2000, an affected unit under 40 CFR 72.6(a)(2); or

(ii) Starting on the later of January 1, 2000 or the deadline for monitor certification under 40 CFR part 75, an affected unit under 40 CFR 72.6(a)(3).

EPA Form 7610-16 (Revised 12-2009)

Error! AutoText entry not defined.
Facility (Source) Name (from STEP 1)

Acid Rain - Page 3

Sulfur Dioxide Requirements, Cont'd.

STEP 3, Cont'd.

(4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
(5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
(6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
(7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

Nitrogen Oxides Requirements

The owners and operators of the source and each affected unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

Excess Emissions Requirements

(1) The designated representative of an affected source that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77.
(2) The owners and operators of an affected source that has excess emissions in any calendar year shall:
(i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR part 77; and
(ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77.

Recordkeeping and Reporting Requirements

(1) Unless otherwise provided, the owners and operators of the source and each affected unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the Administrator or permitting authority:
(i) The certificate of representation for the designated representative for the source and each affected unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;

EPA Form 7610-16 (Revised 12-2009)

Error! AutoText entry not defined.
Facility (Source) Name (from STEP 1)

Acid Rain - Page 4

Recordkeeping and Reporting Requirements, Cont'd.

STEP 3, Cont'd.

(ii) All emissions monitoring information, in accordance with 40 CFR part 75, provided that to the extent that 40 CFR part 75 provides for a 3-year period for recordkeeping, the 3-year period shall apply.
(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and,
(iv) Copies of all documents used to complete an Acid Rain permit application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.
(2) The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR part 72 subpart I and 40 CFR part 75.

Liability

(1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain permit application, an Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.
(2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.
(3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.
(4) Each affected source and each affected unit shall meet the requirements of the Acid Rain Program.
(5) Any provision of the Acid Rain Program that applies to an affected source (including a provision applicable to the designated representative of an affected source) shall also apply to the owners and operators of such source and of the affected units at the source.
(6) Any provision of the Acid Rain Program that applies to an affected unit (including a provision applicable to the designated representative of an affected unit) shall also apply to the owners and operators of such unit.
(7) Each violation of a provision of 40 CFR parts 72, 73, 74, 75, 76, 77, and 78 by an affected source or affected unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

Effect on Other Authorities

No provision of the Acid Rain Program, an Acid Rain permit application, an Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8 shall be construed as:
(1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an affected source or affected unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating

EPA Form 7610-16 (Revised 12-2009)

Error! AutoText entry not defined.
Facility (Source) Name (from STEP 1)

Acid Rain - Page 5

representative of an affected source or affected unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating

STEP 3, Cont'd.

Effect on Other Authorities, Cont'd.

to applicable National Ambient Air Quality Standards or State Implementation Plans;
(2) Limiting the number of allowances a source can hold; *provided,* that the number of allowances held by the source shall not affect the source's obligation to comply with any other provisions of the Act;
(3) Requiring a change of any kind in any State law regulating electric utility rates and charges, affecting any State law regarding such State regulation, or limiting such State regulation, including any prudence review requirements under such State law;
(4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,
(5) Interfering with or impairing any program for competitive bidding for power supply in a State in which such program is established.

STEP 4
Read the certification statement, sign, and date.

Certification

I am authorized to make this submission on behalf of the owners and operators of the affected source or affected units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name DALE GRAY	
Signature	Date 5-29-2012

EPA Form 7610-16 (Revised 12-2000)

CLEAN AIR INTERSTATE RULE PROVISIONS

Clean Air Interstate Rule (CAIR).

Operated by: DeSoto County Generating Company, LLC
Plant Name: DeSoto County Energy Park
ORIS Code: 55422

This Subsection addresses CAIR.

The emissions units below are regulated under the Clean Air Interstate Rule.

E.U. ID No.	EPA Unit ID#	Brief Description
001	CT1	Nominal 170 MW Simple Cycle Turbine
002	CT2	Nominal 170 MW Simple Cycle Turbine

1. Clean Air Interstate Rule Application. The Clean Air Interstate Rule Part Form submitted for this facility is a part of this permit. The owners and operators of these CAIR units as identified in this form must comply with the standard requirements and special provisions set forth in the CAIR Part Form (DEP Form No. 62-210.900(1)(b) - Form, Effective: 3/16/08), which is attached at the end of this subsection. [Chapter 62-213, F.A.C. and Rule 62-210.200, F.A.C.]

2. Comments, Notes, and Justifications. None.

Clean Air Interstate Rule (CAIR) Part

For more information, see instructions and refer to 40 CFR 96.121, 96.122, 96.221, 96.222, 96.321 and 96.322; and Rule 62-296.470, F.A.C.

This submission is: ☐ New ☐ Revised ☒ Renewal

STEP 1

Identify the source by plant name and ORIS or EIA plant code

Plant Name:	State:	ORIS or EIA Plant Code:
Desoto County Energy Park	**Florida**	**55422**

STEP 2

In column "a" enter the unit ID# for every CAIR unit at the CAIR source.

In columns "b," "c," and "d," indicate to which CAIR program(s) each unit is subject by placing an "X" in the column(s).

For new units, enter the requested information in columns "e" and "f.

a	b	c	d	e	f
Unit ID#	Unit will hold nitrogen oxides (NO_X) allowances in accordance with 40 CFR 96.106(c)(1)	Unit will hold sulfur dioxide (SO_2) allowances in accordance with 40 CFR 96.206(c)(1)	Unit will hold NO_X Ozone Season allowances in accordance with 40 CFR 96.306(c)(1)	New Units Expected Commence Commercial Operation Date	New Units Expected Monitor Certification Deadline
CT1	X	X	X		
CT2	X	X	X		

DEP Form No. 62-210.900(1)(b) – Form
Effective: 3/16/08

1

Desoto County Energy Park
Plant Name (from STEP 1)

STEP 3

Read the standard requirements.

CAIR NO_X ANNUAL TRADING PROGRAM

CAIR Part Requirements.

(1) The CAIR designated representative of each CAIR NO_X source and each CAIR NO_x unit at the source shall:
(i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.122 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
(ii) [Reserved];
(2) The owners and operators of each CAIR NO_X source and each CAIR NO_X unit at the source shall have a CAIR Part included in the Title V operating permit issued by the DEP under 40 CFR Part 96, Subpart CC, and operate the source and the unit in compliance with such CAIR Part.

Monitoring, Reporting, and Recordkeeping Requirements.

(1) The owners and operators, and the CAIR designated representative, of each CAIR NO_X source and each CAIR NO_X unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96, Subpart HH, and Rule 62-296.470, F.A.C.
(2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HH, shall be used to determine compliance by each CAIR NO_X source with the following CAIR NO_X Emissions Requirements.

NO_X Emission Requirements.

(1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO_X source and each CAIR NO_X unit at the source shall hold, in the source's compliance account, CAIR NO_X allowances available for compliance deductions for the control period under 40 CFR 96.154(a) in an amount not less than the tons of total NO_X emissions for the control period from all CAIR NO_X units at the source, as determined in accordance with 40 CFR Part 96, Subpart HH.
(2) A CAIR NO_X unit shall be subject to the requirements under paragraph (1) of the NO_X Requirements starting on the later of January 1, 2009, or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.170(b)(1) or (2) and for each control period thereafter.
(3) A CAIR NO_X allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the NO_X Requirements, for a control period in a calendar year before the year for which the CAIR NO_X allowance was allocated.
(4) CAIR NO_X allowances shall be held in, deducted from, or transferred into or among CAIR NO_X Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FF and GG.
(5) A CAIR NO_X allowance is a limited authorization to emit one ton of NO_X in accordance with the CAIR NO_X Annual Trading Program. No provision of the CAIR NO_X Annual Trading Program, the CAIR Part, or an exemption under 40 CFR 96.105 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
(6) A CAIR NO_X allowance does not constitute a property right.
(7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart EE, FF, or GG, every allocation, transfer, or deduction of a CAIR NO_X allowance to or from a CAIR NO_X unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR NO_X unit.

Excess Emissions Requirements.

If a CAIR NO_X source emits NO_X during any control period in excess of the CAIR NO_X emissions limitation, then:
(1) The owners and operators of the source and each CAIR NO_X unit at the source shall surrender the CAIR NO_X allowances required for deduction under 40 CFR 96.154(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and
(2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AA, the Clean Air Act, and applicable state law.

Recordkeeping and Reporting Requirements.

(1) Unless otherwise provided, the owners and operators of the CAIR NO_X source and each CAIR NO_X unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the DEP or the Administrator.
(i) The certificate of representation under 40 CFR 96.113 for the CAIR designated representative for the source and each CAIR NO_X unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 96.113 changing the CAIR designated representative.
(ii) All emissions monitoring information, in accordance with 40 CFR Part 96, Subpart HH, of this part, provided that to the extent that 40 CFR Part 96, Subpart HH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.
(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO_X Annual Trading Program.
(iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR NO_X Annual Trading Program or to demonstrate compliance with the requirements of the CAIR NO_X Annual Trading Program.
(2) The CAIR designated representative of a CAIR NO_X source and each CAIR NO_X unit at the source shall submit the reports required under the CAIR NO_X Annual Trading Program, including those under 40 CFR Part 96, Subpart HH.

Desoto County Energy Park
Plant Name (from STEP 1)

STEP 3, Continued

Liability.

(1) Each CAIR NO_X source and each CAIR NO_X unit shall meet the requirements of the CAIR NO_X Annual Trading Program.
(2) Any provision of the CAIR NO_X Annual Trading Program that applies to a CAIR NO_X source or the CAIR designated representative of a CAIR NO_X source shall also apply to the owners and operators of such source and of the CAIR NO_X units at the source.
(3) Any provision of the CAIR NO_X Annual Trading Program that applies to a CAIR NO_X unit or the CAIR designated representative of a CAIR NO_X unit shall also apply to the owners and operators of such unit.

Effect on Other Authorities.

No provision of the CAIR NO_X Annual Trading Program, a CAIR Part, or an exemption under 40 CFR 96.105 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO_X source or CAIR NO_X unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

CAIR SO_2 TRADING PROGRAM

CAIR Part Requirements.

(1) The CAIR designated representative of each CAIR SO_2 source and each CAIR SO_2 unit at the source shall:
(i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.222 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
(ii) [Reserved];
(2) The owners and operators of each CAIR SO_2 source and each CAIR SO_2 unit at the source shall have a CAIR Part included in the Title V operating permit issued by the DEP under 40 CFR Part 96, Subpart CCC, for the source and operate the source and each CAIR unit in compliance with such CAIR Part.

Monitoring, Reporting, and Recordkeeping Requirements.

(1) The owners and operators, and the CAIR designated representative, of each CAIR SO_2 source and each SO_2 CAIR unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96 ,Subpart HHH, and Rule 62-296.470, F.A.C.
(2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HHH, shall be used to determine compliance by each CAIR SO_2 source with the following CAIR SO_2 Emission Requirements.

SO_2 Emission Requirements.

(1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR SO_2 source and each CAIR SO_2 unit at the source shall hold, in the source's compliance account, a tonnage equivalent in CAIR SO_2 allowances available for compliance deductions for the control period, as determined in accordance with 40 CFR 96.254(a) and (b), not less than the tons of total sulfur dioxide emissions for the control period from all CAIR SO_2 units at the source, as determined in accordance with 40 CFR Part 96, Subpart HHH.
(2) A CAIR SO_2 unit shall be subject to the requirements under paragraph (1) of the Sulfur Dioxide Emission Requirements starting on the later of January 1, 2010 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.270(b)(1) or (2) and for each control period thereafter.
(3) A CAIR SO_2 allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the SO_2 Emission Requirements, for a control period in a calendar year before the year for which the CAIR SO_2 allowance was allocated.
(4) CAIR SO_2 allowances shall be held in, deducted from, or transferred into or among CAIR SO_2 Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FFF and GGG.
(5) A CAIR SO_2 allowance is a limited authorization to emit sulfur dioxide in accordance with the CAIR SO_2 Trading Program. No provision of the CAIR SO_2 Trading Program, the CAIR Part, or an exemption under 40 CFR 96.205 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
(6) A CAIR SO_2 allowance does not constitute a property right.
(7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart FFF or GGG, every allocation, transfer, or deduction of a CAIR SO_2 allowance to or from a CAIR SO_2 unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR SO_2 unit.

Excess Emissions Requirements.

If a CAIR SO_2 source emits SO_2 during any control period in excess of the CAIR SO_2 emissions limitation, then:
(1) The owners and operators of the source and each CAIR SO_2 unit at the source shall surrender the CAIR SO_2 allowances required for deduction under 40 CFR 96.254(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and
(2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AAA, the Clean Air Act, and applicable state law.

DEP Form No. 62-210.900(1)(b) – Form
Effective: 3/16/08

3

Desoto County Energy Park
Plant Name (from STEP 1)

STEP 3, Continued

Recordkeeping and Reporting Requirements.

(1) Unless otherwise provided, the owners and operators of the CAIR SO_2 source and each CAIR SO_2 unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Department or the Administrator.

(i) The certificate of representation under 40 CFR 96.213 for the CAIR designated representative for the source and each CAIR SO_2 unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 96.213 changing the CAIR designated representative.

(ii) All emissions monitoring information, in accordance with 40 CFR Part 96, Subpart HHH, of this part, provided that to the extent that 40 CFR Part 96, Subpart HHH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR SO_2 Trading Program.

(iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR SO_2 Trading Program or to demonstrate compliance with the requirements of the CAIR SO_2 Trading Program.

(2) The CAIR designated representative of a CAIR SO_2 source and each CAIR SO_2 unit at the source shall submit the reports required under the CAIR SO_2 Trading Program, including those under 40 CFR Part 96, Subpart HHH.

Liability.

(1) Each CAIR SO_2 source and each CAIR SO_2 unit shall meet the requirements of the CAIR SO_2 Trading Program.

(2) Any provision of the CAIR SO_2 Trading Program that applies to a CAIR SO_2 source or the CAIR designated representative of a CAIR SO_2 source shall also apply to the owners and operators of such source and of the CAIR SO_2 units at the source.

(3) Any provision of the CAIR SO_2 Trading Program that applies to a CAIR SO_2 unit or the CAIR designated representative of a CAIR SO_2 unit shall also apply to the owners and operators of such unit.

Effect on Other Authorities.

No provision of the CAIR SO_2 Trading Program, a CAIR Part, or an exemption under 40 CFR 96.205 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR SO_2 source or CAIR SO_2 unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

CAIR NO_x OZONE SEASON TRADING PROGRAM

CAIR Part Requirements.

(1) The CAIR designated representative of each CAIR NO_X Ozone Season source and each CAIR NO_X Ozone Season unit at the source shall:

(i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.322 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and

(ii) [Reserved];

(2) The owners and operators of each CAIR NO_X Ozone Season source required to have a Title V operating permit or air construction permit, and each CAIR NO_X Ozone Season unit required to have a Title V operating permit or air construction permit at the source shall have a CAIR Part included in the Title V operating permit or air construction permit issued by the DEP under 40 CFR Part 96, Subpart CCCC, for the source and operate the source and the unit in compliance with such CAIR Part.

Monitoring, Reporting, and Recordkeeping Requirements.

(1) The owners and operators, and the CAIR designated representative, of each CAIR NO_X Ozone Season source and each CAIR NO_X Ozone Season unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96, Subpart HHHH, and Rule 62-296.470, F.A.C.

(2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HHHH, shall be used to determine compliance by each CAIR NO_X Ozone Season source with the following CAIR NO_X Ozone Season Emissions Requirements.

NO_X Ozone Season Emission Requirements.

(1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO_X Ozone Season source and each CAIR NO_X Ozone Season unit at the source shall hold, in the source's compliance account, CAIR NO_X Ozone Season allowances available for compliance deductions for the control period under 40 CFR 96.354(a) in an amount not less than the tons of total NO_X emissions for the control period from all CAIR NO_X Ozone Season units at the source, as determined in accordance with 40 CFR Part 96, Subpart HHHH.

(2) A CAIR NO_X Ozone Season unit shall be subject to the requirements under paragraph (1) of the NO, Ozone Season Emission Requirements starting on the later of May 1, 2009 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.370(b)(1),(2), or (3) and for each control period thereafter.

(3) A CAIR NO_X Ozone Season allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the NO_X Ozone Season Emission Requirements, for a control period in a calendar year before the year for which the CAIR NO_X Ozone Season allowance was allocated.

(4) CAIR NO_X Ozone Season allowances shall be held in, deducted from, or transferred into or among CAIR NO_X Ozone Season Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FFFF and GGGG.

(5) A CAIR NO_X Ozone Season allowance is a limited authorization to emit one ton of NO_X in accordance with the CAIR NO_X Ozone Season Trading Program. No provision of the CAIR NO_X Ozone Season Trading Program, the CAIR Part, or an exemption under 40 CFR 96.305 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.

(6) A CAIR NO_X Ozone Season allowance does not constitute a property right.

(7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart EEEE, FFFF or GGGG, every allocation, transfer, or deduction of a

DEP Form No. 62-210.900(1)(b) – Form
Effective: 3/16/08

4

provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
(6) A CAIR NO_X Ozone Season allowance does not constitute a property right.
(7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart EEEE, FFFF or GGGG, every allocation, transfer, or deduction of a CAIR NO_X Ozone Season allowance to or from a CAIR NO_X Ozone Season unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR NO_X Ozone Season unit.

Desoto County Energy Park
Plant Name (from STEP 1)

STEP 3, Continued

Excess Emissions Requirements.

If a CAIR NO_X Ozone Season source emits NO_X during any control period in excess of the CAIR NO_X Ozone Season emissions limitation, then:
(1) The owners and operators of the source and each CAIR NO_X Ozone Season unit at the source shall surrender the CAIR NO_X Ozone Season allowances required for deduction under 40 CFR 96.354(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and
(2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AAAA, the Clean Air Act, and applicable state law.

Recordkeeping and Reporting Requirements.

(1) Unless otherwise provided, the owners and operators of the CAIR NO_X Ozone Season source and each CAIR NO_X Ozone Season unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the DEP or the Administrator.
(i) The certificate of representation under 40 CFR 96.313 for the CAIR designated representative for the source and each CAIR NO_X Ozone Season unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 96.113 changing the CAIR designated representative.
(ii) All emissions monitoring information, in accordance with 40 CFR Part 96, Subpart HHHH, of this part, provided that to the extent that 40 CFR Part 96, Subpart HHHH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.
(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO_X Ozone Season Trading Program.
(iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR NO_X Ozone Season Trading Program or to demonstrate compliance with the requirements of the CAIR NO_X Ozone Season Trading Program.
(2) The CAIR designated representative of a CAIR NO_X Ozone Season source and each CAIR NO_X Ozone Season unit at the source shall submit the reports required under the CAIR NO_X Ozone Season Trading Program, including those under 40 CFR Part 96, Subpart HHHH.

Liability.

(1) Each CAIR NO_X Ozone Season source and each CAIR NO_X Ozone Season unit shall meet the requirements of the CAIR NO_X Ozone Season Trading Program.
(2) Any provision of the CAIR NO_X Ozone Season Trading Program that applies to a CAIR NO_X Ozone Season source or the CAIR designated representative of a CAIR NO_X Ozone Season source shall also apply to the owners and operators of such source and of the CAIR NO_X Ozone Season units at the source.
(3) Any provision of the CAIR NO_X Ozone Season Trading Program that applies to a CAIR NO_X Ozone Season unit or the CAIR designated representative of a CAIR NO_X Ozone Season unit shall also apply to the owners and operators of such unit.

Effect on Other Authorities.

No provision of the CAIR NO_X Ozone Season Trading Program, a CAIR Part, or an exemption under 40 CFR 96.305 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO_X Ozone Season source or CAIR NO_X Ozone Season unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

STEP 4

Read the certification statement; provide name, title, owner company name, phone, and e-mail address; sign, and date.

Certification (for designated representative or alternate designated representative only)

I am authorized to make this submission on behalf of the owners and operators of the CAIR source or CAIR units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Dale Gray Name	Title
Desoto County Generating Company, LLC Company Owner Name	
(650) 515 - 5347 Phone	**dgray@lspower.com** E-mail Address
Signature Dale Gray	Date 5-29-2012

DEP Form No. 62-210.900(1)(b) – Form

SECTION VI. APPENDICES.

The Following Appendices are Enforceable Parts of This Permit:

Appendix 40 CFR 60 Subpart A, NSPS General Provisions (version dated 02/05/2010).
Appendix 40 CFR 60, Subpart Dc, Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units (version dated 08/14/2009).
Appendix 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines (version dated 07/08/2004).

Appendix A, Glossary.
Appendix I, List of Insignificant Emissions Units and/or Activities.
Appendix RR, Facility-wide Reporting Requirements.
Appendix TR, Facility-wide Testing Requirements.
Appendix TV, Title V General Conditions.