FINAL DETERMINATION

PERMITTEE

JEA
21 West Church Street
Jacksonville, Florida 32202

PERMITTING AUTHORITY

Florida Department of Environmental Protection
Division of Air Resource Management
Office of Permitting and Compliance
2600 Blairstone Road
Tallahassee, Florida 32399

PROJECT

Air Permit No. 0310045-040-AC
Minor Source Air Construction Permit
Northside Generating Station

JEA proposed to commence a project to test the effectiveness of reintroduction of a mixture of bottom ash and fly ash into the boilers at Northside Generating Station. This ash contains lime, which should assist in the control of emissions of sulfur dioxide. The project includes multiple measurements of its effects on mercury emissions and changes in ash composition.

NOTICE AND PUBLICATION

The Department distributed a draft minor source air construction permit package on November 14, 2014. The applicant published the Public Notice in the Financial News & Daily Record on November 18, 2014. The Department received the proof of publication on November 21, 2014. No requests for administrative hearings or requests for extensions of time to file a petition for administrative hearing were received.

COMMENTS

No comments on the Draft Permit were received from the public, the Department's Northeast District Office, the EPA Region 4 Office or the applicant.

CONCLUSION

The final action is to issue the permit with no changes from the draft permit.