

FINAL DETERMINATION

PERMITTEE

White Springs Agricultural Chemicals, Inc.
Post Office Box 300
White Springs, FL 32096

PERMITTING AUTHORITY

Florida Department of Environmental Protection
Northeast District Office, Air Program
8800 Baymeadows Way West, Suite 100
Jacksonville, FL 32256

PROJECT

Air Permit No. 0470002-082-AC
Air Construction Permit
Rental Steam Generating Unit

NOTICE AND PUBLICATION

An "INTENT TO ISSUE AN AIR PERMIT" to White Springs Agricultural Chemicals, Inc for the Suwannee River/Swift Creek Complex located at east of State Road (SR) 137, east of US 41, North of White Springs, Florida, Hamilton County, Florida was clerked on February 1, 2013. The "PUBLIC NOTICE OF INTENT TO ISSUE AN AIR PERMIT" was published in the Jasper News newspaper on February 14, 2013. Proof of publication of the "PUBLIC NOTICE OF INTENT TO ISSUE AN AIR PERMIT" was received on February 19, 2013.

COMMENTS

A comment/question was received from the applicant on February 1, 2013.

Comment: Should the testing condition A.15.e., include an annual test exemption for natural gas? It is suggested to reword the condition language as follows:

"By permit, this annual visible emissions test shall not be required should the unit fire natural gas; or, low sulfur No. 2 fuel oil for a total of less than 400 hours during the year."

Response: The Department concurs with the comment. As stated in the Technical Evaluation and Preliminary Determination dated February 1, 2013, the Department's intent was to only required the annual/Each Federal Fiscal Year VE testing if the boiler fired the low sulfur No. 2 fuel oil for 400 or more hours in a given year. Since this was stated in the Technical Evaluation, the Department considers this permit language change to be typographical in nature and therefore makes the change in the final construction permit.

CONCLUSION

The final action is to issue the permit with the minor changes, corrections and clarifications as described above.