FINAL DETERMINATION

PERMITTEE

United States Sugar Corporation
111 Ponce De Leon Avenue
Clewiston, Florida 33440

PERMITTING AUTHORITY

Florida Department of Environmental Protection
Engineering and Permitting Section
South District Office
2295 Victoria Avenue, Suite 364
Fort Myers, Florida 33901-2549

PROJECT

Air Permit No. Air Permit No. 0510003-056-AC
Air Construction Permit
U.S. Sugar Clewiston Facility

The proposed project will replace the sides and rear waterwalls in Boiler No. 7 with modern membrane style waterwalls. Project was subject to PSD applicability review and avoided PSD review.

NOTICE AND PUBLICATION

The Department distributed a draft minor source air construction permit package on May 30, 2013. The applicant published the Public Notice in the Clewiston News on June 6, 2013. The Department received the proof of publication on June 10, 2013. No requests for administrative hearings or requests for extensions of time to file a petition for administrative hearing were received.

COMMENTS

No comments on the Draft Permit were received from the public, or the applicant. However, the Department made a change to clarify actual emissions reporting.

Department

The last paragraph in Condition 9 in Section 2., Administrative Requirements is hereby changed as follows:

> **9.** ……For this project, the Department requires the annual reporting of actual **SO_2, NO_X, CO, PM, PM_{10}, $PM_{2.5}$** and **VOC** emissions for the following units: EU014 (Boiler No. 7). The Technical Evaluation and Preliminary Determination provides the baseline actual and projected actual emissions for project 0510003-056-AC. The Department shall use these baseline ~~and projected~~ actual emissions for the comparison to the actual emission monitored, recorded and reported over the next five years pursuant to this condition. **If ~~the~~ the actual emissions in any of the five reporting years after completion of the proposed construction project for Boiler No. 7 exceed the ~~projected actual emissions~~ baseline actual emissions plus the PSD significant emission rate, additional permitting actions will be required to address PSD applicability.**

CONCLUSION

The final action is to issue the permit with the minor changes, corrections and clarifications as described above.