Table 2-1, Compliance Testing Requirements

Duke Energy Florida, Inc. dba Duke Energy
University of Florida Cogeneration Plant

Permit ID No.: 0010001-016-AV
Facility ID No.: 0010001

Emission Unit - ID No.

Pollutant Name or Parameter	Fuel(s)	EPA Reference Method/ Requirement	Testing Time or Frequency	Frequency Base Date	Minimum Compliance Test Time	CMS	Permit Condition(s)
CT - 007							
NO_x	Gas	EPA Meth. 20	Annual			Yes	B.21.
SO_2	Gas					NG	B.21.
CO	Gas	EPA Meth. 10	Annual				B.21.
DB - 005							
NO_X	Gas	EPA Meth. 20	Annual			Yes	B.21.
CO	Gas	EPA Meth. 10	Annual				B.21.
Boiler #4 - 002							
SO_2	Oil	F.O. Analysis	Per Delivery				A.19.
VE	Gas/Oil	EPA Meth. 9	Annual		1-hour		A.17.
Boiler #5 - 003							
SO_2	Oil	F.O. Analysis	Per Delivery				A.19.
VE	Gas/Oil	EPA Meth. 9	Annual		1-hour		A.17.
Facility [E.U.'s 002, 003, 005, & 007]							
NO_X	Gas/Oil	EPA Method 20	Annual			Yes	B.29.