CP1.1. Compliance Schedule. No. 7 Power Boiler is subject to 40 CFR 60 Subpart D. RockTenn was issued an air construction permit, No. 0890003-034-AC, to install natural gas burners on the No. 7 Power Boiler. The construction permit required an initial NO_x test while burning natural gas at 160 to 240 MMBtu/hr, with the remainder of heat input due to coal. The results of the performance testing conducted on July 17, 2013, were such that the mill is required to install a NO_x CEMS pursuant to the requirements of Subpart D no later than July 17, 2014.

Because the installation of the NO_x CEMS will be completed in the future, a Compliance Plan has been incorporated into this Title V Operation Permit which includes the mill's plan and schedule for completing the installation. The permittee shall meet the following milestones:

Milestone	**Milestone Date**
Installation of NOx CEMS unit on the No. 7 Power Boiler stack.	June 2014 (tentative)
Written Notification provided to Department's NED Compliance Assurance of Intent to Perform initial Relative Accuracy Test Audit (RATA)	30 days prior to such date
Perform Initial RATA	June 2014 (tentative)
Completion of NO_x CEMS installation, certification, verification of operational status, and operation	July 17, 2014
The facility shall notify the Department's NED Compliance Assurance in writing of the achievement of compliance progress achieved, requirements met, requirements not met, corrective measures adopted, and an explanation of any measure not met by the completion date of the milestone or for compliance. All reports are to be accompanied by a certification, signed by a responsible official in accordance with Rule 62-214.420(4), F.A.C.	15-days after completion date of each stated project item.
Responsible Official to submit the Notification of Compliance Status	No later than 60 days after the conclusion NO_x CEMS certification, verification of operational status, and operation.
Once the Permittee successfully demonstrates completion of construction and completes all stated milestones, then compliance with Appendix CP-1 is complete. Permitting and Compliance demonstrations shall resume in accordance with the specific conditions of the Title V Permit.	