TABLE 2

SUMMARY OF COMPLIANCE REQUIREMENTS– VALID THROUGH MAY 31, 2012

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description	Fuel	Pollutant Name	Emission Control	Compliance Method EPA Method	Testing Time Frequency	Frequency Base Date	Min. Compliance Test Duration	See Permit Conditions
002	HMIWI	Natural Gas	PM	Scrubber	EPA Method 5	Annual	Previous Test	1 hr/run	A.26., A.27., A.30.
			CO		EPA Method 10/10B	Annual	Previous Test	1 hr/run	A.26., A.27., A.30.
			Dioxins/ Furans	Scrubber	EPA Method 23	Renewal		4 hr/run	A.26., A.27., A.32.
			HCl	Scrubber	EPA Method 26	Annual	Previous Test	1 hr/run	A.26., A.27., A.30.
			SO^2	Scrubber	EPA Method 6/6C	Renewal		1 hr/run	A.26., A.27., A.32.
			NOx		EPA Method 7/7E	Renewal		1 hr/run	A.26., A.27., A.32.
			Lead		EPA Method 29	Renewal		1 hr/run	A.26., A.27., A.32.
			Cadmium		EPA Method 29	Renewal		1 hr/run	A.26., A.27., A.32.
			Mercury		EPA Method 29	Renewal		1 hr/run	A.26., A.27., A.32.
			VE		EPA Method 9	Annual		30 minutes	A.27., A.30.
003	Boiler	Natural Gas	VE		DEP Method 9	Annual		60 minutes	B.7.

TABLE 2

SUMMARY OF AIR POLLUTANT STANDARDS AND TERMS

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description	Fuel	Pollutant Name	Emission Control	Compliance Method EPA Method	Testing Time Frequency	Frequency Base Date	Min. Compliance Test Duration	See Permit Conditions
002	HMIWI	Natural Gas	PM	scrubber	EPA Method 5/26A/29	Annual	Initial Test	1 hr/run 3 runs	A.26., A.27., A.28., A.30.
			CO		EPA Method 10/10B	Annual		1 hr/run 3 runs	A.26., A.27., A.28., A.30.
			Dioxins/ Furans	scrubber	EPA Method 23	Renewal		4 hours/run 3 runs	A.26., A.27., A.28., A.32.
			HCl	scrubber	EPA Method 26/26A	Annual		1 hr/run 3 runs	A.26., A.27., A.28., A.30.
			SO2	scrubber	EPA Method 6/6C	Renewal		1 hr/run 3 runs	A.26., A.27., A.28., A.32.
			NOx		EPA Method 7/7E	Renewal		1 hr/run 3 runs	A.26., A.27., A.28., A.32.
			Lead		EPA Method 29	Annual		1 hr/run 3 runs	A.26., A.27., A.28, A.31.
			Cadmium		EPA Method 29	Annual		1 hr/run 3 runs	A.26., A.27., A.28., A.31.
			Mercury		EPA Method 29	Annual		1 hr/run 3 runs	A.26., A.27., A.28., A.31.
			VE		EPA Method 9	Annual		30 minutes	A.27., A.30.
003	Boiler		VE		EPA Method 9	Annual		60 minutes	B.7.