City of Lakeland Electric
C.D. McIntosh, Jr. Power Plant

Facility ID No. 1050004
Polk County

Title V Air Operation Permit Revision

Permit No. 1050004-036-AV
(Revision of Title V Air Operation Permit No. 1050004-033-AV)

Permitting Authority:

State of Florida
Department of Environmental Protection
Division of Air Resource Management
Office of Permitting and Compliance
2600 Blair Stone Road
Mail Station #5505
Tallahassee, Florida 32399-2400

Telephone: (850) 717-9000
Fax: (850) 717-9097

Compliance Authority:

Southwest District Office
13051 N. Telecom Parkway
Temple Terrace, Florida 33637-0926
Telephone: (813) 470-5700
Fax: (813) 470-5995

Title V Air Operation Permit Revision

Permit No. 1050004-036-AV

Table of Contents

Section **Page Number**

Placard Page 1

I. Facility Information.
- A. Facility Description. 2
- B. Summary of Emissions Units. 2
- C. Applicable Regulations. 3

II. Facility-wide Conditions. 4

III. Emissions Units and Conditions.
- A. E.U. -001 McIntosh Unit 1. 6
- B. E.U. -004 Gas Turbine Peaking Unit 1. 12
- C. E.U. -005 McIntosh Unit 2. 14
- D. E.U. -006 McIntosh Unit 3. 19
- E. E.U. -028 McIntosh Unit 5. 28
- F. E.U. -008 Diesel Drive Coal Tunnel Sump Engine. 34
- G. E.U. -010 Fire Water UPS Diesel No. 32. 37
- H. E.U. -011 CT Startup Diesel Engine. 41

IV. Acid Rain Part. 44
- Phase II Acid Rain Application/Compliance Plan.
- Phase II Acid Rain NO_X Compliance Plan.

V. Clean Air Interstate Rule Part. 51

VI. Appendices. 57
- Appendix A, Glossary.
- Appendix ASP, ASP Number 97-B-01 (With Scrivener's Order Dated July 9, 1997).
- Appendix CAM, Compliance Assurance Monitoring Plan.
- Appendix CP, Compliance Plan.
- Appendix I, List of Insignificant Emissions Units and/or Activities.
- Appendix NSPS, Subpart A – General Provisions.
- Appendix NSPS, Subpart D - Standards Of Performance For Fossil-Fuel Fired Steam Generators For Which Construction Is Commenced After August 17, 1971 (version dated 02/16/2012).
- Appendix NSPS, Subpart GG - Standards of Performance For Stationary Gas Turbines (version dated 7/8/2004).
- Appendix NESHAP, Subpart A – General Provisions.
- Appendix NESHAP, Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.
- Appendix NESHAP, Subpart UUUUU - National Emission Standards for Hazardous Air Pollutants: Coal- and Oil-Fired Electric Utility Steam Generating Units.
- Appendix RR, Facility-wide Reporting Requirements.
- Appendix TR, Facility-wide Testing Requirements.
- Appendix TV, Title V General Conditions.
- Appendix U, List of Unregulated Emissions Units and/or Activities.
- Appendix W501G McIntosh #5

Referenced Attachments. ..... At End
Figure 1, Summary Report-Gaseous and Opacity Excess Emission and Monitoring System Performance (40 CFR 60, July, 1996).
Table H, Permit History.

FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION
BOB MARTINEZ CENTER
2600 BLAIR STONE ROAD
TALLAHASSEE, FLORIDA 32399-2400

RICK SCOTT
GOVERNOR

CARLOS LOPEZ-CANTERA
LT. GOVERNOR

HERSCHEL T. VINYARD JR.
SECRETARY

PERMITTEE:
City of Lakeland Electric
501 East Lemon Street
Lakeland, Florida 33801-5079

Permit No. 1050004-036-AV
C. D. McIntosh, Jr. Power Plant
Facility ID No. 1050004
Title V Air Operation Permit Revision

The purpose of this permit is to revise the Title V air operation permit for the above referenced facility. The existing C. D. McIntosh, Jr. Power Plant is located at 3030 East Lake Parker Drive, Lakeland, in Polk County. UTM Coordinates are: Zone 17, 409.0 km East and 3106.2 km North. Latitude is: 28° 04' 50" North; and, Longitude is: 81° 55' 32" West.

The Title V air operation permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213 and 62-214. The above named permittee is hereby authorized to operate the facility in accordance with the terms and conditions of this permit.

1050004-036-AV Effective Date: June 24, 2014
1050004-033-AV Effective Date: January 1, 2014
Renewal Application Due Date: May 20, 2018
Expiration Date: December 31, 2018

David L. Read, PE
2014.07.08
13:06:52 -04'00'

for Jeffery F. Koerner, Program Administrator
Office of Permitting and Compliance
Division of Air Resource Management

JFK/dlr/sms

SECTION I. FACILITY INFORMATION.

Subsection A. Facility Description.

This facility consists of three fossil fuel fired steam generators, three diesel powered engines, and two gas turbines. Fossil fuel fired steam generator Unit 1 is fired with natural gas, No. 6 fuel oil or on-specification used oil generated by the City of Lakeland. Fossil fuel fired steam generator Unit 2 is fired with natural gas, propane, No. 2 fuel oil or No. 6 fuel oil. Fossil fuel fired steam generator 3 is fired with coal, natural gas and petroleum coke. Gas Turbine Peaking Unit 1 is primarily fired with natural gas or No. 2 fuel oil with a maximum sulfur content of 0.5 percent by weight. McIntosh Unit 5, a 370 MW combined cycle stationary combustion turbine, is fired with natural gas, or No. 2 or superior grade fuel oil with a maximum sulfur content of 0.05 percent by weight. The three diesel engines are: a 25 horsepower non-emergency Lister Coal Tunnel Sump diesel engine; a 300 horsepower emergency Fire Water UPS Diesel No. 32 engine; and a 500 horsepower black-start CT Startup Diesel engine. Also included in this permit are miscellaneous unregulated/insignificant emissions units and/or activities.

Subsection B. Summary of Emissions Units.

E.U. ID No.	Brief Description
Regulated Emissions Units	
-001	McIntosh Unit 1 - Fossil Fuel Fired Steam Generator
-004	Gas Turbine Peaking Unit 1
-005	McIntosh Unit 2 - Fossil Fuel Fired Steam Generator
-006	McIntosh Unit 3 - Fossil Fuel Fired Steam Generator
-008	Diesel drive coal tunnel sump engine
-010	Fire water UPS diesel No. 32
-011	CT startup diesel
-028	McIntosh Unit 5 - 370 MW Combined Cycle Stationary Combustion Turbine
Unregulated Emissions Units and Activities	
-007	Tanks with greater than 10,000 gallon capacity installed prior to July 23, 1984
-014	General purpose painting
-015	Parts Cleaning
-016	Sand Blasting (Maintenance only)
-017	Wastewater Treatment Tank
-018	Three Cooling Towers (Units 2 and 3)
-019	Northside Waste Water Treatment Facility - Wastewater treatment processes and tanks
-020	Northside Waste Water Treatment Facility - Four emergency diesel generators
-021	Northside Waste Water Treatment Facility - Chemical and petroleum storage
-022	Northside Waste Water Treatment Facility - Miscellaneous activities
-023	Coal processing and conveying system
-024	Coal storage system
-025	Coal transfer and loading system
-026	Limestone handling and storage system
-027	Fly ash handling and storage system

-029	1.05 million gallon storage tank for McIntosh Unit 5, subject only to the reporting requirements of 40 CFR 60, Subpart Kb
-030	Mechanical Draft Cooling Tower
-033	Portable pumps and welding equipment

Also included in this permit are miscellaneous insignificant emissions units and/or activities (see Appendix I, List of Insignificant Emissions Units and/or Activities).

Subsection C. Applicable Regulations.

Based on the Title V air operation permit renewal application received May 17, 2013, this facility is a major source of hazardous air pollutants (HAP). The existing facility is a prevention of significant deterioration (PSD) major source of air pollutants in accordance with Rule 62-212.400, F.A.C. A summary of applicable regulations is shown in the following table.

Regulation	**EU No(s).**
Federal Rule Citations	
40 CFR 60, Subpart A, Standards of Performance for New Stationary Sources (NSPS) General Provisions	-005, -006, -028
40 CFR 60, NSPS Subpart D, Standards of Performance for Fossil-Fuel Fired Steam Generators for Which Construction is Commenced After August 17, 1971	-005, -006
40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines	-028
40 CFR 63, Subpart A, General Provisions	-001, -005, -006, -008, -010, -011
40 CFR 63, Subpart ZZZZ, National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines	-008, -010, -011
40 CFR 63, Subpart UUUUU, National Emission Standards for Hazardous Air Pollutants: Coal- and Oil-Fired Electric Utility Steam Generating Units	-001, -005, -006
Acid Rain, Phase II SO_2	-001, -005, -006, -028
Acid Rain, Phase II NO_X	-006
Rule 62-296.470, F.A.C., Clean Air Interstate Rule (CAIR)	-001, -005, -006, -028
Compliance Assurance Monitoring (CAM)	-006
State Rule Citations	
Rule 62-210.300, F.A.C., Permits Required	-001, -004, -005, -006, -008, -010, -011, -028
Rule 62-212.400, F.A.C., Prevention of Significant Deterioration (PSD)	-006, -028
Rule 62-296.405, F.A.C., Fossil Fuel Steam Generators with More than 250 million Btu per Hour Heat Input	-001, -005, -006

The following conditions apply facility-wide to all emission units and activities:

FW1. Appendices. The permittee shall comply with all documents identified in Section VI, Appendices, listed in the Table of Contents. Each document is an enforceable part of this permit unless otherwise indicated. [Rule 62-213.440, F.A.C.]

Emissions and Controls

FW2. Not federally Enforceable. Objectionable Odor Prohibited. No person shall cause, suffer, allow or permit the discharge of air pollutants, which cause or contribute to an objectionable odor. An "objectionable odor" means any odor present in the outdoor atmosphere which by itself or in combination with other odors, is or may be harmful or injurious to human health or welfare, which unreasonably interferes with the comfortable use and enjoyment of life or property, or which creates a nuisance. [Rule 62-296.320(2) and 62-210.200(Definitions), F.A.C.]

FW3. General Volatile Organic Compounds (VOC) Emissions or Organic Solvents (OS) Emissions. The permittee shall allow no person to store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds or organic solvents without applying known and existing vapor emission control devices or systems deemed-necessary and ordered by the Department. [Rule 62-296.320(1), F.A.C.]

{Permitting Note: Nothing is deemed necessary and ordered at this time.}

FW4. General Visible Emissions. No person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity equal to or greater than 20% opacity. This regulation does not impose a specific testing requirement. [Rule 62-296.320(4)(b), F.A.C.]

FW5. Unconfined Particulate Matter. No person shall cause, let, permit, suffer or allow the emissions of unconfined particulate matter from any activity, including vehicular movement; transportation of materials; construction; alteration; demolition or wrecking; or industrially related activities such as loading, unloading, storing or handling; without taking reasonable precautions to prevent such emissions. Reasonable precautions to prevent emissions of unconfined particulate matter at this facility include:

a. Maintenance of paved areas.
b. Regular mowing of grass and care of vegetation.
c. Limiting access to plant property by unnecessary vehicles.

[Rule 62-296.320(4)(c), F.A.C.; and, proposed by applicant in Title V air operation permit renewal application received May 17, 2013.]

Annual Reports and Fees

See Appendix RR, Facility-wide Reporting Requirements for additional details.

FW6. Annual Operating Report. The permittee shall submit an annual report that summarizes the actual operating rates and emissions from this facility. Annual operating reports shall be submitted to the Compliance Authority by April 1st of each year. [Rule 62-210.370(3), F.A.C.]

FW7. Annual Emissions Fee Form and Fee. The annual Title V emissions fees are due (postmarked) by April 1st of each year. The completed form and calculated fee shall be submitted to: Major Air Pollution Source Annual Emissions Fee, P.O. Box 3070, Tallahassee, Florida 32315-3070. The forms are available for download by accessing the Title V Annual Emissions Fee On-line Information Center at the following Internet web site: http://www.dep.state.fl.us/Air/permitting/tvfee.htm. [Rule 62-213.205, F.A.C. and §403.0872(11), Florida Statutes (2013)]

{Permitting Note: In addition to the change in the Title V fee submission from March 1st to April 1st, Chapter 403.0872(11)(a) has been revised to require that the annual fee be calculated based upon actual emissions rather than allowable emissions, as in the past. The Department will be exploring the development of a revision to the electronic annual operating report (EAOR) application to automatically calculate the amount of the fee based upon actual emission information provided with the annual operating report. When completed, the procedures for submitting the fee and/or the submission address may change. Until further

notice, the fees shall continue to be submitted to the address shown in Specific Condition FW7 and according to instructions posted on the Department's fee information web page. Be sure to check the Title V Annual Emissions Fee On-line Information Center (see above web site address) periodically for updates, especially before submitting future Title V fee payments.}]

FW8. Annual Statement of Compliance. The permittee shall submit an annual statement of compliance to the compliance authority at the address shown on the cover of this permit within 60 days after the end of each calendar year during which the Title V permit was effective. [Rules 62-213.440(3)(a)2. & 3. and (b), F.A.C.]

FW9. Prevention of Accidental Releases (Section 112(r) of CAA).

a. As required by Section 112(r)(7)(B)(iii) of the CAA and 40 CFR 68, the owner or operator shall submit an updated Risk Management Plan (RMP) to the Chemical Emergency Preparedness and Prevention Office (CEPPO) RMP Reporting Center. (See paragraph e., below.)

b. As required under Section 252.941(1)(c), F.S., the owner or operator shall report to the appropriate representative of the Division of Emergency Management, as established by department rule, within one working day of discovery of an accidental release of a regulated substance from the stationary source, if the owner or operator is required to report the release to the United States Environmental Protection Agency under Section 112(r)(6) of the CAA.

c. The owner or operator shall submit the required annual registration fee to the Division of Emergency Management on or before April 1, in accordance with Part IV, Chapter 252, F.S., and Rule 9G-21, F.A.C.

d. Any required written reports, notifications, certifications, and data required to be sent to the Division of Emergency Management, should be sent to: Division of Emergency Management, 2555 Shumard Oak Boulevard, Tallahassee, FL 32399-2100, Telephone: (850) 413-9970, Fax: (850) 488-1739.

e. Any Risk Management Plans, original submittals, revisions, or updates to submittals, should be sent electronically through EPA's Central Data Exchange system at the following address: https://cdx.epa.gov. Information on electronically submitting risk management plans using the Central Data Exchange system is available at: http://www.epa.gov/osweroe1/content/rmp/index.htm. The RMP Reporting Center can be contacted at: RMP Reporting Center, Post Office Box 10162, Fairfax, VA 22038, Telephone: (703) 227-7650.

f. Any required reports to be sent to the National Response Center, should be sent to: National Response Center, EPA Office of Solid Waste and Emergency Response, USEPA (5305 W), 401 M Street SW, Washington, D.C. 20460, Telephone: (800) 424-8802.

g. Send the required annual registration fee using approved forms made payable to: Cashier, Division of Emergency Management, State Emergency Response Commission, 2555 Shumard Oak Boulevard, Tallahassee, FL 32399-2149

[Part IV, Chapter 252, F.S.; and, Rule 9G-21, F.A.C.]

Subsection A. Emissions Unit -001

The specific conditions in this section apply to the following emissions unit:

E.U. ID No.	Brief Description
-001	McIntosh Unit 1 - Fossil Fuel Fired Steam Generator

McIntosh Unit 1 is a forced draft boiler rated at a nominal load of 90 megawatts. The unit is fired with natural gas at a maximum heat input rate of 985 million Btu per hour (approximately 970 million cubic feet per hour), or No. 6 fuel oil, having a maximum sulfur content of 2.5 percent by weight, at a maximum heat input rate of 950 million Btu per hour (approximately 6,300 gallons per hour). This unit is also permitted to burn on-specification used oil generated by the City of Lakeland, at a maximum heat input rate of 950 million Btu per hour. McIntosh Unit 1 began commercial service in February, 1971. The stack parameters are: height, 150 feet: diameter, 9.0 feet; exit temperature, 277 degrees F; and, actual stack gas flow rate, 310,000 acfm.

{Permitting note(s): The emissions unit is regulated under Acid Rain, Phase II; Rule 62-296.405(1), F.A.C., Fossil Fuel Steam Generators with More than 250 million Btu per Hour Heat Input; and, Rule 62-296.470, F.A.C., Clean Air Interstate Rule (CAIR).}

Essential Potential to Emit (PTE) Parameters

A.1. Permitted Capacity. The maximum operation heat input rates are as follows:

Unit No.	MMBtu/hr Heat Input	Fuel Type
1	985	Natural Gas
	950	No. 6 Fuel Oil
	950	Used Oil

When a blend of fuel oil, on-specification used oil or natural gas is fired, the heat input is prorated based on the percent heat input of each fuel. The Acid Rain CEMS will not be a method of compliance for the determination of the heat input rate. [Rules 62-4.160(2), 62-210.200 (Definitions - Potential to Emit (PTE)); and, 62-296.405, F.A.C.]

{Permitting note: The heat input limitations have been placed in each permit to identify the capacity of each unit for the purposes of confirming that emissions testing is conducted within 90 to 100 percent of the unit's rated capacity (or to limit future operation to 110 percent of the test load), to establish appropriate emission limits and to aid in determining future rule applicability. Regular record keeping is not required for heat input. Instead the owner or operator is expected to determine heat input whenever emission testing is required, to demonstrate at what percentage of the rated capacity that the unit was tested. Rule 62-297.310(5), F.A.C., included in the permit, requires measurement of the process variables for emission tests. Such heat input determination may be based on measurements of fuel consumption by various methods including but not limited to fuel flow metering or tank drop measurements, using the heat value of the fuel determined by the fuel vendor or the owner or operator, to calculate average hourly heat input during the test.}

A.2. Emissions Unit Operating Rate Limitation After Testing. See the related testing provisions in Appendix TR, Facility-wide Testing Requirements. [Rule 62-297.310(2), F.A.C.]

A.3. Methods of Operation - Fuels.

a. The only fuels allowed to be burned are natural gas, propane, No. 6 Fuel Oil, On-Specification Used Oil, No. 2 Fuel Oil and combinations of natural gas, propane, No. 6 Fuel Oil, No. 2 Fuel Oil and/or On-Specification Used Oil. On-Specification used oil containing any quantifiable levels of PCBs can only be fired when the emissions unit is at normal operating temperatures. [Rule 62-213.410, F.A.C.; and, 40 CFR 271.20(e)(3)]

b. Fuel oil deliveries into the Unit 1 fuel oil storage tank shall not exceed 0.7% sulfur content, by weight. This fuel sulfur limitation shall become effective upon the effective date of EPA's approval of this specific requirement in the Florida Regional Haze State Implementation Plan. [1050004-032-AC and Rule 62-210.200(PTE), F.A.C.]

A.4. Hours of Operation. This emissions unit may operate continuously, i.e., 8,760 hours/year. [Rules 62-4.160(2) and 62-210.200 (Definitions - PTE), F.A.C.]

Emission Limitations and Standards

Unless otherwise specified, the averaging times for Specific Conditions **A.5. - A.9.** are based on the specified averaging time of the applicable test method.

A.5. Visible Emissions. Visible emissions shall not exceed 20 percent opacity, except for one two-minute period per hour during which opacity shall not exceed 40 percent. Emissions units governed by this visible emissions limit shall compliance test for particulate matter emissions annually and as otherwise required by Chapter 62-297, F.A.C. [Rule 62-296.405(1)(a), F.A.C.]

A.6. Visible Emissions - Soot Blowing and Load Change. Visible emissions shall not exceed 60 percent opacity during the 3-hours in any 24 hour period of excess emissions allowed for boiler cleaning (soot blowing) and load change. A load change occurs when the operational capacity of a unit is in the 10 percent to 100 percent capacity range, other than startup or shutdown, which exceeds 10 percent of the unit's rated capacity and which occurs at a rate of 0.5 percent per minute or more. [Rule 62-210.700(3), F.A.C.]

A.7. Particulate Matter. Particulate matter emissions shall not exceed 0.1 pound per million Btu heat input, as measured by applicable compliance methods. [Rule 62-296.405(1)(b), F.A.C.]

A.8. Particulate Matter - Soot Blowing and Load Change. Particulate matter emissions shall not exceed an average of 0.3 pound per million Btu heat input during the 3-hours in any 24-hour period of excess emissions allowed for boiler cleaning (soot blowing) and load change. [Rule 62-210.700(3), F.A.C.]

A.9. Sulfur Dioxide. When burning liquid fuel, sulfur dioxide emissions shall not exceed 2.75 pounds per million Btu heat input, as measured by applicable compliance methods. [Rule 62-296.405(1) (c)1.j., F.A.C.]

*{Permitting Note: Applicant has elected to use the Part 75 CEMS as the primary method for determining compliance with the above emission limit. Fuel sampling as specified in Specific Conditions **A.22.** and **A.23.** may be used when CEMS data is not available. }*

A.10. Sulfur Dioxide - Sulfur Content. The No. 6 fuel oil sulfur content shall not exceed 2.5 percent, by weight when CEMS are not utilized for compliance. [Rule 62-296.405(1)(e)3.& 62-213.440(1), F.A.C.]

Excess Emissions

Rule 62-210.700 (Excess Emissions), F.A.C. cannot vary any requirement of an NSPS, NESHAP or Acid Rain program provision.

A.11. Excess Emissions Allowed - Malfunctions. Excess emissions resulting from malfunction shall be permitted providing (1) best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration. [Rule 62-210.700(1), F.A.C.]

A.12. Excess Emissions Allowed - Startup And Shutdown. Excess emissions resulting from startup or shutdown shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized. [Rule 62-210.700(2), F.A.C.]

A.13. Excess Emissions Prohibited. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. [Rule 62-210.700(4), F.A.C.]

Continuous Monitoring Requirements

A.14. Sulfur Dioxide. The permittee elected to demonstrate compliance by accepting a liquid fuel sulfur limit that will be verified with fuel analysis provided by the vendor or the permittee upon each fuel delivery. This protocol is allowed because the emissions unit does not have an operating flue gas desulfurization device. As an alternative, the acid rain required continuous emission monitoring system for sulfur dioxide may be used

for emissions determination and reporting. [40 CFR 75; and, Rules 62-213.440(1) & 62-296.405(1)(f)1.b., F.A.C.]

Test Methods and Procedures

A.15. Test Methods. Required tests shall be performed in accordance with the following reference methods:

Method(s)	Description of Method(s) and Comment(s)
EPA Methods 1-4	Traverse Points, Velocity and Flow Rate, Gas Analysis, and Moisture Content
EPA Methods 17, 5, 5B, or 5F	Methods for Determining Particulate Matter Emissions
EPA Method 19	Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide, and Nitrogen Oxides Emission Rates (Optional F-factor method may be used to determine flow rate and gas analysis to calculate mass emissions in lieu of Methods 1-4.)
DEP Method 9	Visual Determination of the Opacity of Emissions

The above methods are described in Chapter 62-297, F.A.C. No other methods may be used unless prior written approval is received from the Department. [Chapter 62-297, F.A.C.]

A.16. Annual Compliance Tests. Unless otherwise specified by this permit, during each federal fiscal year (October 1st to September 30th), this emissions unit shall be tested to demonstrate compliance with the emission limitations and standards for visible emissions (VE) and particulate matter (PM) emissions. [Rule 62-297.310(7), F.A.C.]

A.17. Compliance Tests Prior To Renewal. Prior to permit renewal, compliance tests shall be performed for the following pollutants: VE and PM. [Rule 62-297.310(7)(a)3., F.A.C.]

A.18. Common Testing Requirements. Unless otherwise specified, tests shall be conducted in accordance with the requirements and procedures specified in Appendix TR, Facility-Wide Testing Requirements, of this permit. [Rule 62-297.310, F.A.C.]

A.19. Visible emissions. The test method for visible emissions shall be DEP Method 9, incorporated in Chapter 62-297, F.A.C. A transmissometer may be used and calibrated according to Rule 62-297.520, F.A.C. [Rule 62-296.405(1)(e)1., F.A.C.]

A.20. DEP Method 9. The provisions of EPA Method 9 (40 CFR 60, Appendix A) are adopted by reference with the following exceptions:

a. EPA Method 9, Section 2.4, Recording Observations. Opacity observations shall be made and recorded by a certified observer at sequential fifteen second intervals during the required period of observation.
b. EPA Method 9, Section 2.5, Data Reduction. For a set of observations to be acceptable, the observer shall have made and recorded, or verified the recording of, at least 90 percent of the possible individual observations during the required observation period. For single-valued opacity standards (e.g., 20 percent opacity), the test result shall be the highest valid six-minute average for the set of observations taken. For multiple-valued opacity standards (e.g., 20 percent opacity, except that an opacity of 40 percent is permissible for not more than two minutes per hour) opacity shall be computed as follows:
   (1) For the basic part of the standard (i.e., 20 percent opacity) the opacity shall be determined as specified above for a single-valued opacity standard.
   (2) For the short-term average part of the standard, opacity shall be the highest valid short-term average (i.e., two-minute, three-minute average) for the set of observations taken.

   In order to be valid, any required average (i.e., a six-minute or two-minute average) shall be based on all of the valid observations in the sequential subset of observations selected, and the selected subset shall contain at least 90 percent of the observations possible for the required averaging time. Each required average shall be calculated by summing the opacity value of each of the valid observations in the

appropriate subset, dividing this sum by the number of valid observations in the subset, and rounding the result to the nearest whole number. The number of missing observations in the subset shall be indicated in parenthesis after the subset average value.
[Rule 62-297.401, F.A.C.]

A.21. Particulate Matter. The test methods for particulate emissions shall be EPA Methods 17, 5, 5B, or 5F, incorporated by reference in Chapter 62-297, F.A.C. The minimum sample volume shall be 30 dry standard cubic feet. EPA Method 5 may be used with filter temperature no more than 320 degrees Fahrenheit. For EPA Method 17, stack temperature shall be less than 375 degrees Fahrenheit. The owner or operator may use EPA Method 5 to demonstrate compliance. EPA Method 3 or 3A with Orsat analysis shall be used when the oxygen based F-factor, computed according to EPA Method 19, is used in lieu of heat input. Acetone wash shall be used with EPA Method 5 or 17. [Rules 62-296.405(1)(e)2. and 62-297.401, F.A.C.]

A.22. Sulfur Dioxide. The test methods for sulfur dioxide emissions shall be EPA Methods 6, 6A, 6B, or 6C, incorporated by reference in Chapter 62-297, F.A.C., or methods from the acid rain rule. Fuel sampling and analysis may be used as an alternate sampling procedure if such a procedure is incorporated into the operation permit for the emissions unit. If the emissions unit obtains an alternate procedure under the provisions of Rule 62-297.620, F.A.C., the procedure shall become a condition of the emissions unit's permit. The Department will retain the authority to require EPA Method 6 or 6C if it has reason to believe that exceedences of the sulfur dioxide emissions limiting standard are occurring. Results of an approved fuel sampling and analysis program shall have the same effect as EPA Method 6 test results for purposes of demonstrating compliance or noncompliance with sulfur dioxide standards. The permittee may use the EPA test methods, referenced above, to demonstrate compliance; however, as an alternate sampling procedure authorized by permit, the permittee elected to demonstrate compliance by accepting a liquid fuel sulfur limit that will be verified with a fuel analysis provided by the vendor or the permittee upon each fuel delivery. As an alternative, the acid rain required continuous emission monitoring system for sulfur dioxide may be used for emissions determination and reporting. [40 CFR Part 75; and, Rules 62-213.440(1), 62-296.405(1)(e)3. & 62-297.401, F.A.C.]

A.23. Sulfur Content Sampling Methods. The fuel sulfur content, percent by weight, for liquid fuels shall be evaluated using either ASTM D2622-92, ASTM D4294-90, or both ASTM D4057-88 and ASTM D129-91, or the respective successor ASTM method(s). [Rules 62-213.440, 62-296.405(1)(e)3., 62-296.405(1)(f)1.b. and 62-297.440, F.A.C.]

A.24. VE Testing Not Required. By this permit, annual emissions compliance testing for visible emissions is not required for this emissions unit while burning:
a. only gaseous fuel(s); or
b. gaseous fuel(s) in combination with any amount of liquid fuel(s) for less than 400 hours per year; or
c. only liquid fuel(s) for less than 400 hours per year.
See Specific Condition **TR7.** [Rule 62-297.310(7)(a)4., F.A.C.]

A.25. PM Testing Not Required. Annual and permit renewal compliance testing for particulate matter emissions is not required for this emissions unit while burning:
a. only gaseous fuel(s); or
b. gaseous fuel(s) in combination with any amount of liquid fuel(s) for less than 400 hours per year; or
c. only liquid fuel(s) for less than 400 hours per year.
See Specific Condition **TR7.** [Rules 62-297.310(7)(a)3. & 5., F.A.C.; and, ASP Number 97-B-01.]

Record keeping and Reporting Requirements

See Appendix RR, Facility-wide Reporting Requirements, for additional reporting requirements.

A.26. Reporting Schedule. The following report shall be submitted to the Compliance Authority:

Report	Reporting Deadline(s)	Related Condition(s)

Quarterly Excess Emissions	Every 3 months (quarter)	**A.28.**

[Rule 62-296.405(1)(g), F.A.C.]

A.27. Reporting of Excess Emissions Due to Malfunctions. In the case of excess emissions resulting from malfunctions, each owner or operator shall notify the Department or the appropriate Local Program in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department or the appropriate Local Program. [Rule 62-210.700(6), F.A.C.]

A.28. Quarterly Excess Emissions Report. Submit to the Department a written report of emissions in excess of emission limiting standards as set forth in Rule 62-296.405(1), F.A.C., for each calendar quarter. The nature and cause of the excess emissions shall be explained. This report does not relieve the owner or operator of the legal liability for violations. All recorded data shall be maintained on file by the Source for a period of five years. [Rules 62-213.440 and 62-296.405(1)(g), F.A.C.]

Other Requirements

A.29. On-Specification Used Oil. Burning of on-specification used oil is allowed in this emissions unit in accordance with all other conditions of this permit and the following conditions:

a. *On-Specification Used Oil Emissions Limitations.* This emissions unit is permitted to burn on-specification used oil, which contains a Polychlorinated Biphenyl (PCB) concentration of less than 50 parts per million (ppm). On-specification used oil is defined as used oil that meets the specifications of 40 CFR 279 - Standards for the Management of Used Oil, listed below. "Off-specification" used oil shall not be burned. Used oil which fails to comply with any of these specification levels is considered "off-specification" used oil.

CONSTITUENT/PROPERTY	ALLOWABLE LEVEL
Arsenic	5 ppm maximum
Cadmium	2 ppm maximum
Chromium	10 ppm maximum
Lead	100 ppm maximum
Total Halogens	1000 ppm maximum
Flash point	100 degrees F minimum

b. *Quantity Limitation*. This emissions unit is permitted to burn on-specification used oil that is generated by the City of Lakeland in the production and distribution of electricity, not to exceed 42,000 gallons (1,000 barrels) during any calendar year.

c. *PCB Limitation*. Used oil containing a PCB concentration of 50 or more ppm shall not be burned at this facility. Used oil shall not be blended to meet this requirement.

d. *Operational Requirements*. On-specification used oil with a PCB concentration of 2 to less than 50 ppm shall be burned only at normal source operating temperatures. On-specification used oil with a PCB concentration of 2 to less than 50 ppm shall not be burned during periods of startup or shutdown.

e. *Testing Requirements*. For each batch of used oil to be burned, the owner or operator must be able to demonstrate that the used oil qualifies as on-specification used oil and that the PCB content is less than 50 ppm.
The requirements of this demonstration are governed by the following federal regulations:
(1) Analysis of used oil fuel. A generator, transporter, processor/re-refiner, or burner may determine that used oil that is to be burned for energy recovery meets the fuel specifications of Sec. 279.11 by performing analyses or obtaining copies of analyses or other information documenting that the used oil fuel meets the specifications. [40 CFR 279.72(a)]

(2) Testing of used oil fuel. Used oil to be burned for energy recovery is presumed to contain quantifiable levels (2 ppm) of PCB unless the marketer obtains analyses (testing) or other information that the used oil fuel does not contain quantifiable levels of PCBs.
   (a) The person who first claims that a used oil fuel does not contain quantifiable level (2 ppm) PCB must obtain analyses or other information to support that claim.
   (b) Testing to determine the PCB concentration in used oil may be conducted on individual samples, or in accordance with the testing procedures described in Sec. 761.60(g)(2). However, for purposes of this part, if any PCBs at a concentration of 50 ppm or greater have been added to the container or equipment, then the total container contents must be considered as having a PCB concentration of 50 ppm or greater for purposes of complying with the disposal requirements of this part.
   (c) Other information documenting that the used oil fuel does not contain quantifiable levels (2 ppm) of PCBs may consist of either personal, special knowledge of the source and composition of the used oil, or a certification from the person generating the used oil claiming that the oil contains no detectable PCBs.

[40 CFR 761.20(e)(2)]

When testing is required, the owner or operator shall sample and analyze each batch of used oil to be burned for the following parameters:

Arsenic, cadmium, chromium, lead, total halogens, flash point and PCBs.

Testing (sampling, extraction and analysis) shall be performed using approved methods specified in EPA Publication SW-846 (Test Methods for Evaluating Solid Waste, Physical/Chemical Methods).

f. *Recordkeeping Requirements.* The owner or operator shall obtain, make, and keep the following records related to the use of used oil in a form suitable for inspection at the facility by the Department:
   (1) The gallons of on-specification used oil placed into inventory to be burned and the gallons of on-specification used oil burned each month.
   (2) Results of the analyses of each deposit of used oil, as required by the above conditions.
   (3) Other information, besides testing, used to make a claim that the used oil meets the requirements of on-specification used oil or that the used oil contains less than 50 ppm of PCBs.

   [40 CFR 279.72(b), 40 CFR 279.74(b) and 40 CFR 761.20(e)]

g. *Reporting Requirements.* The owner or operator shall submit, with the Annual Operation Report form, the analytical results required above and the total amount of on-specification used oil placed into inventory to be burned and the total amount of on-specification used oil burned during the previous calendar year.

[Rule 62-4.070(3) and 62-213.440, F.A.C., 40 CFR 279 and 40 CFR 761, unless otherwise noted.]

A.30. NESHAP Requirements - Subpart UUUUU. Except as otherwise provided in this permit, this emissions unit boiler shall comply with all applicable provisions of 40 CFR 63, Subpart UUUUU, National Emissions Standards for Hazardous Air Pollutants (NESHAP): Coal- and Oil-Fired Electric Utility Steam Generating Units. This emissions unit shall comply with **Appendix 40 CFR 63 Subpart UUUUU** attached to this permit by date of April 15, 2015. [40 CFR 63 Subpart UUUUU]

Subsection B. Emissions Unit -004

The specific conditions in this section apply to the following emission units:

E.U. ID No.	Brief Description
-004	Gas Turbine Peaking Unit 1

Gas Turbine Peaking Unit 1 consists of a gas turbine, which drives a generator producing electrical power at a nominal nameplate rating of 20 megawatts. The gas turbine is fired with natural gas, or No. 2 fuel oil with a maximum sulfur content of 0.5 percent by weight. The maximum fuel firing rate is 320 million cubic feet per hour of natural gas (approximately 330 million Btu per hour) or 2,310 gallons per hour of No. 2 fuel oil (approximately 320 million Btu per hour). Gas Turbine Peaking Unit 1 began commercial service in 1973. The stack parameters are: height, 35 feet: diameter (rectangular), 13'2" x 10'11" feet; exit temperature, 900 degrees F; actual stack gas flow rate (gas), 742,174 acfm: and, actual stack gas flow rate (oil), 682,334 acfm.

{Permitting notes: This emissions unit is regulated under Rule 62-210.300, F.A.C., Permits Required. This unit is not subject to 40 CFR 60, Subpart GG, Standards of Performance for New Stationary Gas Turbines.}

Essential Potential to Emit (PTE) Parameters

B.1. Permitted Capacity.

a. The maximum heat input rate of the turbine is 330 million Btu per hour (lower heating value) at 30 degrees F while firing natural gas and 320 million Btu per hour (lower heating value) at 30 degrees F while firing No. 2 fuel oil.

b. **Not federally enforceable.** The maximum firing rate of the turbine is 320 million cubic feet per hour when firing natural gas or 2,310 gallons per hour when firing No. 2 fuel oil.

[Rules 62-4.160(2) and 62-210.200 (Definitions - Potential to Emit (PTE)), F.A.C.]

B.2. Emissions Unit Operating Rate Limitation After Testing. See the related testing provisions in Appendix TR, Facility-wide Testing Requirements. [Rule 62-297.310(2), F.A.C.]

B.3. Methods of Operation - Fuels. Only natural gas or distillate (No. 2) fuel oil shall be fired in the combustion turbine. [Rule 62-213.410, F.A.C.]

B.4. Hours of Operation. These emissions unit(s) may operate continuously, i.e., 8,760 hours/year. [Rules 62-4.160(2) and 62-210.200(PTE), F.A.C.]

Emission Limitations and Standards

Unless otherwise specified, the averaging time for Specific Condition **B.5.** is based on the specified averaging time of the applicable test method.

B.5. Visible Emissions. Visible emissions from each turbine shall not be equal to or greater than 20 percent opacity. [Rule 62-296.320(4)(b)1., F.A.C.]

B.6. **Not federally enforceable.** Sulfur Dioxide - Sulfur Content. The sulfur content of the No. 2 fuel oil shall not exceed 0.5 percent, by weight. [Rule 62-213.440, F.A.C. and Applicant request.]

Excess Emissions

B.7. Excess Emissions Allowed. Excess emissions from these emissions units resulting from startup, shutdown or malfunction shall be permitted providing (1) that best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration. [Rule 62-210.700(1), F.A.C.]

B.8. Excess Emissions Prohibited. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. [Rule 62-210.700(4), F.A.C.]

Monitoring of Operations

B.9. Fuel Sulfur Monitoring. The permittee shall demonstrate compliance with the liquid fuel sulfur limit by means of a fuel analysis provided by the vendor or the permittee upon each fuel delivery. [Rule 62-213.440, F.A.C.]

Test Methods and Procedures

B.10. Test Methods. Required tests shall be performed in accordance with the following reference methods:

Method(s)	Description of Method(s) and Comment(s)
EPA Method 9	Visual Determination of the Opacity of Emissions

The above methods are described in Chapter 62-297, F.A.C. No other methods may be used unless prior written approval is received from the Department. [Chapter 62-297, F.A.C.]

B.11. Annual Compliance Tests. Unless otherwise specified by this permit, during each federal fiscal year (October 1st to September 30th), this emissions unit shall be tested to demonstrate compliance with the emission limitations and standards for visible emissions (VE). [Rule 62-297.310(7), F.A.C.]

B.12. Compliance Tests Prior To Renewal. Prior to permit renewal, compliance tests shall be performed for the following pollutants: VE. [Rule 62-297.310(7)(a)3., F.A.C.]

B.13. Common Testing Requirements. Unless otherwise specified, tests shall be conducted in accordance with the requirements and procedures specified in Appendix TR, Facility-Wide Testing Requirements, of this permit. [Rule 62-297.310, F.A.C.]

B.14. The test method for visible emissions shall be EPA Method 9, adopted and incorporated by reference in Rule 62-204.800, F.A.C., and referenced in Chapter 62-297, F.A.C. [Rules 62-204.800, 62-296.320(4)(b)4.a. and 62-297.401, F.A.C.]

B.15. The fuel sulfur content, percent by weight, for liquid fuels shall be evaluated using either ASTM D2622-92, ASTM D4294-90, or both ASTM D4057-88 and ASTM D129-91, or the respective successor ASTM method(s). [Rules 62-213.440 and 62-297.440, F.A.C.]

B.16. Visible Emissions Testing - Annual. By this permit, annual emissions compliance testing for visible emissions is not required for this emissions unit while burning:

a. only gaseous fuels; or
b. gaseous fuels in combination with any amount of liquid fuels for less than 400 hours per year; or
c. only liquid fuels for less than 400 hours per year.

[Rules 62-297.310(7)(a)4. & 8., F.A.C.]

Recordkeeping and Reporting Requirements

See Appendix RR, Facility-Wide Reporting Requirements, for additional reporting requirements.

Subsection C. Emissions Unit -005

The specific conditions in this section apply to the following emission units:

E.U. ID No.	Brief Description
-005	McIntosh Unit 2 - Fossil Fuel Fired Steam Generator

McIntosh Unit 2 is a nominal 114.7 megawatt (electric) fossil fuel fired steam generator. The unit is fired on low sulfur No. 6 or No. 2 fuel oil with a maximum heat input of 1,115 million Btu per hour, or natural gas with a maximum heat input of 1,184.5 million Btu per hour. The stack parameters are: height, 157 feet: diameter, 10.5 feet; exit temperature, 277 degrees F; and, actual stack gas flow rate, 380,200 acfm. McIntosh Unit 2 began commercial service in June, 1976.

{Permitting note(s): The emissions unit is regulated under Acid Rain, Phase II; Rule 62-296.405(2), F.A.C., Fossil Fuel Steam Generators with More than 250 million Btu per Hour Heat Input; and NSPS - 40 CFR 60, Subpart D, Standards of Performance for Fossil-Fuel Fired Steam Generators for Which Construction is Commenced After August 17, 1971, adopted and incorporated by reference in Rule 62-204.800(8)1., F.A.C.; and, Rule 62-296.470, F.A.C., Clean Air Interstate Rule (CAIR).}

Essential Potential to Emit (PTE) Parameters

C.1. Permitted Capacity. The maximum operation heat input rate is as follows:

Unit No.	MMBtu/hr Heat Input	Fuel Type
2	1,184.5	Natural Gas
	1,115	No. 6 Fuel Oil
	1,115	No. 2 Fuel Oil

When a blend of fuel oil and natural gas is fired, the heat input is prorated based on the percent heat input of each fuel. The Acid Rain CEM will not be a method of compliance for the determination of the heat input rate.
[Rules 62-4.160(2) and 62-210.200 (Definitions - Potential to Emit (PTE)), F.A.C.]

{Permitting note: The heat input limitations have been placed in each permit to identify the capacity of each unit for the purposes of confirming that emissions testing is conducted within 90 to 100 percent of the unit's rated capacity (or to limit future operation to 110 percent of the test load), to establish appropriate emission limits and to aid in determining future rule applicability. Regular record keeping is not required for heat input. Instead the owner or operator is expected to determine heat input whenever emission testing is required, to demonstrate at what percentage of the rated capacity that the unit was tested. Rule 62-297.310(5), F.A.C., included in the permit, requires measurement of the process variables for emission tests. Such heat input determination may be based on measurements of fuel consumption by various methods including but not limited to fuel flow metering or tank drop measurements, using the heat value of the fuel determined by the fuel vendor or the owner or operator, to calculate average hourly heat input during the test.}

C.2. Emissions Unit Operating Rate Limitation After Testing. See the related testing provisions in Appendix TR, Facility-wide Testing Requirements. [Rule 62-297.310(2), F.A.C.]

C.3. Methods of Operation. Fuels. The only fuels allowed to be burned are natural gas, propane, No. 6 fuel oil, No. 2 fuel oil and combinations of natural gas, propane, No. 6 fuel oil and/or No. 2 fuel oil. [Rule 62-213.410, F.A.C.]

C.4. Hours of Operation. This emissions unit is allowed to operate continuously, i.e., 8,760 hours/year. [Rules 62-4.160(2) and 62-210.200(PTE), F.A.C.]

Emission Limitations and Standards

Unless otherwise specified, the averaging times for Specific Conditions **C.5. - C.6.**; and, **C.8. - C.9.** are based on the specified averaging time of the applicable test method.

C.5. Particulate Matter. On and after the date on which the performance test required to be conducted by 40 CFR 60.8 is completed, no owner or operator subject to the provisions of 40 CFR 60, Subpart D, shall cause to be discharged into the atmosphere from any affected facility any gases which contain particulate matter in excess of 43 nanograms per joule heat input (0.10 lb per million Btu). [40 CFR 60.42(a)(1)]

C.6. Visible Emissions. On and after the date on which the performance test required to be conducted by 40 CFR 60.8 is completed, no owner or operator subject to the provisions of 40 CFR 60, Subpart D, shall cause to be discharged into the atmosphere from any affected facility any gases which exhibit greater than 20 percent opacity except for one six-minute period per hour of not more than 27 percent opacity. [40 CFR 60.42(a)(2)]

C.7. Sulfur Dioxide. On and after the date on which the performance test required to be conducted by 40 CFR 60.8 is completed, no owner or operator subject to the provisions of 40 CFR 60, Subpart D, shall cause to be discharged into the atmosphere from any affected facility any gases which contain sulfur dioxide in excess of 340 nanograms per joule heat input (0.80 lb per million Btu) derived from liquid fossil fuel. [40 CFR 60.43(a)(1)]

C.8. Sulfur Dioxide. Compliance shall be based on the total heat input from all fossil fuels burned, including gaseous fuels. [40 CFR 60.43(c)]

C.9. Nitrogen Oxides. On and after the date on which the performance test required to be conducted by 40 CFR 60.8 is completed, no owner or operator subject to the provisions of 40 CFR 60, Subpart D, shall cause to be discharged into the atmosphere from any affected facility any gases which contain nitrogen oxides, expressed as NO_2 in excess of:

a. 86 nanograms per joule heat input (0.20 lb per million Btu) derived from gaseous fossil fuel.
b. 129 nanograms per joule heat input (0.30 lb per million Btu) derived from liquid fossil fuel.

[40 CFR 60.44(a)(1) & (2)]

C.10. Nitrogen Oxides. When different fossil fuels are burned simultaneously in any combination, the applicable standard (in ng/J) is determined by proration using the following formula:

$$PS_{NOx} = \frac{w(260)+x(86)+y(130)+z(300)}{w+x+y+z}$$

where:
PS_{NOx} = is the prorated standard for nitrogen oxides when burning different fuels simultaneously, in nanograms per joule heat input derived from all fossil fuels fired or from all fossil fuels and wood residue fired;
w = is the percentage of total heat input derived from lignite;
x = is the percentage of total heat input derived from gaseous fossil fuel;
y = is the percentage of total heat input derived from liquid fossil fuel; and,
z = is the percentage of total heat input derived from solid fossil fuel (except lignite).

[40 CFR 60.44(b)]

Excess Emissions

The Excess Emissions Rule at Rule 62-210.700, F.A.C., cannot vary any requirement of an NSPS, NESHAP, or Acid Rain program provision.

C.11. Excess Emissions Allowed. Excess emissions from these emissions units resulting from startup, shutdown or malfunction shall be permitted providing (1) that best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration. [Rule 62-210.700(1), F.A.C.]

C.12. Excess Emissions Prohibited. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. [Rule 62-210.700(4), F.A.C.]

Continuous Monitoring Requirements

C.13. Sulfur Dioxide. For a fossil fuel fired steam generator that does not use a flue gas desulfurization device, a continuous monitoring system for measuring sulfur dioxide emissions is not required if the owner or operator monitors sulfur dioxide emissions by fuel sampling and analysis under 40 CFR 60.45(d). The applicant has elected to utilize either fuel sampling and analysis or the acid rain required continuous emission monitoring system for determining compliance with the sulfur dioxide emission limit in Specific Condition **C.7.** [40 CFR 60.45(b)(2) & 40 CFR 75; and, Rule 62-213.440(1) F.A.C.]

Test Methods and Procedures

C.14. Test Methods. Required tests shall be performed in accordance with the following reference methods:

Method(s)	Description of Method(s) and Comment(s)
EPA Methods 1-4	Traverse Points, Velocity and Flow Rate, Gas Analysis, and Moisture Content
EPA Methods 17, 5, 5B, or 5F	Methods for Determining Particulate Matter Emissions
EPA Methods 6, 6A, 6B, or 6C	Methods for Determining Sulfur Dioxide Emissions
Method 7, Method 7A, 7C, 7D, or 7E	Determination of Nitrogen Oxide Emissions
EPA Method 19	Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide, and Nitrogen Oxides Emission Rates (Optional F-factor method may be used to determine flow rate and gas analysis to calculate mass emissions in lieu of Methods 1-4.)
EPA Method 9	Visual Determination of the Opacity of Emissions

The above methods are described in Chapter 62-297, F.A.C. No other methods may be used unless prior written approval is received from the Department. [Chapter 62-297, F.A.C.]

C.15. Annual Compliance Tests. Unless otherwise specified by this permit, during each federal fiscal year (October 1st to September 30th), this emissions unit shall be tested to demonstrate compliance with the emission limitations and standards for particulate matter, nitrogen oxides and visible emissions. The NO_X RATA test data may be used to demonstrate compliance with the annual test requirement, provided the testing requirements (notification, procedures & reporting) of Chapter 62-297, F.A.C. are met. [Rule 62-297.310(7), F.A.C.]

C.16. Compliance Tests Prior To Renewal. Prior to permit renewal, compliance tests shall be performed for the following pollutants: VE, PM, SO_2 and NO_X. The SO_2 and NO_X RATA test data may be used to demonstrate compliance, provided the testing requirements (notification, procedures & reporting) of Chapter 62-297, F.A.C. are met. [Rule 62-297.310(7)(a)3., F.A.C.]

C.17. Common Testing Requirements. Unless otherwise specified, tests shall be conducted in accordance with the requirements and procedures specified in Appendix TR, Facility-Wide Testing Requirements, of this permit. [Rule 62-297.310, F.A.C.]

C.18. SO_2 Compliance. Compliance with the sulfur dioxide emission standard of specific condition **C.7.** shall be demonstrated using the fuel sampling and analysis procedures of specific condition **C.18.** or the acid rain required continuous emission monitoring system, based on a 3-hour rolling average. [40 CFR 75 and Rule 62-213.440(1), F.A.C.]

C.19. Fuel Sampling. The following fuel sampling and analysis program may be used to demonstrate compliance with the sulfur dioxide standard and as the substitute for the sulfur dioxide continuous monitoring system:

a. Determine and record the as-fired fuel sulfur content, percent by weight, (1) for liquid fuels using either ASTM D2622-92, ASTM D4294-90, or both ASTM D4057-88 and ASTM D129-91, or the respective successor ASTM method(s), to analyze a representative sample of the blended fuel following each fuel delivery, (2) for gaseous fuels using ASTM D1072-90, or the respective successor ASTM method.
b. Record daily the amount of each fuel fired, the density of each fuel, and the percent sulfur content by weight of each fuel.
c. Utilize the information in a. and b., above, to calculate the SO_2 emission rate to ensure compliance at all times.

[Rule 62-213.440(1), F.A.C.]

C.20. VE Testing Not Required. By this permit, annual emissions compliance testing for visible emissions is not required for this emissions unit while burning:

a. only gaseous fuel(s); or
b. gaseous fuel(s) in combination with any amount of liquid fuel(s) for less than 400 hours per year; or
c. only liquid fuel(s) for less than 400 hours per year.

See Specific Condition **TR7.** [Rule 62-297.310(7)(a)4., F.A.C.]

C.21. PM Testing Not Required. Annual and permit renewal compliance testing for particulate matter emissions is not required for this emissions unit while burning:

a. only gaseous fuel(s); or
b. gaseous fuel(s) in combination with any amount of liquid fuel(s) for less than 400 hours per year; or
c. only liquid fuel(s) for less than 400 hours per year.

See Specific Condition **TR7.** [Rules 62-297.310(7)(a)3. & 5., F.A.C.; and, ASP Number 97-B-01.]

Recordkeeping and Reporting Requirements

See Appendix RR, Facility-wide Reporting Requirements, for additional reporting requirements.

C.22. Reporting Schedule. The following report shall be submitted to the Compliance Authority:

Report	Reporting Deadline(s)	Related Condition(s)
NSPS Excess Emissions and Monitoring System Performance	Every 6 months (semi-annual), except when more frequent reporting is specifically required	**C.23.**
Quarterly Excess Emissions	Every 3 months (quarter)	**C.22.**

[40 CFR 60 Subpart A; and, Rule 62-210.700(6), F.A.C.]

C.23. Quarterly Excess Emissions Report. Submit to the Department a written report of emissions in excess of emission limiting standards for each calendar quarter. The nature and cause of the excess emissions shall be

explained. This report does not relieve the owner or operator of the legal liability for violations. All recorded data shall be maintained on file by the Source for a period of five years. [Rule 62-210.700(6), F.A.C.]

Miscellaneous Requirements

C.24. NSPS Requirements - Subpart A. These emissions units shall comply with all applicable requirements of 40 CFR 60, Subpart A, General Provisions, including:

40 CFR 60.7, Notification and Recordkeeping
40 CFR 60.8, Performance Tests
40 CFR 60.11, Compliance with Standards and Maintenance Requirements
40 CFR 60.12, Circumvention
40 CFR 60.13, Monitoring Requirements
40 CFR 60.19, General Notification and Reporting requirements,

which have been adopted by reference in Rule 62-204.800(8)(d), F.A.C., except that the Secretary is not the Administrator for purposes of 40 CFR 60.4, 40 CFR 60.8(b)(2) and (3), 40 CFR 60.11(e)(7) and (8), 40 CFR 60.13(g), (i) and (j)(2), and 40 CFR 60.16. These emissions units shall comply with **Appendix 40 CFR 60 Subpart A** included with this permit. [Rule 62-204.800(8)(d), F.A.C.]

C.25. NSPS Requirements - Subpart D. Except as otherwise provided in this permit, this fossil-fuel fired steam generator shall comply with all applicable provisions of 40 CFR 60, Subpart D, Standards of Performance for Fossil-Fuel Fired Steam Generators for Which Construction is Commenced After August 17, 1971, adopted by reference in Rule 62-204.800(8)(b)1., F.A.C. This emissions unit shall comply with **Appendix 40 CFR 60 Subpart D** included with this permit. [Rule 62-204.800(8)(b)1., F.A.C.]

C.26. NESHAP Requirements - Subpart UUUUU. Except as otherwise provided in this permit, this emissions unit boiler shall comply with all applicable provisions of 40 CFR 63, Subpart UUUUU, National Emissions Standards for Hazardous Air Pollutants (NESHAP): Coal- and Oil-Fired Electric Utility Steam Generating Units. This emissions unit shall comply with **Appendix 40 CFR 63 Subpart UUUUU** attached to this permit by date of April 15, 2015. [40 CFR 63 Subpart UUUUU]

The specific conditions in this section apply to the following emission units:

E.U. ID No.	Brief Description
-006	McIntosh Unit 3 - Fossil Fuel Fired Steam Generator

McIntosh Unit 3 is a nominal 364 megawatt (electric) dry bottom wall-fired fossil fuel fired steam generator. The unit is fired on coal, residual oil, natural gas and petroleum coke. The maximum heat input rate is 3,640 million Btu per hour. Unit 3 is equipped with an electrostatic precipitator (ESP), a flue gas desulfurization system (FGD), and low NO_X burners (LNB) and an overfire air (OFA) system to control emissions. McIntosh Unit 3 began commercial service in September, 1982. Compliance Assurance Monitoring (CAM) requirements for the ESP are included in Appendix CAM. The FGD is exempted from CAM because the Acid Rain SO_2 continuous emissions monitor will be used to demonstrate continuous compliance. The stack parameters are: height, 250 feet: diameter, 18 feet; exit temperature, 125 degrees F; and, actual stack gas flow rate, 1,260,536 acfm.

{Permitting note(s): The emissions unit is regulated under Acid Rain, Phase II; Rule 62-296.405(2), F.A.C., Fossil Fuel Steam Generators with More than 250 million Btu per Hour Heat Input; and NSPS - 40 CFR 60, Subpart D, Standards of Performance for Fossil-Fuel Fired Steam Generators for Which Construction is Commenced After August 17, 1971, adopted and incorporated by reference in Rule 62-204.800(8)(b)1., F.A.C.; Rule 212.400(6), F.A.C., Prevention of Significant Deterioration (PSD); Rule 62-212.400(6), F.A.C., Best Available Control Technology (BACT) Determination; Compliance Assurance Monitoring (CAM), adopted and incorporated by reference in Rule 62-204.800, F.A.C.; and, Rule 62-296.470, F.A.C., Clean Air Interstate Rule (CAIR).}

In addition to the requirements listed below, these emissions units are also subject to the standards and requirements contained in the Acid Rain Part of this permit (see Section IV).

Essential Potential to Emit (PTE) Parameters

D.1. Capacity. The maximum heat input rate is 3,640 MMBtu per hour. The Acid Rain CEMS will not be a method of compliance for the determination of the heat input rate. [Rules 62-4.160(2) and 62-210.200 (Definitions - Potential to Emit (PTE)), F.A.C.]

{Permitting note: The heat input limitations have been placed in each permit to identify the capacity of each unit for the purposes of confirming that emissions testing is conducted within 90 to 100 percent of the unit's rated capacity (or to limit future operation to 110 percent of the test load), to establish appropriate emission limits and to aid in determining future rule applicability. Regular record keeping is not required for heat input. Instead the owner or operator is expected to determine heat input whenever emission testing is required, to demonstrate at what percentage of the rated capacity that the unit was tested. Rule 62-297.310(5), F.A.C., included in the permit, requires measurement of the process variables for emission tests. Such heat input determination may be based on measurements of fuel consumption by various methods including but not limited to fuel flow metering or tank drop measurements, using the heat value of the fuel determined by the fuel vendor or the owner or operator, to calculate average hourly heat input during the test.}

D.2. Emissions Unit Operating Rate Limitation After Testing. See the related testing provisions in Appendix TR, Facility-wide Testing Requirements. [Rule 62-297.310(2), F.A.C.]

D.3. Methods of Operation - Fuels. The only fuels allowed to be burned are:

a. Coal only;
b. Low sulfur fuel oil only (≤ 0.5 percent sulfur by weight);
c. Coal and up to 20 percent petroleum coke (based on weight);
d. High sulfur fuel oil (> 0.5 percent sulfur by weight); and,
e. Natural gas or propane only, or in combination with any of the other fuels or fuel combinations listed above.

[Rules 62-4.160(2), 62-210.200 (Definitions - PTE), and 62-213.440(1), F.A.C.; and, PSD-FL-008(B)]

a. Petroleum coke shall not be fired in Unit 3. This prohibition shall become effective upon the effective date of EPA's approval of this specific requirement in the Florida Regional Haze State Implementation Plan. [Rule 62-4.160(2) F.A.C. and Application No. 1050004-032-AC]

{Permitting note: Upon the effective date of EPA's approval of the above requirement in the Florida Regional Haze State Implementation plan, this condition will supersede the authority to fire petcoke authorized by permit No. PSD-FL-008(B), issued December 11, 1995, which was a revision to the original PSD permit issued by EPA in 1978}

D.4. Hours of Operation. This emissions unit is allowed to operate continuously, i.e., 8,760 hours/year. [Rule 62-210.200 (Definitions - PTE), F.A.C.]

Emission Limitations and Standards

Unless otherwise specified, the averaging times for Specific Conditions **D.5.-D.7.; D.9.-D.11.;** and, **D.13.-D.14.** are based on the specified averaging time of the applicable test method.

D.5. Particulate Matter. Particulate matter emitted to the atmosphere from the boiler shall not exceed:

Mode of Firing	Pound / MMBtu Heat Input
Coal	0.044
Coal/Petroleum Coke	0.044
Oil	0.070

[40 CFR 60.42(a)(2); and, PSD-FL-008(B)]

D.6. Visible Emissions. Visible emissions shall not exceed 20 percent opacity except for one six-minute period per hour of not more than 27 percent opacity. [40 CFR 60.42(a)(2); and, PSD-FL-008(B)]

D.7. Sulfur Dioxide. On and after the date on which the performance test required to be conducted by 40 CFR 60.8 is completed, no owner or operator subject to the provisions of 40 CFR 60, Subpart D, shall cause to be discharged into the atmosphere from any affected facility any gases which contain sulfur dioxide in excess of: (1) 340 nanograms per joule heat input (0.80 lb per million Btu) derived from liquid fossil fuel or liquid fossil fuel and wood residue, or (2) 520 nanograms per joule heat input (1.2 lb per million Btu) derived from solid fossil fuel or solid fossil fuel and wood residue, except as provided in 40 CFR 60.43(e). [40 CFR 60.43(a)(1) and (2)]

D.8. Sulfur Dioxide. When different fossil fuels are burned simultaneously in any combination, the applicable standard (in ng/J) shall be determined by proration using the following formula:

$PS_{SO2} = [y(340) + z(520)]/(y+z)$

where:
PS_{SO2} is the prorated standard for sulfur dioxide when burning different fuels simultaneously, in nanograms per joule heat input derived from all fossil fuels fired or from all fossil fuels and wood residue fired,
y is the percentage of total heat input derived from liquid fossil fuel, and
z is the percentage of total heat input derived from solid fossil fuel.
[40 CFR 60.43(b)]
Compliance shall be based on the total heat input from all fossil fuels burned, including gaseous fuels. [40 CFR 60.43(c)]

D.9. Sulfur Dioxide. A flue gas desulfurization system will be installed to treat exhaust gases and will operate such that whenever coal or blends of coal and petroleum coke are burned, sulfur dioxide gases discharged to the atmosphere from the boiler shall not exceed 10 percent of the potential combustion concentration (90

percent reduction), or 35 percent of the potential combustion concentration (65 percent reduction) when emissions are less than 0.75 pound per million Btu heat input. Compliance with the percent reduction requirement shall be determined on a 30-day rolling average. This compliance information shall be retained for a period of five years and made available by the City upon request of the Department. Whenever blends of petroleum coke with other fuels are co-fired, sulfur dioxide emissions shall not exceed 0.718 pound per million Btu heat input based on a 30-day rolling average and shall comply with the reduction requirements given above. [PSD-FL-008(B); and, Rule 62-213.440, F.A.C.]

D.10. Sulfur Dioxide. The burning of high sulfur oil (greater than 0.5 percent sulfur by weight) or a combination of high sulfur oil as an emergency fuel without the use of the SO_2 scrubber will be allowed only when the flue gas desulfurization system malfunctions to the extent that the burning of coal would cause emission limitations to be exceeded. Sulfur dioxide emitted to the atmosphere from the boiler shall not exceed 0.8 pound per million Btu heat input under this condition. [PSD-FL-008(B)]

D.11. Sulfur Dioxide. During malfunctions of equipment which cause an interruption of the coal feed to the boiler, the burning of high sulfur oil (greater than 0.5 percent sulfur by weight) will be allowed only if all flue gases are fully scrubbed by the SO_2 scrubber. Sulfur dioxide emitted to the atmosphere from the boiler shall not exceed 0.8 pound per million Btu heat input under this condition. [PSD-FL-008(B)]

D.12. Sulfur Dioxide. Continuous burning of natural gas, low sulfur fuel oil (less than or equal to 0.5 percent sulfur by weight), or combinations of these two fuels with or without the use of the SO_2 scrubber will be allowed. [PSD-FL-008(B)]

D.13. Nitrogen Oxides. On and after the date on which the performance test required to be conducted by 40 CFR 60.8 is completed, no owner or operator subject to the provisions of 40 CFR 60, Subpart D, shall cause to be discharged into the atmosphere from any affected facility any gases which contain nitrogen oxides, expressed as NO_2 in excess of:

a. 86 nanograms per joule heat input (0.20 lb per million Btu) derived from gaseous fossil fuel.
b. 129 nanograms per joule heat input (0.30 lb per million Btu) derived from liquid fossil fuel, liquid fossil fuel and wood residue, or gaseous fossil fuel and wood residue.
c. 300 nanograms per joule heat input (0.70 lb per million Btu) derived from solid fossil fuel or solid fossil fuel and wood residue (except lignite or a solid fossil fuel containing 25 percent, by weight, or more of coal refuse).

[40 CFR 60.44(a)(1), (2) & (3)]

D.14. Nitrogen Oxides. Except as provided under paragraphs 40 CFR 60.44(c) and (d), when different fossil fuels are burned simultaneously in any combination, the applicable standard (in ng/J) is determined by proration using the following formula:

$$PS_{NOx} = \frac{w(260)+x(86)+y(130)+z(300)}{w+x+y+z}$$

where:
PS_{NOx} = is the prorated standard for nitrogen oxides when burning different fuels simultaneously, in nanograms per joule heat input derived from all fossil fuels fired or from all fossil fuels and wood residue fired;
w = is the percentage of total heat input derived from lignite;
x = is the percentage of total heat input derived from gaseous fossil fuel;
y = is the percentage of total heat input derived from liquid fossil fuel; and,
z = is the percentage of total heat input derived from solid fossil fuel (except lignite).

[40 CFR 60.44(b)]

D.15. Ammonia Emissions (Slip). Subject to the requirements of Condition 36 in this section, the SCR system shall be operated for an ammonia slip target of less than 5 ppmv based on the average of three, 1-hour test runs. [Air Construction Permit No. 1050004-026-AC, Specific Condition 12.]

D.16. CO Emission Limit Subject to Revision. Emissions of carbon monoxide (CO) from Unit 3 shall not exceed 0.20 pounds per million Btu heat input (lb/MMBtu) on a 30-day rolling average as described in air construction permit 1050004-018-AC. Based on results of compliance tests and analysis of 12 months worth of continuous monitoring data, the Department will reassess the previously issued best available control technology (BACT) determination. The emission limit may be adjusted downward to make this limit more stringent provided that overall control attained for all air pollutants including CO, SO_2, NO_X, PM/PM_{10}, sulfuric acid mist, and VOC is optimized. Such revision shall be based on data that represents a full range of operating conditions and a representative period of time. Such revision, if required by the Department, shall be in the form of an air construction permit following the Department's procedures in Rules 62-210.300 and 62-4.055, F.A.C. [Air Construction Permit Nos. 1050004-019-AC, Specific Condition 13.a and 1050004-026-AC, Specific Condition 13.]

D.17. NO_X Emission Limit. NO_X emissions from Unit 3 shall not exceed 0.22 lb/MMBtu of heat input based on a calendar year average of all periods of operation, including startup, shutdown and malfunction. The permittee shall begin collecting and averaging data towards a demonstration of compliance with the new NO_X emissions limitation beginning January 1, 2011. [Air Construction Permit No. 1050004-026-AC, Specific Condition 13.b.]

Excess Emissions

The Excess Emissions Rule at Rule 62-210.700, F.A.C., cannot vary any requirement of an NSPS, NESHAP, or Acid Rain program provision.

D.18. Excess Emissions Allowed. Excess emissions from these emissions units resulting from startup, shutdown or malfunction shall be permitted providing (1) that best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration. [Rule 62-210.700(1), F.A.C.]

D.19. Excess Emissions Prohibited. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. [Rule 62-210.700(4), F.A.C.]

Monitoring of Operations

D.20. CAM Plan. This emissions unit is subject to the Compliance Assurance Monitoring (CAM) requirements contained in the attached Appendix CAM for the controlled emissions of particulate matter. Failure to adhere to the monitoring requirements specified does not necessarily indicate an exceedance of a specific emissions limitation; however, it may constitute good reason to require compliance testing pursuant to Rule 62-297.310(7)(b), F.A.C. [40 CFR 64; Rules 62-204.800 and 62-213.440(1)(b)1.a., F.A.C.]

D.21. Use of SO_2 CEMS For Continuous Compliance. Pursuant to 40 CFR 64.2(b)(1)(vi), the applicant has elected to use the existing certified Acid Rain SO_2 continuous emissions monitor for continuous compliance in order to be exempted from the Compliance Assurance Monitoring (CAM) requirements contained in 40 CFR 64. [40 CFR 64.2(b)(vi); and, Applicant request]

Continuous Monitoring Requirements

D.22. Performance Specifications and Quality Assurance. The CO monitor shall be certified pursuant to 40 CFR 60, Appendix B, Performance Specification 4 or 4A within 180 calendar days of commencing operation

following installation of the Low-NO_X burners and over fire air system. Quality assurance procedures shall conform to the requirements of 40 CFR 60, Appendix F. The required RATA tests shall be performed using EPA Method 10 in Appendix A of 40 CFR 60 and shall be based on a continuous sampling train. The CO monitor span values shall be set appropriately, considering the expected range of emissions and corresponding emission standards. [Rules 62-4.070(3) and 62-210.200(BACT), F.A.C.; and, PSD-FL-387.]

D.23. CEMS Data Requirements for CO BACT Standard.

a. *Data Collection*. The CO CEMS shall monitor and record emissions during all operations and whenever emissions are being generated, including during episodes of startups, shutdowns, and malfunctions. All data shall be used, except for invalid measurements taken during monitor system breakdowns, repairs, calibration checks, zero adjustments, and span adjustments.

b. *Operating Hours and Operating Days*. An hour is the 60-minute period beginning at the top of each hour. Any hour during which an emissions unit is in operation for more than 15 minutes is an operating hour for that emission unit. A day is the 24-hour period from midnight to midnight. Any day with at least one operating hour for an emissions unit is an operating day for that emission unit.

c. *Valid Hourly Averages*. The CEMS shall be designed and operated to sample, analyze, and record data evenly spaced over the hour at a minimum of one measurement per minute. All valid measurements collected during an hour shall be used to calculate a 1-hour block average that begins at the top of each hour.

(1) Hours that are not operating hours are not valid hours.

(2) For each operating hour, the 1-hour block average shall be computed from at least two data points separated by a minimum of 15 minutes. If less than two such data points are available, there is insufficient data, the 1-hour block average is not valid, and the hour is considered as "monitor unavailable."

d. *Rolling 30-day average*. Compliance shall be determined after each operating day by calculating the arithmetic average of all the valid hourly averages from that operating day and the prior 29 operating days.

e. *Monitor Availability*. The quarterly excess emissions report shall identify monitor availability for each quarter in which the unit operated. Monitor availability for the CEMS shall be 95% or greater in any calendar quarter in which the unit operated for more than 760 hours. In the event the applicable availability is not achieved, the permittee shall provide the Department with a report identifying the problems in achieving the required availability and a plan of corrective actions that will be taken to achieve 95% availability. The permittee shall implement the reported corrective actions within the next calendar quarter. Failure to take corrective actions or continued failure to achieve the minimum monitor availability shall be violations of this permit.

[Rules 62-4.070(3) and 62-210.200(BACT), F.A.C.; and, PSD-FL-387.]

D.24. CEM Requirements. Continuous monitors shall be installed and operated in accordance with 40 CFR 60.45 and 60.13. In addition, an ASTM-certified automatic solid fossil fuel sampler shall be installed which produces a representative daily sample for analysis of sulfur, moisture, heating value and ash. The solid fossil fuel data shall be used in conjunction with emissions factors and the continuous monitoring data to calculate SO_2 reduction. [PSD-FL-008(B)]

D.25. CEMS Annual Emissions Requirement. The owner or operator shall use data from the CO CEMS when calculating annual emissions for purposes of computing actual emissions, baseline actual emissions, and net emissions increase, as defined at Rule 62-210.200, F.A.C., and for purposes of computing emissions pursuant to the reporting requirements of Rule 62-210.370(3), F.A.C. In computing the emissions of a pollutant, the owner or operator shall account for the emissions during periods of startup and shutdown of the emissions unit. [Rules 62-210.200, and 62-210.370(3), F.A.C.; and, PSD-FL-387.]

D.26. Ammonia Monitoring Requirements. In accordance with the manufacturer's specifications, the permittee shall calibrate, operate, and maintain an ammonia flow meter to measure and record the ammonia injection rate to the SCR system. [Air Construction Permit No. 1050004-019-AC, Specific Condition 22.]

Test Methods and Procedures

D.27. Test Methods. Required tests shall be performed in accordance with the following reference methods:

Method(s)	Description of Method(s) and Comment(s)
EPA Methods 1-4	Traverse Points, Velocity and Flow Rate, Gas Analysis, and Moisture Content
EPA Methods 17, 5, 5B or 5F	Methods for Determining Particulate Matter Emissions
EPA Methods 6, 6A, 6B or 6C	Methods for Determining Sulfur Dioxide Emissions
Method 7, Method 7A, 7C, 7D or 7E	Determination of Nitrogen Oxide Emissions
10	Determination of Carbon Monoxide Emissions
EPA Method 19	Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide, and Nitrogen Oxides Emission Rates (Optional F-factor method may be used to determine flow rate and gas analysis to calculate mass emissions in lieu of Methods 1-4.)
EPA Method 9	Visual Determination of the Opacity of Emissions

The above methods are described in Chapter 62-297, F.A.C. No other methods may be used unless prior written approval is received from the Department. [Chapter 62-297, F.A.C.]

D.28. Annual Compliance Tests. Unless otherwise specified by this permit, during each federal fiscal year (October 1st to September 30th), this emissions unit shall be tested to demonstrate compliance with the emission limitations and standards for particulate matter (PM), nitrogen oxides (NO_X), sulfur dioxide (SO_2) and visible emissions (VE). The NO_X and SO_2 RATA test data may be used to demonstrate compliance with the annual test requirement, provided the testing requirements (notification, procedures & reporting) of Chapter 62-297, F.A.C. are met. [Rule 62-297.310(7), F.A.C.]

D.29. Compliance Tests Prior To Renewal. Prior to permit renewal, compliance tests shall be performed for the following pollutants: VE, PM, SO_2 and NO_X. [Rule 62-297.310(7)(a)3., F.A.C.]

D.30. Common Testing Requirements. Unless otherwise specified, tests shall be conducted in accordance with the requirements and procedures specified in Appendix TR, Facility-Wide Testing Requirements, of this permit. [Rule 62-297.310, F.A.C.]

D.31. Continuous Compliance with CO limits. Compliance with the 30 operating day rolling average shall be demonstrated using data collected from the required CEMS. [Rule 62-4.070(3), F.A.C.; and, PSD-FL-387.]

D.32. VE Tests Not Required. By this permit, annual emissions compliance testing for visible emissions is not required for this emissions unit while burning:

a. only gaseous fuel(s); or
b. gaseous fuel(s) in combination with any amount of liquid fuel(s) for less than 400 hours per year; or
c. only liquid fuel(s) for less than 400 hours per year.

See Specific Condition **TR7.** [Rule 62-297.310(7)(a)4., F.A.C.]

D.33. PM Tests Not Required. Annual and permit renewal compliance testing for particulate matter emissions is not required for this emissions unit while burning:
a. only gaseous fuel(s); or
b. gaseous fuel(s) in combination with any amount of liquid fuel(s) for less than 400 hours per year; or
c. only liquid fuel(s) for less than 400 hours per year.
See Specific Condition **TR7.** [Rules 62-297.310(7)(a)3. & 5., F.A.C.; and, ASP Number 97-B-01.]

D.34. Determining Actual SAM Emissions. The permittee must demonstrate on an annual basis, for a period of 5 years from the date of the maximum sulfur content tested, that SAM emissions increases as a result of this project are less than 7 TPY. The permittee shall operate the sorbent injection system at a frequency and injection rate for SAM control to satisfy this requirement. An automated control system will be used to adjust the sorbent flow rate for the given set of operating conditions based on the most recent performance test results. Actual SAM emissions shall be calculated using the information available for the given operating conditions (e.g., the sulfur content of fuel blend, the SO_2 emission rate prior to the SCR catalyst, the unit load, the flue gas flow rate, the sorbent injection rate and the current catalyst oxidation rate). If performance testing shows that it is unnecessary to operate the sorbent injection system for a given coal blend or the sorbent injection system is removed, the permittee shall determine actual SAM emissions based on emissions factors developed through the performance tests. [Air Construction Permit No. 1050004-026-AC, Specific Condition 16 and Rule 62-212.300(1)(e), F.A.C.]

D.35. Ammonia Slip Tests. Annual compliance with the ammonia (NH_3) slip target shall be determined using EPA conditional test method (CTM-027), EPA method 320, or other methods approved by the Department. If the tested ammonia slip rate exceeds 5 ppmv during the test, the permittee shall:
a. Begin testing and reporting the ammonia slip for each subsequent calendar quarter;
b. Before the ammonia slip exceeds 7 ppmv, take corrective actions that result in lowering the ammonia slip to less than 5 ppmv; and
c. Test and demonstrate that the ammonia slip is less than 5 ppmv within 30 days after completing the corrective actions.
Corrective actions may include, but are not limited to, adding catalyst, replacing catalyst, or other SCR system maintenance or repair. After demonstrating that the ammonia slip level is less than 5 ppmv, testing and reporting shall resume on an annual basis. [Air Construction Permit No. 1050004-026-AC, Specific Condition 18.]

Recordkeeping and Reporting Requirements

See Appendix RR, Facility-wide Reporting Requirements, for additional reporting requirements.

D.36. Reporting Schedule. The following report shall be submitted to the Compliance Authority:

Report	**Reporting Deadline(s)**	**Related Condition(s)**
NSPS Excess Emissions and Monitoring System Performance	Every 6 months (semi-annual), except when more frequent reporting is specifically required	**D.37. & D.39.**
Quarterly Excess Emissions	Every 3 months (quarter)	**D.33., D.34., D.35.**
Monthly CO CEMS		**D.36.**

{Note: If there are no periods of excess emissions as defined in 40 CFR 60 Subpart D, a statement to that effect may be submitted with the SIP Quarterly Excess Report to suffice for the NSPS Report.}
[40 CFR 60 Subpart A; and, Rule 62-210.700(6), F.A.C.]

D.37. Excess Emissions Reports - Malfunctions. In the case of excess emissions resulting from malfunctions, each owner or operator shall notify the Department in accordance with Rule 62-4.130, F.A.C. A full written

report on the malfunctions shall be submitted in a quarterly report, if requested by the Department. [Rule 62-210.700(6), F.A.C.]

D.38. Quarterly Excess Emissions Reports. Submit to the Department a written report of emissions in excess of emission limiting standards for each calendar quarter. The nature and cause of the excess emissions shall be explained. This report does not relieve the owner or operator of the legal liability for violations. All recorded data shall be maintained on file by the Source for a period of five years. [Rule 62-210.700(6), F.A.C.]

D.39. Excess Emissions Reporting- *SIP Quarterly Report*. Within 30 days following the end of each calendar-quarter, the permittee shall submit a report to the Compliance Authority summarizing periods of CO emissions in excess of the BACT permit standard following the NSPS format in 40 CFR 60.7(c), Subpart A. In addition, the report shall summarize the CO CEMS system monitor availability for the previous quarter. [Rules 62-4.130, 62-210.700(6) and 62-212.400(BACT), F.A.C.]

D.40. Monthly CO CEMS Report. The permittee shall submit, on a monthly basis, a report in electronic file format which includes Unit 3 CO, NO_X, and heat input data. The report shall be submitted by the 15th of each month by mailing a compact disc to the Department's Office of Permitting and Compliance (OPC), Title V Permitting Section and shall include all hourly readings from the previous month. Alternatively, upon contacting the Bureau's project engineer, the file may be emailed to the appropriate OPC personnel. [Rule 62-4.070(3), F.A.C.; and, PSD-FL-387.]

D.41. Excess Emissions Report. In addition to the requirements of 40 CFR 60.7, each excess emissions report shall include the periods of oil consumption due to flue gas desulfurization system malfunction. [PSD-FL-008]

Miscellaneous Requirements

D.42. NSPS Requirements - Subpart A. These emissions units shall comply with all applicable requirements of 40 CFR 60, Subpart A, General Provisions, including:

40 CFR 60.7, Notification and Recordkeeping
40 CFR 60.8, Performance Tests
40 CFR 60.11, Compliance with Standards and Maintenance Requirements
40 CFR 60.12, Circumvention
40 CFR 60.13, Monitoring Requirements
40 CFR 60.19, General Notification and Reporting requirements,

which have been adopted by reference in Rule 62-204.800(8)(d), F.A.C., except that the Secretary is not the Administrator for purposes of 40 CFR 60.4, 40 CFR 60.8(b)(2) and (3), 40 CFR 60.11(e)(7) and (8), 40 CFR 60.13(g), (i) and (j)(2), and 40 CFR 60.16. These emissions units shall comply with **Appendix 40 CFR 60 Subpart A** included with this permit. [Rule 62-204.800(8)(d), F.A.C.]

D.43. NSPS Requirements - Subpart D. Except as otherwise provided in this permit, this fossil-fuel fired steam generator shall comply with all applicable provisions of 40 CFR 60, Subpart D, Standards of Performance for Fossil-Fuel Fired Steam Generators for Which Construction is Commenced After August 17, 1971, adopted by reference in Rule 62-204.800(8)(b)1., F.A.C. This emissions unit shall comply with **Appendix 40 CFR 60 Subpart D** included with this permit. [Rule 62-204.800(8)(b)1., F.A.C.]

D.44. Future Actual Emissions Reporting. The permittee shall maintain and submit to the Department on an annual basis for a period of 5 years from the date the SCR systems are initially operated, information demonstrating in accordance with Rule 62-212.300(1)(e), F.A.C., using the emissions computation and reporting procedures in Rule 62-210.370, F.A.C., that the installation of LNB, OFA and SCR did not result in an emissions increase of PM or SAM that would equal or exceed the respective significant emission rates as defined in Rule 62-210.300, F.A.C. The future emissions shall be compared with the baseline actual emissions for the period 2001-2002 for SAM and 2002-2003 for PM as reported in the annual operating

reports (AOR) using EPA Method 5B for PM and Method 8A (controlled condensate) for SAM. [Air Construction Permit No. 1050004-019-AC, Specific Condition 14.]

D.45. New Control Equipment. In accordance with Rule 62-210.300(1)(a), F.A.C., if the sorbent injection system is removed, the permittee shall obtain an air construction permit to install new acid mist mitigation equipment or to reinstall the sorbent injection system if required to maintain SAM emissions below a 7 TPY increase above the baseline emissions, which were estimated at 136 TPY. [Air Construction Permit No. 1050004-026-AC]

D.46. NESHAP Requirements - Subpart UUUUU. Except as otherwise provided in this permit, this emissions unit boiler shall comply with all applicable provisions of 40 CFR 63, Subpart UUUUU, National Emissions Standards for Hazardous Air Pollutants (NESHAP): Coal- and Oil-Fired Electric Utility Steam Generating Units. This emissions unit shall comply with **Appendix 40 CFR 63 Subpart UUUUU** attached to this permit by date of April 15, 2015. [40 CFR 63 Subpart UUUUU]

The specific conditions in this section apply to the following emission units:

E.U. ID No.	Brief Description
-028	McIntosh Unit 5 - 370 MW Combined Cycle Stationary Combustion Turbine

McIntosh Unit 5 is a Westinghouse 501G combustion turbine operating in combined cycle with a HRSG and 120 MW steam electric turbine. The turbine is fired with natural gas or a maximum 0.05 percent, by weight, sulfur content No. 2 or superior grade of distillate fuel oil. NO_X emissions are controlled by low NO_X burners, water injection and a selective catalytic reduction (SCR) system. An oxidation catalyst was installed to control carbon monoxide (CO) and volatile organic compound (VOC) emissions in 2003. The stack parameters are: height, 300 feet; diameter, 20 feet; exit temperature, 187 degrees F; actual stack gas flow rate (gas), 1,271,428 acfm; and, actual stack gas flow rate (oil), 1,291,502 acfm.

{Permitting note(s): The emissions unit is regulated under Acid Rain, Phase II; NSPS - 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines, adopted and incorporated by reference in Rule 62-204.800(8)(b), F.A.C.; Rule 62-212.400(5), F.A.C., Prevention of Significant Deterioration (PSD); Rule 62-212.400(6), F.A.C., Best Available Control Technology (BACT) Determination, dated July 10, 1998; and, Rule 62-296.470, F.A.C., Clean Air Interstate Rule (CAIR). Simple cycle combustion turbine operation began in March, 2000. Combined cycle combustion turbine operation began in January, 2002.}

Essential Potential to Emit (PTE) Parameters

E.1. Permitted Capacity. The maximum heat input rates, based on the lower heating value (LHV) of each fuel to Unit 5 at ambient conditions of 59°F temperature, 60% relative humidity, 100% load, and 14.7 psi pressure shall not exceed 2,407 million Btu per hour when firing natural gas, nor 2,236 million Btu per hour when firing No. 2 or superior grade of distillate fuel oil. These maximum heat input rates will vary depending upon ambient conditions and the combustion turbine characteristics. Manufacturer's curves approved by the Department, attached in Appendix W501G McIntosh #5, Lakeland FL - Maximum Heat Input as a Function of Compressor Inlet Temperature (1/5/01), for the heat input correction to other temperatures may be utilized to establish heat input rates over a range of temperatures for compliance determination. Monitoring required under 40 CFR 60.334(a) shall satisfy periodic monitoring requirements for heat input. [Rules 62-4.160(2), 62-210.200 (Definitions - Potential to Emit (PTE)); and 62-213.440(1)(b)1.b., F.A.C.; and, PSD-FL-245C.]

E.2. Emissions Unit Operating Rate Limitation After Testing. See the related testing provisions in Appendix TR, Facility-wide Testing Requirements. [Rule 62-297.310(2), F.A.C.]

E.3. Methods of Operation - Fuels. Only pipeline natural gas or a maximum 0.05 percent, by weight, sulfur content No. 2 or superior grade of distillate fuel oil shall be fired in this unit. [Rules 62-212.400, 62-212.410, and 62-213.410, F.A.C.; and, PSD-FL-245.]

E.4. Hours of Operation. This emissions unit may operate continuously, i.e., 8,760 hours/year. [Rule 62-210.200 (Definitions - PTE), F.A.C.; and, PSD-FL-245.]

E.5. Fuel Usage as Heat Input - Fuel Oil. Fuel usage as heat input shall not exceed 599 x 10^9 Btu (LHV) per year (rolled monthly). [PSD-FL-245.]

Control Technology

E.6. Selective Catalytic Reduction. The permittee shall operate SCR equipment and operate an oxidation catalyst. The oxidation catalyst shall be designed for a minimum 90% destruction efficiency at base load. [PSD Permit Modification dated October 8, 2002, specific condition 17.]

E.7. Water Injection for Oil Firing. A water injection system shall be used when firing No. 2 or superior grade distillate fuel oil for control of NO_X emissions. [PSD-FL-245.]

Emission Limitations and Standards

Unless otherwise specified, the averaging times for Specific Conditions **E.9.-E.13.** are based on the specified averaging time of the applicable test method.

E.8. Summary of Emission Standards & Limits and Performance Criteria. The following table is a summary of the BACT determination and is followed by the applicable specific conditions **E.9.** through **E.13.** Values for NO_X are corrected to 15% O_2. Values for CO are corrected to 15% O_2.

Operational Mode	NO_X (ppm)	CO (ppm)	VOC (ppm)	PM/Visibility (% Opacity)	Technology and Comments
Combined	7.5 - NG (3 hr avg) 15 - FO (3-hr avg)	Oxidation Catalyst (annual test 2 ppm criteria at full load firing natural gas.)	Oxidation Catalyst	10	Conventional SCR with Oxidation Catalyst. Clean fuels, good combustion.

[PSD Permit Modification dated October 8, 2002, specific condition 20.]

E.9. Nitrogen Oxides. NO_X emissions shall not exceed 7.5 ppmvd at 15% O_2 when firing natural gas and 15 ppmvd at 15% O_2 when firing fuel oil on the basis of a 3-hour average, as measured by the CEMS. In addition, NO_X emissions calculated as NO_2 (at ISO conditions) shall not exceed 71.1 pounds per hour (when firing natural gas) and 148 pounds per hour (when firing fuel oil) to be demonstrated by stack tests. [PSD-FL-245.]

E.10. Carbon Monoxide Performance Criteria. The concentration of CO in the exhaust gas shall be additionally controlled by the use of an oxidation catalyst with a minimum of 90% CO removal efficiency (based upon design at base load). The CO emissions shall be tested annually at full load and shall not exceed 2 ppmvd when firing natural gas as measured by EPA Method 10. The oxidation catalyst shall be maintained according to manufacturer's recommendations, however in the event that CO emissions exceed 2 ppmvd (as demonstrated by annual testing above) the permittee shall implement a remedy and re-test within 90 days of operation. Should the re-test result in CO emissions exceeding 2 ppmvd, the remedy shall be to completely replace the oxidation catalyst. [PSD Permit Modification dated October 8, 2002, specific condition 22.]

E.11. Sulfur Dioxide. SO_2 emissions (at ISO conditions) shall not exceed 8 pounds per hour when firing pipeline natural gas and 127 pounds per hour when firing maximum 0.05 percent, by weight, sulfur content No. 2 or superior grade distillate fuel oil, as measured by applicable compliance methods. Emissions of SO_2 shall not exceed 38.4 tons per year. [PSD-FL-245C and Applicant request to Escape PSD Review.]

E.12. Visible Emissions. Visible emissions shall not exceed 10 percent opacity. [PSD-FL-245.]

E.13. Volatile Organic Compounds. VOC emissions shall be additionally controlled through the use of an oxidation catalyst. CO emissions shall be employed as a surrogate for VOC emissions and no further annual testing will be required. [PSD Permit Modification dated October 8, 2002, specific condition 25.]

Excess Emissions

The Excess Emissions Rule at Rule 62-210.700, F.A.C., cannot vary any requirement of a NSPS, NESHAP, or Acid Rain program provision.

E.14. Excess Emissions Allowed. Excess emissions from this emissions unit resulting from startup, shutdown, malfunction or fuel switching shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized. Excess emissions occurrences shall in no case exceed four hours in any 24 hour period for cold startup or two hours in any 24 hour period for other reasons unless specifically authorized by the Department for longer duration. During any calendar day in which a start-up, shutdown, or fuel change occurs, the following alternative NO_X limit applies:

a. 100 lbs/hr on the basis of a 24-hour average
b. 200 lbs/hr on the basis of a 24-hour average if fuel oil is fired during a start-up or shut-down within the 24-hour period.

[Rule 62-210.700(1), F.A.C.; and, PSD Permit Modification dated October 8, 2002, specific condition 26.]

E.15. Excess Emissions Prohibited. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. [Rule 62-210.700(4), F.A.C.]

Monitoring of Operations

E.16. Fuel Oil Monitoring Schedule. The following monitoring schedule for No. 2 or superior grade fuel oil shall be followed: For all bulk shipments of No. 2 or superior grade fuel oil received at the C. D. McIntosh, Jr. Power Plant, an analysis which reports the sulfur content and the nitrogen content of the fuel shall be provided by the vendor. The analysis shall also specify the methods by which the analysis was conducted and shall comply with the requirements of 40 CFR 60.335(d). [PSD-FL-245.]

E.17. Natural Gas Monitoring Schedule. The following custom monitoring schedule for natural gas is approved (pending EPA concurrence) in lieu of the daily sampling requirements of 40 CFR 60.334(b)(2):

a. Monitoring of natural gas nitrogen content shall not be required.
b. Analysis of the sulfur content of natural gas shall be conducted using one of the EPA-approved ASTM reference methods for the measurement of sulfur in gaseous fuels, or an approved alternate method. Monitoring of the sulfur content of the natural gas shall be conducted twice monthly for six months. If this monitoring shows little variability in the fuel sulfur content, and indicates consistent compliance with 40 CFR 60.333, then fuel sulfur monitoring shall be conducted once per quarter for six quarters and after that, semiannually.
c. Should any sulfur analysis indicate noncompliance with 40 CFR 60.333, the City shall notify DEP of such excess emissions and the custom fuel monitoring schedule shall be reexamined. The sulfur content of the natural gas will be monitored weekly during the interim period while the monitoring schedule is reexamined.
d. The City shall notify DEP of any change in natural gas supply for reexamination of this monitoring schedule. A substantial change in natural gas quality (i.e., sulfur content variation of greater than one grain per 100 cubic feet of natural gas) shall be considered as a change in the natural gas supply. Sulfur content of the natural gas will be monitored weekly by the natural gas supplier during the interim period when this monitoring schedule is being reexamined.
e. Records of sampling analyses and natural gas supply pertinent to this monitoring schedule shall be retained by the City for a period of five years, and shall be made available for inspection by the appropriate regulatory personnel.
f. The City may obtain the sulfur content of the natural gas from the fuel supplier (Florida Gas Transmission or Gulfstream) provided the approved test methods are used.

[PSD-FL-245.]

{Permitting note: The permittee may satisfy this custom monitoring schedule for natural gas in accordance with **Appendix GG** attached to this permit.}

Continuous Monitoring Requirements

E.18. Continuous Monitoring System. The permittee shall install, calibrate, maintain, and operate a continuous emission monitor in the stack to measure and record the nitrogen oxides emissions from Unit 5. Periods when NO_X emissions (ppmvd @ 15% oxygen) are above the BACT standards, listed in specific conditions **E.8.** and **E.9.**, shall be reported to the DEP Southwest District office pursuant to Rule 62-4.160(8), F.A.C. Following the format of 40 CFR 60.7, periods of startup, shutdown, malfunction and fuel switching shall be monitored,

recorded and reported as excess emissions when emission levels exceed the BACT standards listed in specific conditions **E.8.** and **E.9.** [PSD-FL-245 and 40 CFR 60.7.]

E.19. CEMS in lieu of Water to Fuel Ratio. Subject to EPA approval, the NO_X CEMS shall be used in lieu of the water/fuel monitoring system for reporting excess emissions in accordance with 40 CFR 60.334(c)(1). Subject to EPA approval, calibration of the water/fuel monitoring device required in 40 CFR 60.335(c)(2) will be replaced by the 40 CFR 75 certification tests of the NO_X CEMS. Upon request from DEP, the CEMS emissions rates for NO_X on Unit 5 shall be corrected to ISO conditions to demonstrate compliance with the NO_X standard established in 40 CFR 60.332. [PSD-FL-245.]

{Permitting note: The permittee may satisfy this condition for using the NOx CEMS in accordance with Appendix GG attached to this permit.}

E.20. Missing Data Substitution. When NO_X monitoring data is not available, substitution for missing data shall be handled as required by Title IV (40 CFR 75) to calculate any specified average time. [PSD-FL-245.]

E.21. Continuous Monitoring System. The monitoring devices shall comply with the certification and quality assurance, and any other applicable requirements of Rule 62-297.520, F.A.C., 40 CFR 60.13, including certification of each device in accordance with 40 CFR 60, Appendix B, Performance Specifications and 40 CFR 60.7(a)(5) or 40 CFR 75. Quality assurance procedures must conform to all applicable sections of 40 CFR 60, Appendix F or 40 CFR 75. [PSD-FL-245.]

Test Methods and Procedures

E.22. Test Methods. Required tests shall be performed in accordance with the following reference methods:

Method(s)	Description of Method(s) and Comment(s)
ASTM D2880-71 or D4294 (or latest version) for the sulfur content of liquid fuels and D1072-80, D3031-81, D4084-82 or D3246-81 (or latest version)	Methods for Evaluating Fuel Sulfur Content
EPA Method 9	Visual Determination of the Opacity of Emissions
EPA Method 10	Determination of Carbon Monoxide Emissions
EPA Reference Method 18, 25 and/or 25A	Determination of Volatile Organic Concentrations
EPA Method 7E	Determination of Nitrogen Oxide Emissions
EPA Method 20	Determination of Nitrogen Oxides, Sulfur Dioxide and Diluent Emissions from Stationary Gas Turbines

The above methods are described in Chapter 62-297, F.A.C. No other methods may be used unless prior written approval is received from the Department. [Chapter 62-297, F.A.C.]

E.23. Annual Compliance Tests. During each federal fiscal year (October 1st to September 30th), this emissions unit shall be tested to demonstrate compliance with the emissions standards for VE, CO and NO_X. The NO_X RATA test data may be used to demonstrate compliance with the annual test requirement, provided the testing requirements (notification, procedures & reporting) of Chapter 62-297, F.A.C. are met. [Rule 62-297.310(7), F.A.C.]

E.24. Compliance Tests Prior To Renewal. Prior to permit renewal, compliance test shall be performed for the following pollutants: VE, CO and NOX. [Rule 62-297.310(7)(a)3., F.A.C.]

E.25. Common Testing Requirements. Unless otherwise specified, tests shall be conducted in accordance with the requirements and procedures specified in Appendix TR, Facility-Wide Testing Requirements, of this permit. [Rule 62-297.310, F.A.C.]

E.26. Compliance with the Allowable Emission Limiting Standards - Each Fuel. Compliance with the allowable emission limiting standards shall be determined within 60 days after achieving the maximum production rate, for each fuel, at which this unit will be operated, but not later than 180 days after initial operation of the unit for that fuel, and annually thereafter as indicated in this permit, by using the reference methods as described in the latest edition of 40 CFR 60, Appendix A, and adopted by reference in Chapter 62-204.800, F.A.C. [PSD-FL-245.]

E.27. Compliance Testing. Initial (I) performance tests shall be performed on Unit 5 while firing natural gas as well as while firing fuel oil. Initial tests shall also be conducted after any modifications (and shakedown period not to exceed 100 days after restarting the combustion turbine) of air pollution control equipment, including installation of Ultra Low NO_X burners, Hot SCR, or conventional SCR. [PSD-FL-245.]

E.28. Continuous Compliance with the NO_X Emission Limits. Continuous compliance with the NOX emission limits shall be demonstrated with the CEMS based on the applicable averaging time of 24-hr block average (DLN or ULN technology) or a 3-hr average (if SCR is used). Based on CEMS data, a separate compliance determination is conducted at the end of each operating day (or 3-hr period when applicable) and a new average emission rate is calculated from the arithmetic average of all valid hourly emission rates from the previous operating day (or 3-hr period when applicable). Valid hourly emission rates shall not included periods of startup (including fuel switching), shutdown, or malfunction as defined in Rule 62-210.200, F.A.C., where emissions exceed the applicable NO_X standard. These excess emissions periods shall be reported as required. A valid hourly emission rate shall be calculated for each hour in which at least two NO_X concentrations are obtained at least 15 minutes apart. [PSD-FL-245.]

E.29. Compliance with the SO_2 and PM/PM_{10} Emission Limits. Not withstanding the requirements of Rule 62-297.340, F.A.C., the use of pipeline natural gas and maximum 0.05 percent sulfur (by weight) No. 2 or superior grade distillate fuel oil, is the method for determining compliance for SO2 and PM/PM10. For the purposes of demonstrating compliance with the 40 CFR 60.333 SO2 standard and the 0.05% S limit, fuel oil analysis using ASTM D2880-71 or D4294 (or latest version) for the sulfur content of liquid fuels and D1072-80, D3031-81, D4084-82 or D3246-81 (or latest version) for sulfur content of gaseous fuel shall be utilized in accordance with the EPA-approved custom fuel monitoring schedule. The applicant is responsible for ensuring that the procedures above are used for determination of fuel sulfur content. Analysis may be performed by the owner or operator, a service contractor retained by the owner or operator, the fuel vendor, or any other qualified agency pursuant to 40 CFR 60.335(e). [PSD-FL-245.]

E.30. Compliance with CO Emissions/Performance Criteria. Annual compliance testing for CO may be conducted concurrent with the annual RATA testing for NO_X required pursuant to 40 CFR 75 (required for gas only). [PSD-FL-245.]

E.31. Compliance with the VOC Emissions/Performance Criteria. The CO emission limit will be employed as a surrogate and no annual testing for VOC emissions is required. [PSD-FL-245.]

Record Keeping and Reporting Requirements

See Appendix RR, Facility-wide Reporting Requirements, for additional reporting requirements.

E.32. Reporting Schedule. The following report shall be submitted to the Compliance Authority:

Report	Reporting Deadline(s)	Related Condition(s)
NSPS Excess Emissions and Monitoring System Performance	Every 6 months (semi-annual), except when more frequent reporting is specifically required	**E.36.**
Quarterly Excess Emissions, if requested	Every 3 months (quarter)	**E.33.**

[40 CFR 60 Subpart A; and, Rule 62-210.700(6), F.A.C.]

E.33. Malfunction Reporting. In the case of excess emissions resulting from malfunctions, each owner or operator shall notify the Department's Southwest District office within one (1) working day of: the nature, extent, and duration of the excess emissions; and, the actions taken to correct the problem. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department. [Rule 62-210.700(6), F.A.C.; and, PSD-FL-245.]

Miscellaneous Requirements

E.34. Operating Procedures. Operating procedures shall include good operating practices and proper training of all operators and supervisors. The good operating practices shall meet the guidelines and procedures as established by the equipment manufacturers. All operators (including supervisors) of air pollution control devices shall be properly trained in plant specific equipment. [PSD-FL-245.]

E.35. Compliance Plan. Based on the application for Permit No. 1050004-016-AV, initial compliance has been demonstrated for natural gas firing, but not for distillate fuel oil firing. **Appendix CP, Compliance Plan** for McIntosh Unit 5, is attached as a part of this permit. [Rule 62-213.440(2), F.A.C.]

E.36. NSPS Requirements - Subpart A. These emissions units shall comply with all applicable requirements of 40 CFR 60, Subpart A, General Provisions, including:

40 CFR 60.7, Notification and Recordkeeping
40 CFR 60.8, Performance Tests
40 CFR 60.11, Compliance with Standards and Maintenance Requirements
40 CFR 60.12, Circumvention
40 CFR 60.13, Monitoring Requirements
40 CFR 60.19, General Notification and Reporting requirements,

which have been adopted by reference in Rule 62-204.800(8)(d), F.A.C., except that the Secretary is not the Administrator for purposes of 40 CFR 60.4, 40 CFR 60.8(b)(2) and (3), 40 CFR 60.11(e)(7) and (8), 40 CFR 60.13(g), (i) and (j)(2), and 40 CFR 60.16. This emissions unit shall comply with **Appendix 40 CFR 60 Subpart A** included with this permit. [Rule 62-204.800(8)(d), F.A.C.]

E.37. NSPS Requirements - Subpart GG. Except as otherwise provided in this permit, the combustion turbine shall comply with all applicable provisions of 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines, adopted by reference in Rule 62-204.800(8)(b), F.A.C., except that the Secretary is not the Administrator for purposes of 40 CFR 60.334(b)(2) and 40 CFR 60.335(f)(1). The Subpart GG requirement to correct test data to ISO conditions applies, but such correction is not required to demonstrate compliance with the non-NSPS permit standard(s). This emissions unit shall comply with **Appendix 40 CFR 60 Subpart GG** attached to this permit. [Rule 62-204.800(8)(b)39., F.A.C.]

The specific conditions in this section apply to the following emissions unit:

E.U. ID No.	Brief Description
-008	Diesel Drive Coal Tunnel Sump Engine

Emissions Unit -008 consists of a Lister diesel engine-driven non-emergency sump pump engine.

The following table provides important details for the above emission units:

E.U. ID No.	Engine Brake HP	Date of Construction	Primary Fuel	Type of Engine	Displacement liters/cylinder(l/c)	Serial Number	Date of last modification or reconstruction
-008	25	1981	Diesel	Non-Emergency	----	25M55A1 C20	N/A

{Permitting Note: This compression ignition reciprocating internal combustion engine (CI RICE) is regulated under 40 CFR 63, Subpart ZZZZ, NESHAP for Stationary RICE adopted in Rule 62.204.800(11)(b), F.A.C. This RICE is not used for fire pumps. This RICE is exempted from regulations under 40 CFR 60, Subpart IIII - New Source Performance for Stationary Internal Combustion Engines (ICE) based on the manufacturer date. This is an "existing" stationary CI RICE less than or equal to 500 HP, with a displacement of less than 10 liters per cylinder that is located at a major source of HAP and that has not been modified or reconstructed after 6/12/2006.}

Essential Potential to Emit (PTE) Parameters

F.1. Hours of Operation.

a. *Normal Operation*. The stationary RICE may operate continuously (8,760 hours a year) if needed. [40 CFR 63.6640(f)(1)]

b. *Engine Startup*. During periods of startup the owner or operator must minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply. [40 CFR 63.6625(h)]

F.2. Work or Management Practice Standards.

a. *Oil*. Change oil and filter every 1,000 hours of operation or annually, whichever comes first. [40 CFR 63.6602 & Table 2c.2.a.]

b. *Air Cleaner*. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first and replace as necessary. [40 CFR 63.6602 & Table 2c.2.b.]

c. *Hoses and Belts*. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary. [40 CFR 63.6602 & Table 2c.2.c.]

d. *Operation and Maintenance*. Operate and maintain the stationary RICE according to the manufacturer's emission-related operation and maintenance instructions or develop and follow your own maintenance plan which must provide, to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution, control practice for minimizing emissions. [40 CFR 63.6625(e), 63.6640(a) & Table 6.9.a.]

e. *Engine Startup*. During periods of startup the owner or operator must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63.6625(h)]

f. *Oil Analysis*. The owner or operator has the option of using an oil analysis program to extend the oil change requirement. The oil analysis must be performed at the same frequency specified for changing the oil in paragraph **a**., above. The analysis program must at a minimum analyze the following three

parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR 63.6625(i)]

Monitoring of Operations

F.3. RESERVED

Compliance

F.4. Continuous Compliance. Each unit shall be in compliance with the emission limitations and operating standards in this section at all times. [40 CFR 63.6605(a)]

F.5. Operation and Maintenance of Equipment. At all times the owner or operator must operate and maintain, any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. Determination of whether such operation and maintenance procedures are being used will be based on information available to the compliance authority which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source. [40 CFR 63.6605(b)]

Recordkeeping Requirements

F.6. Notification, Performance and Compliance Records. The owner or operator must keep:

a. A copy of each notification and report that the owner or operator submitted to comply with this section, including all documentation supporting any Initial Notification or Notification of Compliance Status that the owner or operator submitted.
b. Records of the occurrence and duration of each malfunction of operation.
c. Records of all required maintenance performed on the hour meter.
d. Records of actions taken during periods of malfunction to minimize emissions in accordance with Specific Condition **F.5.**, including corrective actions to restore malfunctioning process and monitoring equipment to its normal or usual manner of operation.
e. Records of the actions required in specific condition **F.2.d.** to show continuous compliance with each operating requirement.
f. Records of the Work or Management Practice Standards specified in Specific Condition **F.2.**
g. Records of the maintenance conducted in order to demonstrate that the RICE was operated and maintained according to your own maintenance plan.
h. Records of the hours of operation of the engine that is recorded through the non-resettable hour meter. [40 CFR 63.6655]

F.7. Record Retention.

a. The owner or operator must keep records in a suitable and readily available form for expeditious reviews.
b. The owner or operator must keep each record readily accessible in hard copy or electronic form for at least 5 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record.

[40 CFR 63.6660 and 40 CFR 63.10(b)(1)]

Reporting Requirements

F.8. Delay of Performing Work Practice Requirements. If it is not possible to shut down the engine in order to perform the work practice requirements on the schedule required in Specific Condition **F.2.**, or if performing the work practice on the required schedule would otherwise pose an unacceptable risk under federal, state, or local law, the work practice can be delayed until the emergency is over or the unacceptable risk under federal, state, or local law has abated. The work practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under federal, state, or local law has abated. Sources must report any failure to perform the work practice on the schedule required and the federal, state or local law under which the risk was deemed unacceptable. [40 CFR 63, Subpart ZZZZ, Table 2c, footnote 1]

General Provisions

F.9. 40 CFR 63 Subpart A - General Provisions. The owner or operator shall comply with the following applicable requirements of 40 CFR 63 Subpart A - General Provisions, which have been adopted by reference in Rule 62-204.800(11)(d)1., F.A.C., except that the Secretary is not the Administrator for purposes of 40 CFR 63.5(e), 40 CFR 63.5(f), 40 CFR 63.6(g), 40 CFR 63.6(h)(9), 40 CFR 63.6(j), 40 CFR 63.13, and 40 CFR 63.14. Link to 40 CFR 63, Subpart A - General Provisions

General Provisions Citation	Subject of Citation
§63.1	General applicability of the General Provisions
§63.2	Definitions (additional terms defined in 43 CFR 63.6675)
§63.3	Units and abbreviations
§63.4	Prohibited activities and circumvention
§63.5	Construction and reconstruction
§63.6(a)	Applicability
§63.9(a)	Applicability and State delegation of notification requirements
§63.9(b)(1)-(5)	Initial notifications (except that §63.9(b)(3) is reserved)
§63.9(i)	Adjustment of submittal deadlines
§63.9(j)	Change in previous information
§63.10(a)	Administrative provisions for recordkeeping/reporting
§63.10(b)(1)	Record retention
§63.10(b)(2)(vi)–(xi)	Records
§63.10(b)(2)(xii)	Record when under waiver
§63.10(b)(2)(xiv)	Records of supporting documentation
§63.10(b)(3)	Records of applicability determination
§63.10(d)(1)	General reporting requirements
§63.10(f)	Waiver for recordkeeping/reporting
§63.12	State authority and delegations
§63.13	Addresses
§63.14	Incorporation by reference
§63.15	Availability of information

[40 CFR 63.6665 & Table 8 to Subpart ZZZZ of Part 63]

The specific conditions in this section apply to the following emissions unit:

ID No.	Emission Unit Description
-010	Fire Water UPS Diesel No. 32

Emissions Unit -010 consists of a Cummins diesel engine-driven emergency fire pump.

The following table provides important details for this engine:

Engine Identification	Engine Brake HP	Date of Installation	Model Year	Displacement liters/cylinder (l/c)	Engine Manufacturer	Model No.
Emergency Fire Pump	300	April 1989		14	Cummins	NT 885-F3

{Permitting Note: The engine is an emergency use engine, this unit is not subject to the VOC and NO_X RACT requirements contained in Rules 62-296.500 & 570, F.A.C. This compression ignition reciprocating internal combustion engine (CI RICE) is regulated under 40 CFR 63, Subpart ZZZZ, National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE) adopted in Rule 62.204.800(11)(b), F.A.C. This permit section addresses an "existing" emergency stationary CI RICE fire pump engine less than or equal to 500 HP that is located at a major source of HAPs and that has not been modified or reconstructed after 6/12/2006.}

Essential Potential to Emit (PTE) Parameters

G.1. Hours of Operation.

a. *Emergency Situations*. There is no time limit on the use of emergency stationary RICE in emergency situations. [40 CFR 63.6640(f)(1)]

b. *Maintenance and Testing*. This unit is authorized to operate for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, or the insurance company associated with the engine. Maintenance checks and readiness testing of such units is limited to 100 hours per year. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency RICE beyond 100 hours per year. [40 CFR 63.6640(f)(2)(i)]

c. *Non-emergency Situations*. This unit is authorized to operate up to 50 hours per year in non-emergency situations, but those 50 hours are counted towards the 100 hours per year provided for maintenance and testing. [40 CFR 63.6640(f)(2)(iii)]

Emission Limitations and Operating Requirements

G.2. Work or Management Practice Standards.

a. *Oil*. Change oil and filter every 500 hours of operation or annually, whichever comes first. [40 CFR 63.6602 & Table 2c.1.a.]

b. *Air Cleaner*. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first, and replace as necessary. [40 CFR 63.6602 & Table 2c.1.b.]

c. *Hoses and Belts*. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary. [40 CFR 63.6602 & Table 2c.1.c.]

d. *Operation and Maintenance*. Operate and maintain the stationary RICE according to the manufacturer's emission-related operation and maintenance instructions or develop and follow your own maintenance plan which must provide, to the extent practicable for the maintenance and operation of the engine in a

manner consistent with good air pollution control practice for minimizing emissions. [40 CFR 63.6625(e) & Table 6.9.].

e. *Engine Startup*. During periods of startup the owner or operator must minimize the engine's time spent at idle and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63.6625(h)]

f. *Oil Analysis*. The owner or operator has the option of using oil analysis to extend the oil change requirement. The oil analysis must be performed at the same frequency specified for changing the oil in paragraph a., of this condition. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR 63.6625(i)]

Monitoring of Operations

G.3. Hour Meter. The owner or operator must install a non-resettable hour meter if one is not already installed. [40 CFR 63.6625(f)]

Compliance

G.4. Continuous Compliance. Each unit shall be in compliance with the emission limitations, operating limitations, and other requirements in this section at all times. [40 CFR 63.6605(a)]

G.5. Operation and Maintenance of Equipment. At all times the owner or operator must operate and maintain, any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. Determination of whether such operation and maintenance procedures are being used will be based on information available to the compliance authority which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source. [40 CFR 63.6605(b)]

Recordkeeping Requirements

G.6. Notification, Performance and Compliance Records. The owner or operator must keep:

a. A copy of each notification and report that the owner or operator submitted to comply with this section, including all documentation supporting any Initial Notification or Notification of Compliance Status that the owner or operator submitted.
b. Records of the occurrence and duration of each malfunction of operation.
c. Records of all required maintenance performed on the hour meter.
d. Records of actions taken during periods of malfunction to minimize emissions in accordance with Specific Condition **G.5.**, including corrective actions to restore malfunctioning process and monitoring equipment to its normal or usual manner of operation.
e. Records of the actions required in specific condition **G.2.d.** to show continuous compliance with each emission limitation or operating requirement.
f. Records of the Work or Management Practice Standards specified in Specific Condition **G.2.**

g. Records of the maintenance conducted in order to demonstrate that the RICE was operated and maintained according to your own maintenance plan.
h. Records of the hours of operation of the engine that is recorded through the non-resettable hour meter. The owner or operator must document how many hours are spent for emergency operation including what classified the operation as emergency and how many hours are spent for non-emergency operation. If the engines are used for emergency demand response operation or for periods of voltage or frequency deviations, the owner or operator must keep records of the notification of the emergency situation, and the time of engine operation for these purposes.

[40 CFR 63.6655]

G.7. Record Retention.
a. The owner or operator must keep records in a suitable and readily available form for expeditious reviews.
b. The owner or operator must keep each record readily accessible in hard copy or electronic form for at least 5 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record.

[40 CFR 63.6660 and 40 CFR 63.10(b)(1)]

Reporting Requirements

G.8. Delay of Performing Work Practice Requirements. If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the work practice requirements on the schedule required in specific condition **G.2.** of this section, or if performing the work practice on the required schedule would otherwise pose an unacceptable risk under Federal, State, or local law, the work practice can be delayed until the emergency is over or the unacceptable risk under Federal, State, or local law has abated. The work practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, State, or local law has abated. Sources must report any failure to perform the work practice on the schedule required and the Federal, State or local law under which the risk was deemed unacceptable. [40 CFR 63, Subpart ZZZZ, Table 2c, footnote 1]

General Provisions

G.9. 40 CFR 63 Subpart A - General Provisions. The owner or operator shall comply with the following applicable requirements of 40 CFR 63 Subpart A - General Provisions, which have been adopted by reference in Rule 62-204.800(11)(d)1., F.A.C., except that the Secretary is not the Administrator for purposes of 40 CFR 63.5(e), 40 CFR 63.5(f), 40 CFR 63.6(g), 40 CFR 63.6(h)(9), 40 CFR 63.6(j), 40 CFR 63.13, and 40 CFR 63.14. Link to 40 CFR 63, Subpart A - General Provisions

General Provisions Citation	Subject of Citation
§63.1	General applicability of the General Provisions
§63.2	Definitions (Additional terms defined in §63.6675)
§63.3	Units and abbreviations
§63.4	Prohibited activities and circumvention
§63.5	Construction and reconstruction
§63.6(a)	Applicability
§63.9(a)	Applicability and State delegation of notification requirements
§63.9(b)(1)–(5)	Initial notifications (Except that §63.9(b)(3) is reserved)
§63.9(i)	Adjustment of submittal deadlines
§63.9(j)	Change in previous information
§63.10(a)	Administrative provisions for recordkeeping/reporting
§63.10(b)(1)	Record retention
§63.10(b)(2)(vi)–(xi)	Records

General Provisions Citation	Subject of Citation
§63.10(b)(2)(xii)	Record when under waiver
§63.10(b)(2)(xiv)	Records of supporting documentation
§63.10(b)(3)	Records of applicability determination
§63.10(d)(1)	General reporting requirements
§63.10(f)	Waiver for recordkeeping/reporting
§63.12	State authority and delegations
§63.13	Addresses
§63.14	Incorporation by reference
§63.15	Availability of information

[40 CFR 63.6665 & Table 8 to Subpart ZZZZ of Part 63]

The specific conditions in this section apply to the following emissions units:

E.U. ID No.	Brief Description
-011	CT Startup Diesel Engine

This Detroit Diesel engine is used as startup engine for the combustion turbine previously described in Section III.

The following table provides important details for these emissions units:

E.U. ID No.	Engine Brake HP	Date of Construction	Model Year	Primary Fuel	Type of Engine	Displacement liters/cylinder (l/c)	Serial #	Date of last mod. or reconst.
-015	500	1969		Diesel	Black Start		CH8118	N/A

{Permitting Note: This emissions unit, compression ignition (CI) engine, is regulated under 40 CFR 63, Subpart ZZZZ, NESHAP for Stationary RICE adopted in Rule 62.204.800(11)(b), F.A.C. This RICE is not used for fire pumps. This permit section addresses "existing" stationary CI RICE less than or equal to 500 HP that are located at a major source of HAP and that have not been modified or reconstructed after 6/12/2006. Unless the RICE is modified or reconstructed after 7/11/2005, NSPS 40 CFR 60, Subpart IIII, will not apply. The permittee shall comply with the following emissions and operating limitations no later than May 3, 2013, or as otherwise stated in Subpart ZZZZ.}

Operation and Maintenance Requirements

H.1. Work or Management Practice Standards.

a. Change oil and filter every 500 hours of operation or annually, whichever comes first. Sources have the option to utilize an oil analysis program as described in 40 CFR 63.6625(i) or (j) in order to extend the specified oil change requirement; [40 CFR 63.6602 Table 2c(1)(a) and footnote 2]

b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first; and [40 CFR 63.6602 Table 2c(1)(b)]

c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary. Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices. [40 CFR 63.6602 Table 2c(1)(c) and footnote 3]

Monitoring of Operations

H.2. Monitoring of Operations. If you own or operate an existing black start stationary RICE located at a major source of HAP emissions, you must operate and maintain the stationary RICE and after-treatment control device (if any) according to the manufacturer's emission-related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions. [40 CFR 63.6625(e)(2)]

H.3. Monitoring of Operations. During periods of startup you must minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply. Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices. [40 CFR 63.6602 Table 2c(1) and footnote 3]

Compliance

H.4. Work or Management Practices. Compliance with the operating limitations, and other requirements:

a. You must demonstrate continuous compliance with each operating limitation and other requirements in Table 2c to this subpart that apply to you.

b. You must report each instance in which you did not meet each operating limitation in Table 2c to this subpart that apply to you. These instances are deviations from the emission and operating limitations in this subpart. These deviations must be reported according to the requirements in 40 CFR 63.6650. [40 CFR 63.6640(a) and (b)]

Recordkeeping Requirements

H.5. Notification, Performance and Compliance Records. If you must comply with the emission and operating limitations, you must keep the records described below:

a. A copy of each notification and report that you submitted to comply with this subpart, including all documentation supporting any Initial Notification or Notification of Compliance Status that you submitted, according to the requirement in §63.10(b)(2)(xiv).

b. Records of the occurrence and duration of each malfunction of operation (*i.e.*, process equipment) or the air pollution control and monitoring equipment.

c. Reserved.

d. Records of all required maintenance performed on the air pollution control and monitoring equipment.

e. Records of actions taken during periods of malfunction to minimize emissions in accordance with §63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation.. [40 CFR 63.6655(a)(1) through (5)]

H.6. Delay of Performing Work Practice Requirements. If performing the work practice on the required schedule would otherwise pose an unacceptable risk under Federal, State, or local law, the work practice can be delayed until the emergency is over or the unacceptable risk under Federal, State, or local law has abated. The work practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, State, or local law has abated. Sources must report any failure to perform the work practice on the schedule required and the Federal, State or local law under which the risk was deemed unacceptable. [40 CFR 63, Subpart ZZZZ, Table 2c, footnote 1]

General Provisions

H.7. 40 CFR 63 Subpart A - General Provisions. The owner or operator shall comply with the following applicable requirements of 40 CFR 63 Subpart A - General Provisions, which have been adopted by reference in Rule 62-204.800(11)(d)1., F.A.C., except that the Secretary is not the Administrator for purposes of 40 CFR 63.5(e), 40 CFR 63.5(f), 40 CFR 63.6(g), 40 CFR 63.6(h)(9), 40 CFR 63.6(j), 40 CFR 63.13, and 40 CFR 63.14. Link to 40 CFR 63, Subpart A - General Provisions

General Provisions Citation	Subject of Citation
§63.1	General applicability of the General Provisions
§63.2	Definitions (Additional terms defined in §63.6675)
§63.3	Units and abbreviations
§63.4	Prohibited activities and circumvention
§63.5	Construction and reconstruction
§63.6(a)	Applicability
§63.9(a)	Applicability and State delegation of notification requirements
§63.9(b)(1)–(5)	Initial notifications (Except that §63.9(b)(3) is reserved)
§63.9(i)	Adjustment of submittal deadlines
§63.9(j)	Change in previous information
§63.10(a)	Administrative provisions for recordkeeping/reporting
§63.10(b)(1)	Record retention
§63.10(b)(2)(vi)–(xi)	Records
§63.10(b)(2)(xii)	Record when under waiver
§63.10(b)(2)(xiv)	Records of supporting documentation
§63.10(b)(3)	Records of applicability determination
§63.10(d)(1)	General reporting requirements
§63.10(f)	Waiver for recordkeeping/reporting
§63.12	State authority and delegations
§63.13	Addresses
§63.14	Incorporation by reference
§63.15	Availability of information

[40 CFR 63.6665 & Table 8 to Subpart ZZZZ of Part 63]

SECTION IV. ACID RAIN PART.

Federal Acid Rain Provisions

Operated by: Lakeland Electric
ORIS Code: 0676

The emissions units listed below are regulated under Acid Rain, Phase II.

E.U. ID No.	Brief Description
-001	Boiler - McIntosh Unit 1
-005	Boiler - McIntosh Unit 2
-006	Boiler - McIntosh Unit 3
-028	McIntosh Unit 5 – 370 MW Combined Cycle Stationary Combustion Turbine

A.1. The Phase II Acid Rain Part application submitted for this facility, as approved by the Department, is a part of this permit. The owners and operators of these Phase II acid rain units must comply with the standard requirements and special provisions set forth in the application listed below:

a. DEP Form No. 62-210.900(1)(a), dated 5/15/2013, received 5/17/2013.
[Chapter 62-213, F.A.C. and Rule 62-214.320, F.A.C.]

A.2. Nitrogen oxide (NO_X) requirements for each Acid Rain Phase II unit are as follows:

E.U. ID #	EPA ID	NO_X Limit
-006	**03**	The Florida Department of Environmental Protection approves a NO_X compliance plan for this unit. The compliance plan is effective for calendar year 2014 through calendar year 2018. This unit's applicable emission limitation for each year of the plan, is 0.46 lb/MMBtu from 40 CFR 76.7(a)(2) for dry bottom wall-fired boilers. In addition to the described NO_X compliance plan, this unit shall comply with all other applicable requirements of 40 CFR Part 76, including the duty to reapply for a NO_X compliance plan and the requirements covering excess emissions.

A.3. Sulfur Dioxide (SO_2) Emission Allowances. SO_2 emissions from sources subject to the Federal Acid Rain Program (Title IV) shall not exceed any allowances that the source lawfully holds under the Federal Acid Rain Program. Allowances shall not be used to demonstrate compliance with a non-Title IV applicable requirement of the Act.

a. No permit revision shall be required for increases in emissions that are authorized by allowances acquired pursuant to the Federal Acid Rain Program, provided that such increases do not require a permit revision pursuant to Rule 62-213.400(3), F.A.C.
b. No limit shall be placed on the number of allowances held by the source under the Federal Acid Rain Program.
c. Allowances shall be accounted for under the Federal Acid Rain Program.

[Rule 62-213.440(1)(c)1., 2. & 3., F.A.C.]

A.4. Comments, Notes, and Justifications: None.

Acid Rain Part Application

For more information, see instructions and refer to 40 CFR 72.30, 72.31, and 74; and Chapter 62-214, F.A.C.

This submission is: ☐ New ☐ Revised ■ Renewal

STEP 1

Identify the source by plant name, state, and ORIS or plant code.

Plant name	State	ORIS/Plant Code
C.D. McIntosh, Jr. Power Plant	FL	0676

STEP 2
Enter the unit ID# for every Acid Rain unit at the Acid Rain source in column "a."

If unit a SO_2 Opt-in unit, enter "yes" in column "b".

For new units or SO_2 Opt-in units, enter the requested information in columns "d" and "e."

a	b	c	d	e
Unit ID#	SO_2 Opt-in Unit? (Yes or No)	Unit will hold allowances in accordance with 40 CFR 72.9(c)(1)	New or SO_2 Opt-in Units Commence Operation Date	New or SO_2 Opt-in Units Monitor Certification Deadline
EU 001	No	Yes	N/A	N/A
EU 005	No	Yes	N/A	N/A
EU 006	No	Yes	N/A	N/A
EU 028	No	Yes	N/A	N/A

DEP Form No. 62-210.900(1)(a) – Form
Effective: 3/16/08

1

C.D. McIntosh, Jr. Power Plant

Plant Name (from STEP 1)

STEP 3

Read the standard requirements.

Acid Rain Part Requirements.

(1) The designated representative of each Acid Rain source and each Acid Rain unit at the source shall:
(i) Submit a complete Acid Rain Part application (including a compliance plan) under 40 CFR Part 72 and Rules 62-214.320 and 330, F.A.C., in accordance with the deadlines specified in Rule 62-214.320, F.A.C.; and
(ii) Submit in a timely manner any supplemental information that the DEP determines is necessary in order to review an Acid Rain Part application and issue or deny an Acid Rain Part;
(2) The owners and operators of each Acid Rain source and each Acid Rain unit at the source shall:
(i) Operate the unit in compliance with a complete Acid Rain Part application or a superseding Acid Rain Part issued by the DEP; and
(ii) Have an Acid Rain Part.

Monitoring Requirements.

(1) The owners and operators and, to the extent applicable, designated representative of each Acid Rain source and each Acid Rain unit at the source shall comply with the monitoring requirements as provided in 40 CFR Part 75, and Rule 62-214.420, F.A.C.
(2) The emissions measurements recorded and reported in accordance with 40 CFR Part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
(3) The requirements of 40 CFR Part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.
(4) For applications including a SO_2 Opt-in unit, a monitoring plan for each SO_2 Opt-in unit must be submitted with this application pursuant to 40 CFR 74.14(a). For renewal applications for SO_2 Opt-in units include an updated monitoring plan if applicable under 40 CFR 75.53(b).

Sulfur Dioxide Requirements.

(1) The owners and operators of each source and each Acid Rain unit at the source shall:
(i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)), or in the compliance subaccount of another Acid Rain unit at the same source to the extent provided in 40 CFR 73.35(b)(3), not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and
(ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
(2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
(3) An Acid Rain unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
(i) Starting January 1, 2000, an Acid Rain unit under 40 CFR 72.6(a)(2); or
(ii) Starting on the later of January 1, 2000, or the deadline for monitor certification under 40 CFR Part 75, an Acid Rain unit under 40 CFR 72.6(a)(3).
(4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
(5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
(6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain Part application, the Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
(7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

Nitrogen Oxides Requirements. The owners and operators of the source and each Acid Rain unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

Excess Emissions Requirements.

(1) The designated representative of an Acid Rain unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR Part 77.
(2) The owners and operators of an Acid Rain unit that has excess emissions in any calendar year shall:
(i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR Part 77; and
(ii) Comply with the terms of an approved offset plan, as required by 40 CFR Part 77.

Recordkeeping and Reporting Requirements.

(1) Unless otherwise provided, the owners and operators of the source and each Acid Rain unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the EPA or the DEP:
(i) The certificate of representation for the designated representative for the source and each Acid Rain unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with Rule 62-214.350, F.A.C.; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;
(ii) All emissions monitoring information, in accordance with 40 CFR Part 75, provided that to the extent that 40 CFR Part 75 provides for a 3-year period for recordkeeping, the 3-year period shall apply;
(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and,

C.D. McIntosh, Jr. Power Plant
Plant Name (from STEP 1)

STEP 3, Continued.

Recordkeeping and Reporting Requirements (cont)

(iv) Copies of all documents used to complete an Acid Rain Part application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.

(2) The designated representative of an Acid Rain source and each Acid Rain unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR Part 72, Subpart I, and 40 CFR Part 75.

Liability.

(1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain Part application, an Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.
(2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.
(3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.
(4) Each Acid Rain source and each Acid Rain unit shall meet the requirements of the Acid Rain Program.
(5) Any provision of the Acid Rain Program that applies to an Acid Rain source (including a provision applicable to the designated representative of an Acid Rain source) shall also apply to the owners and operators of such source and of the Acid Rain units at the source.
(6) Any provision of the Acid Rain Program that applies to an Acid Rain unit (including a provision applicable to the designated representative of an Acid Rain unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR 72.44 (Phase II repowering extension plans) and 40 CFR 76.11 (NO_x averaging plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR Part 75 (including 40 CFR 75.16, 75.17, and 75.18), the owners and operators and the designated representative of one Acid Rain unit shall not be liable for any violation by any other Acid Rain unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative.
(7) Each violation of a provision of 40 CFR Parts 72, 73, 74, 75, 76, 77, and 78 by an Acid Rain source or Acid Rain unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

Effect on Other Authorities.

No provision of the Acid Rain Program, an Acid Rain Part application, an Acid Rain Part, or an exemption under 40 CFR 72.7or 72.8 shall be construed as:
(1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an Acid Rain source or Acid Rain unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;
(2) Limiting the number of allowances a unit can hold; *provided*, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Act;
(3) Requiring a change of any kind in any state law regulating electric utility rates and charges, affecting any state law regarding such state regulation, or limiting such state regulation, including any prudence review requirements under such state law;
(4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,
(5) Interfering with or impairing any program for competitive bidding for power supply in a state in which such program is established.

STEP 4
For SO_2 Opt-in units only.

In column "f" enter the unit ID# for every SO_2 Opt-in unit identified in column "a" of STEP 2.

For column "g" describe the combustion unit and attach information and diagrams on the combustion unit's configuration.

In column "h" enter the hours.

f	g	h (not required for renewal application)
Unit ID#	Description of the combustion unit	Number of hours unit operated in the six months preceding initial application
N/A	N/A	N/A

DEP Form No. 62-210.900(1)(a) – Form
Effective: 3/16/08

3

C.D. McIntosh, Jr. Power Plant

Plant Name (from STEP 1)

STEP 5

For SO_2 Opt-in units only.
(Not required for SO_2 Opt-in renewal applications.)

In column "i" enter the unit ID# for every SO_2 Opt-in unit identified in column "a" (and in column "f").

For columns "j" through "n," enter the information required under 40 CFR 74.20-74.25 and attach all supporting documentation required by 40 CFR 74.20-74.25.

i	j	k	l	m	n
Unit ID#	Baseline or Alternative Baseline under 40 CFR 74.20 (mmBtu)	Actual SO_2 Emissions Rate under 40 CFR 74.22 (lbs/mmBtu)	Allowable 1985 SO_2 Emissions Rate under 40 CFR 74.23 (lbs/mmBtu)	Current Allowable SO_2 Emissions Rate under 40 CFR 74.24 (lbs/mmBtu)	Current Promulgated SO_2 Emissions Rate under 40 CFR 74.25 (lbs/mmBtu)
N/A	N/A	N/A	N/A	N/A	N/A

STEP 6

For SO_2 Opt-in units only.

Attach additional requirements, certify and sign.

A. If the combustion source seeks to qualify for a transfer of allowances from the replacement of thermal energy, a thermal energy plan as provided in 40 CFR 74.47 for combustion sources must be attached.
B. A statement whether the combustion unit was previously an affected unit under 40 CFR 74.
C. A statement that the combustion unit is not an affected unit under 40 CFR 72.6 and does not have an exemption under 40 CFR 72.7, 72.8, or 72.14.
D. Attach a complete compliance plan for SO_2 under 40 CFR 72.40.
E. The designated representative of the combustion unit shall submit a monitoring plan in accordance with 40 CFR 74.61. For renewal application, submit an updated monitoring plan if applicable under 40 CFR 75.53(b).
F. The following statement must be signed by the designated representative or alternate designated representative of the combustion source: "I certify that the data submitted under 40 CFR Part 74, Subpart C, reflects actual operations of the combustion source and has not been adjusted in any way."

Signature N/A | Date N/A 5/15/13

STEP 7

Read the certification statement; provide name, title, owner company name, phone, and e-mail address; sign, and date.

Certification (for designated representative or alternate designated representative only)

I am authorized to make this submission on behalf of the owners and operators of the Acid Rain source or Acid Rain units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Subject: Acid Rain Part Application (C.D.McIntosh, Jr. Power Plant)

Name Mr Tony Candales | Title Assistant General Manager of Production

Owner Company Name Lakeland Electric

Phone (863) 834-6559 | E-mail address tony.candales@lakelandelectric.com

Signature | Date 5/15/13

DEP Form No. 62-210.900(1)(a) – Form
Effective: 3/16/08

4

SECTION IV. ACID RAIN PART.

United States
Environmental Protection Agency
Acid Rain Program

OMB No. 2060-0258

Phase II NO_x Compliance Plan

Page 1 of 2

For more information, see instructions and refer to 40 CFR 76.9

This submission is: [X] New [ ] Revised

Step 1
Indicate plant name, State, and ORIS code from NADB, if applicable

Plant Name	State	ORIS Code
C.D. McIntosh, Jr. Power Plant	FL	0676

Step 2
Identify each affected Group 1 and Group 2 boiler using the boiler ID# from NADB, if applicable. Indicate boiler type: "GB" for cell burner, "CY" for cyclone, "DBW" for dry bottom wall fired, "T" for tangentially fired, "V" for vertically fired, and "WB" for wet bottom. Indicate the compliance option selected for each unit.

	ID# 03 (EU006) Type DBW	ID# Type	ID# Type	ID# Type	ID# Type	ID# Type
(a) Standard annual average emission limitation of 05.0 lb/mmBtu (for Phase I dry bottom wall-fired boilers)	[ ]	[ ]	[ ]	[ ]	[ ]	[ ]
(b) Standard annual average emission limitation of 0.45 lb/mmBtu (for Phase I tangentially fired boilers)	[ ]	[ ]	[ ]	[ ]	[ ]	[ ]
(c) EPA-approved early election plan under 40 CFR 76.8 through 12/31/07 (also indicate above emission limit specified in	[ ]	[ ]	[ ]	[ ]	[ ]	[ ]
(d) standard annual average emission limitation of 0.46 lb/mmBtu (for Phase II dry bottom wall-fired boilers)	[X]	[ ]	[ ]	[ ]	[ ]	[ ]
(e) Standard annual average emission limitation of 4.0 lb/mmBtu (for Phase II tangentially fired boilers)	[ ]	[ ]	[ ]	[ ]	[ ]	[ ]
(f) Standard annual average emission limitation of 0.68 lb/mmBtu (for cell burner boilers)	[ ]	[ ]	[ ]	[ ]	[ ]	[ ]
(g) Standard annual average emission limitation of .086 lb/mmBtu (for cyclone boilers)	[ ]	[ ]	[ ]	[ ]	[ ]	[ ]
(h) Standard annual average emission limitation of 0.80 lb/mmBtu (for vertically fired boilers)	[ ]	[ ]	[ ]	[ ]	[ ]	[ ]
(i) Standard annual average emission limitation of 0.84 lb/mmBtu (for wet bottom boilers)	[ ]	[ ]	[ ]	[ ]	[ ]	[ ]
(j) NO_x Averaging Plan (include NO_x Averaging form)	[ ]	[ ]	[ ]	[ ]	[ ]	[ ]
(k) Common stack pursuant to 40 CFR 75.17(a)(2)(i)(A)(check the standard emission limitation applicable to any unit utilizing stack)	[ ]	[ ]	[ ]	[ ]	[ ]	[ ]
(l) Common stack pursuant to 40 CFR 75.17(a)(2)(i)(B) with NOX Averaging (check the NOX Averaging Plan box and include NOX Averaging form)	[ ]	[ ]	[ ]	[ ]	[ ]	[ ]

EPA Form 7610-28 (3-97)

SECTION IV. ACID RAIN PART.

C.D. McIntosh, Jr. Power Plant
Plant Name (from Step 1)

NOX Compliance – Page 2
Page 2 of 2

Step 2, cont'd

	ID# / Type	ID# / Type	ID# / Type	ID# / Type	ID# / Type	ID# / Type
(m) EPA-approved common stack apportionment method pursuant to 40 CFR 75.17 (a)(2)(i)(C), (a)(2)(ii)(B), or (b)(2)						
(n) AEL (include Phase II AEL Demonstration Period, Final AEL Petition, or AEL Renewal form as appropriate)	☐	☐	☐	☐	☐	☐
(o) Petition for AEL demonstration period or final AEL under review by U.S. EPA or demonstration period ongoing	☐	☐	☐	☐	☐	☐
(p) Repowering extension plan approved or under review	☐	☐	☐	☐	☐	☐

Step 3
Read the standard requirements and certification, enter the name of the designated representative, sign &

Standard Requirements

General. This source is subject to the standard requirement in 40 CFR 72.9 (consistent with 40 CFR 76.8(e)(1)(i)). These requirements are listed in this source's Acid Rain Permit.

Special Provisions for Early Election Units

Nitrogen Oxides. A unit that is governed by approved early election plan shall be subject to an emissions limitation for NO_x as provided under 40 CFR 76.8(a)(2) except as provided under 40 CFR 76.8(e)(3)(ii).
Liability. The owners and operators of a unit governed by an approved early election plan shall be liable for any violation of the plan or 40 CFR 76.8 at that unit. The owners and operators shall be liable, beginning January 1,200, for fulfilling the obligations specified in 40 CFR part 77.
Termination. An approved early election plan shall be in effect only until the earlier of January 1, 2008 or january1 of the calendar year for which a termination of the plan takes effect. If the designated representative of the unit under an approved early election plan fails to demonstrate compliance with the applicable emissions limitation under 40 CFR 76.5 for any year during the period beginning January 1 of the first year the early election takes effect and ending December 31, 2007, the permitting authority will terminate the plan. The termination will take effect beginning January 1 of the year for which there is a failure to demonstrate compliance, and the designated representative may no submit a new early election plan. The designated representative of the unit under an approved early election plan may terminate the plan any year prior to 2008 but may not submit a new early election plan. In order to terminate the plan, the designated representive must submit a notice under 40 CFR 72.40(d) by January 1 of the year for which the termination is to take effect. If an early election plan is terminated any year prior to 2000, the unit shall meet, beginning January 1, 2000, the applicable emissions limitation for NO_x for phase II units with Group 1boilers under 40 CFR 76.7 If an early election plan is terminated on or after 2000,the unit shall meet, beginning on the effective date of the termination, the applicable emissions limitation for NO_x for Phase II units with Group 1 boilers under 40 CFR 76.7.

Certification

I am authorized to make this submission on behalf of the owners and operators of the affected source or affected units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Subject: C.D. McIntosh, Jr. Power Plant Renewal Phase II NOx Compliance Plan Form

Name Timothy Bachand, P. E.
Signature [signature] Date 6/14/08

EPA Form 7610-28 (3-97)

Clean Air Interstate Rule (CAIR).

Operated by: City of Lakeland, Department of Electric Utilities
Plant: C. D. McIntosh, Jr. Power Plant
ORIS Code: 0676

The emissions units below are regulated under the Clean Air Interstate Rule.

EU No.	EPA Unit ID#	Brief Description
-001	01	Boiler - McIntosh Unit 1
-005	02	Boiler - McIntosh Unit 2
-006	03	Boiler - McIntosh Unit 3
-028		McIntosh Unit 5 – 370 MW Combined Cycle Stationary Combustion Turbine

1. Clean Air Interstate Rule Application. The Clean Air Interstate Rule Part Form submitted for this facility is a part of this permit. The owners and operators of these CAIR units as identified in this form must comply with the standard requirements and special provisions set forth in the CAIR Part Form (DEP Form No. 62-210.900(1)(b)) dated March 16, 2008, which is attached at the end of this section. [Chapter 62-213, F.A.C. and Rule 62-210.200, F.A.C.]

Clean Air Interstate Rule (CAIR) Part

For more information, see instructions and refer to 40 CFR 96.121, 96.122, 96.221, 96.222, 96.321 and 96.322; and Rule 62-296.470, F.A.C.

This submission is: ☐ New ☐ Revised ■ Renewal

STEP 1

Identify the source by plant name and ORIS or EIA plant code

Plant Name:	State: Florida	ORIS or EIA Plant Code:
C.D. McIntosh, Jr. Power Plant		0676

STEP 2

In column "a" enter the unit ID# for every CAIR unit at the CAIR source.

In columns "b," "c," and "d," indicate to which CAIR program(s) each unit is subject by placing an "X" in the column(s).

For new units, enter the requested information in columns "e" and "f.

a	b	c	d	e	f
Unit ID#	Unit will hold nitrogen oxides (NO_X) allowances in accordance with 40 CFR 96.106(c)(1)	Unit will hold sulfur dioxide (SO_2) allowances in accordance with 40 CFR 96.206(c)(1)	Unit will hold NO_X Ozone Season allowances in accordance with 40 CFR 96.306(c)(1)	New Units Expected Commence Commercial Operation Date	New Units Expected Monitor Certification Deadline
EU 001	x	x	x	N/A	N/A
EU 005	x	x	x	N/A	N/A
EU 006	x	x	x	N/A	N/A
EU 028	x	x	x	N/A	N/A

DEP Form No. 62-210.900(1)(b) – Form
Effective: 3/16/08

1

C.D. McIntosh, Jr. Power Plant

Plant Name (from STEP 1)

STEP 3

Read the standard requirements.

CAIR NO_X ANNUAL TRADING PROGRAM

CAIR Part Requirements.

(1) The CAIR designated representative of each CAIR NO_X source and each CAIR NO_X unit at the source shall:
(i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.122 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
(ii) [Reserved];
(2) The owners and operators of each CAIR NO_X source and each CAIR NO_X unit at the source shall have a CAIR Part included in the Title V operating permit issued by the DEP under 40 CFR Part 96, Subpart CC, and operate the source and the unit in compliance with such CAIR Part.

Monitoring, Reporting, and Recordkeeping Requirements.

(1) The owners and operators, and the CAIR designated representative, of each CAIR NO_X source and each CAIR NO_X unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96, Subpart HH, and Rule 62-296.470, F.A.C.
(2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HH, shall be used to determine compliance by each CAIR NO_X source with the following CAIR NO_X Emissions Requirements.

NO_X Emission Requirements.

(1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO_X source and each CAIR NO_X unit at the source shall hold, in the source's compliance account, CAIR NO_X allowances available for compliance deductions for the control period under 40 CFR 96.154(a) in an amount not less than the tons of total NO_X emissions for the control period from all CAIR NO_X units at the source, as determined in accordance with 40 CFR Part 96, Subpart HH.
(2) A CAIR NO_X unit shall be subject to the requirements under paragraph (1) of the NO_X Requirements starting on the later of January 1, 2009, or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.170(b)(1) or (2) and for each control period thereafter.
(3) A CAIR NO_X allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the NO_X Requirements, for a control period in a calendar year before the year for which the CAIR NO_X allowance was allocated.
(4) CAIR NO_X allowances shall be held in, deducted from, or transferred into or among CAIR NO_X Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FF and GG.
(5) A CAIR NO_X allowance is a limited authorization to emit one ton of NO_X in accordance with the CAIR NO_X Annual Trading Program. No provision of the CAIR NO_X Annual Trading Program, the CAIR Part, or an exemption under 40 CFR 96.105 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
(6) A CAIR NO_X allowance does not constitute a property right.
(7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart EE, FF, or GG, every allocation, transfer, or deduction of a CAIR NO_X allowance to or from a CAIR NO_X unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR NO_X unit.

Excess Emissions Requirements.

If a CAIR NO_X source emits NO_X during any control period in excess of the CAIR NO_X emissions limitation, then:
(1) The owners and operators of the source and each CAIR NO_X unit at the source shall surrender the CAIR NO_X allowances required for deduction under 40 CFR 96.154(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and
(2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AA, the Clean Air Act, and applicable state law.

Recordkeeping and Reporting Requirements.

(1) Unless otherwise provided, the owners and operators of the CAIR NO_X source and each CAIR NO_X unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the DEP or the Administrator.
(i) The certificate of representation under 40 CFR 96.113 for the CAIR designated representative for the source and each CAIR NO_X unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 96.113 changing the CAIR designated representative.
(ii) All emissions monitoring information, in accordance with 40 CFR Part 96, Subpart HH, of this part, provided that to the extent that 40 CFR Part 96, Subpart HH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.
(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO_X Annual Trading Program.
(iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR NO_X Annual Trading Program or to demonstrate compliance with the requirements of the CAIR NO_X Annual Trading Program.
(2) The CAIR designated representative of a CAIR NO_X source and each CAIR NO_X unit at the source shall submit the reports required under the CAIR NO_X Annual Trading Program, including those under 40 CFR Part 96, Subpart HH.

DEP Form No. 62-210.900(1)(b) – Form
Effective: 3/16/08

2

C.D. McIntosh Jr. Power Plant
Plant Name (from STEP 1)

STEP 3, Continued

Liability.

(1) Each CAIR NO_X source and each CAIR NO_X unit shall meet the requirements of the CAIR NO_X Annual Trading Program.
(2) Any provision of the CAIR NO_X Annual Trading Program that applies to a CAIR NO_X source or the CAIR designated representative of a CAIR NO_X source shall also apply to the owners and operators of such source and of the CAIR NO_X units at the source.
(3) Any provision of the CAIR NO_X Annual Trading Program that applies to a CAIR NO_X unit or the CAIR designated representative of a CAIR NO_X unit shall also apply to the owners and operators of such unit.

Effect on Other Authorities.

No provision of the CAIR NO_X Annual Trading Program, a CAIR Part, or an exemption under 40 CFR 96.105 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO_X source or CAIR NO_X unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

CAIR SO_2 TRADING PROGRAM

CAIR Part Requirements.

(1) The CAIR designated representative of each CAIR SO_2 source and each CAIR SO_2 unit at the source shall:
(i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.222 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
(ii) [Reserved];
(2) The owners and operators of each CAIR SO_2 source and each CAIR SO_2 unit at the source shall have a CAIR Part included in the Title V operating permit issued by the DEP under 40 CFR Part 96, Subpart CCC, for the source and operate the source and each CAIR unit in compliance with such CAIR Part.

Monitoring, Reporting, and Recordkeeping Requirements.

(1) The owners and operators, and the CAIR designated representative, of each CAIR SO_2 source and each SO_2 CAIR unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96 ,Subpart HHH, and Rule 62-296.470, F.A.C.
(2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HHH, shall be used to determine compliance by each CAIR SO_2 source with the following CAIR SO_2 Emission Requirements.

SO_2 Emission Requirements.

(1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR SO_2 source and each CAIR SO_2 unit at the source shall hold, in the source's compliance account, a tonnage equivalent in CAIR SO_2 allowances available for compliance deductions for the control period, as determined in accordance with 40 CFR 96.254(a) and (b), not less than the tons of total sulfur dioxide emissions for the control period from all CAIR SO_2 units at the source, as determined in accordance with 40 CFR Part 96, Subpart HHH.
(2) A CAIR SO_2 unit shall be subject to the requirements under paragraph (1) of the Sulfur Dioxide Emission Requirements starting on the later of January 1, 2010 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.270(b)(1) or (2) and for each control period thereafter.
(3) A CAIR SO_2 allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the SO_2 Emission Requirements, for a control period in a calendar year before the year for which the CAIR SO_2 allowance was allocated.
(4) CAIR SO_2 allowances shall be held in, deducted from, or transferred into or among CAIR SO_2 Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FFF and GGG.
(5) A CAIR SO_2 allowance is a limited authorization to emit sulfur dioxide in accordance with the CAIR SO_2 Trading Program. No provision of the CAIR SO_2 Trading Program, the CAIR Part, or an exemption under 40 CFR 96.205 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
(6) A CAIR SO_2 allowance does not constitute a property right.
(7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart FFF or GGG, every allocation, transfer, or deduction of a CAIR SO_2 allowance to or from a CAIR SO_2 unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR SO_2 unit.

Excess Emissions Requirements.

If a CAIR SO_2 source emits SO_2 during any control period in excess of the CAIR SO_2 emissions limitation, then:
(1) The owners and operators of the source and each CAIR SO_2 unit at the source shall surrender the CAIR SO_2 allowances required for deduction under 40 CFR 96.254(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law, and
(2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AAA, the Clean Air Act, and applicable state law.

DEP Form No. 62-210.900(1)(b) – Form
Effective: 3/16/08

3

C.D. McIntosh Jr. Power Plant
Plant Name (from STEP 1)

STEP 3, Continued

Recordkeeping and Reporting Requirements.

(1) Unless otherwise provided, the owners and operators of the CAIR SO_2 source and each CAIR SO_2 unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Department or the Administrator.

(i) The certificate of representation under 40 CFR 96.213 for the CAIR designated representative for the source and each CAIR SO_2 unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 96.213 changing the CAIR designated representative.

(ii) All emissions monitoring information, in accordance with 40 CFR Part 96, Subpart HHH, of this part, provided that to the extent that 40 CFR Part 96, Subpart HHH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR SO_2 Trading Program.

(iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR SO_2 Trading Program or to demonstrate compliance with the requirements of the CAIR SO_2 Trading Program.

(2) The CAIR designated representative of a CAIR SO_2 source and each CAIR SO_2 unit at the source shall submit the reports required under the CAIR SO_2 Trading Program, including those under 40 CFR Part 96, Subpart HHH.

Liability.

(1) Each CAIR SO_2 source and each CAIR SO_2 unit shall meet the requirements of the CAIR SO_2 Trading Program.
(2) Any provision of the CAIR SO_2 Trading Program that applies to a CAIR SO_2 source or the CAIR designated representative of a CAIR SO_2 source shall also apply to the owners and operators of such source and of the CAIR SO_2 units at the source.
(3) Any provision of the CAIR SO_2 Trading Program that applies to a CAIR SO_2 unit or the CAIR designated representative of a CAIR SO_2 unit shall also apply to the owners and operators of such unit.

Effect on Other Authorities.

No provision of the CAIR SO_2 Trading Program, a CAIR Part, or an exemption under 40 CFR 96.205 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR SO_2 source or CAIR SO_2 unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

CAIR NO_x OZONE SEASON TRADING PROGRAM

CAIR Part Requirements.

(1) The CAIR designated representative of each CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit at the source shall:
(i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.322 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
(ii) [Reserved];
(2) The owners and operators of each CAIR NO_x Ozone Season source required to have a Title V operating permit or air construction permit, and each CAIR NO_x Ozone Season unit required to have a Title V operating permit or air construction permit at the source shall have a CAIR Part included in the Title V operating permit or air construction permit issued by the DEP under 40 CFR Part 96, Subpart CCCC, for the source and operate the source and the unit in compliance with such CAIR Part.

Monitoring, Reporting, and Recordkeeping Requirements.

(1) The owners and operators, and the CAIR designated representative, of each CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96, Subpart HHHH, and Rule 62-296.470, F.A.C.
(2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HHHH, shall be used to determine compliance by each CAIR NO_x Ozone Season source with the following CAIR NO_x Ozone Season Emissions Requirements.

NO_x Ozone Season Emission Requirements.

(1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit at the source shall hold, in the source's compliance account, CAIR NO_x Ozone Season allowances available for compliance deductions for the control period under 40 CFR 96.354(a) in an amount not less than the tons of total NO_x emissions for the control period from all CAIR NO_x Ozone Season units at the source, as determined in accordance with 40 CFR Part 96, Subpart HHHH.
(2) A CAIR NO_x Ozone Season unit shall be subject to the requirements under paragraph (1) of the NO, Ozone Season Emission Requirements starting on the later of May 1, 2009 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.370(b)(1),(2), or (3) and for each control period thereafter.
(3) A CAIR NO_x Ozone Season allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the NO_x Ozone Season Emission Requirements, for a control period in a calendar year before the year for which the CAIR NO_x Ozone Season allowance was allocated.
(4) CAIR NO_x Ozone Season allowances shall be held in, deducted from, or transferred into or among CAIR NO_x Ozone Season Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FFFF and GGGG.
(5) A CAIR NO_x Ozone Season allowance is a limited authorization to emit one ton of NO_x in accordance with the CAIR NO_x Ozone Season Trading Program. No provision of the CAIR NO_x Ozone Season Trading Program, the CAIR Part, or an exemption under 40 CFR 96.305 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
(6) A CAIR NO_x Ozone Season allowance does not constitute a property right.

DEP Form No. 62-210.900(1)(b) – Form
Effective: 3/16/08

4

(7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart EEEE, FFFF or GGGG, every allocation, transfer, or deduction of a CAIR NO_X Ozone Season allowance to or from a CAIR NO_X Ozone Season unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR NO_X Ozone Season unit.

C.D. McIntosh Jr. Power Plant Plant Name (from STEP 1)

STEP 3, Continued

Excess Emissions Requirements.

If a CAIR NO_X Ozone Season source emits NO_X during any control period in excess of the CAIR NO_X Ozone Season emissions limitation, then:
(1) The owners and operators of the source and each CAIR NO_X Ozone Season unit at the source shall surrender the CAIR NO_X Ozone Season allowances required for deduction under 40 CFR 96.354(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and
(2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AAAA, the Clean Air Act, and applicable state law.

Recordkeeping and Reporting Requirements.

(1) Unless otherwise provided, the owners and operators of the CAIR NO_X Ozone Season source and each CAIR NO_X Ozone Season unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the DEP or the Administrator.
(i) The certificate of representation under 40 CFR 96.313 for the CAIR designated representative for the source and each CAIR NO_X Ozone Season unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 96.113 changing the CAIR designated representative.
(ii) All emissions monitoring information, in accordance with 40 CFR Part 96, Subpart HHHH, of this part, provided that to the extent that 40 CFR Part 96, Subpart HHHH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.
(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO_X Ozone Season Trading Program.
(iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR NO_X Ozone Season Trading Program or to demonstrate compliance with the requirements of the CAIR NO_X Ozone Season Trading Program.
(2) The CAIR designated representative of a CAIR NO_X Ozone Season source and each CAIR NO_X Ozone Season unit at the source shall submit the reports required under the CAIR NO_X Ozone Season Trading Program, including those under 40 CFR Part 96, Subpart HHHH.

Liability.

(1) Each CAIR NO_X Ozone Season source and each CAIR NO_X Ozone Season unit shall meet the requirements of the CAIR NO_X Ozone Season Trading Program.
(2) Any provision of the CAIR NO_X Ozone Season Trading Program that applies to a CAIR NO_X Ozone Season source or the CAIR designated representative of a CAIR NO_X Ozone Season source shall also apply to the owners and operators of such source and of the CAIR NO_X Ozone Season units at the source.
(3) Any provision of the CAIR NO_X Ozone Season Trading Program that applies to a CAIR NO_X Ozone Season unit or the CAIR designated representative of a CAIR NO_X Ozone Season unit shall also apply to the owners and operators of such unit.

Effect on Other Authorities.

No provision of the CAIR NO_X Ozone Season Trading Program, a CAIR Part, or an exemption under 40 CFR 96.305 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO_X Ozone Season source or CAIR NO_X Ozone Season unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

STEP 4

Read the certification statement; provide name, title, owner company name, phone, and e-mail address; sign, and date.

Certification (for designated representative or alternate designated representative only)

I am authorized to make this submission on behalf of the owners and operators of the CAIR source or CAIR units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name Mr. Tony Candales	Title Assistant General Manager of Production
Company Owner Name Lakeland Electric	
Phone (863) 834-6559	E-mail Address tony.candales@lakelandelectric.com
Signature	Date 5/15/13

DEP Form No. 62-210.900(1)(b) – Form
Effective: 3/16/08

5

SECTION VI. APPENDICES.

The Following Appendices Are Enforceable Parts of This Permit:

Appendix A, Glossary.
Appendix ASP, ASP Number 97-B-01 (With Scrivener's Order Dated July 9, 1997).
Appendix CAM, Compliance Assurance Monitoring Plan.
Appendix CP, Compliance Plan.
Appendix I, List of Insignificant Emissions Units and/or Activities.
Appendix NSPS, Subpart A – General Provisions.
Appendix NSPS, Subpart D - Standards Of Performance For Fossil-Fuel Fired Steam Generators For Which Construction Is Commenced After August 17, 1971 (version dated 02/16/2012).
Appendix NSPS, Subpart GG - Standards of Performance For Stationary Gas Turbines (version dated 7/8/2004).
Appendix NESHAP, Subpart A – General Provisions.
Appendix NESHAP, Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.
Appendix NESHAP, Subpart UUUUU - National Emission Standards for Hazardous Air Pollutants: Coal- and Oil-Fired Electric Utility Steam Generating Units.
Appendix RR, Facility-wide Reporting Requirements.
Appendix TR, Facility-wide Testing Requirements.
Appendix TV, Title V General Conditions.
Appendix U, List of Unregulated Emissions Units and/or Activities.
Appendix W501G McIntosh #5