STANDARDS OF PERFORMANCE FOR STATIONARY COMPRESSION IGNITION INTERNAL COMBUSTION ENGINES 40 CFR 60 SUBPART IIII
(Mosaic Fertilizer LLC - South Pierce Facility, Facility ID: 1050055)

Reciprocating Internal Combustion Engine (RICE) Information										40 CFR 60 Subpart IIII Applicable Requirements				
Engine Description / Location	**Owned or Rented?**	**Engine Serial Number**	**Engine Manufacturer**	**Model Number**	**Date of Construction / Reconstruction**	**Power (bhp)**	**Fuel**	**CI or SI**	**Indicate if Emergency or Limited Use***	**Emission Standards** (from 60.4205(a) Table 1)	**Fuel Requirements** 60.4207(b)	**Compliance Requirements** (60.4211(b))	**Testing Requirements** (from 63.4212)	**Notification, Reports and Records** (60.4214)
Building 2 Generator	Owned	--	Caterpillar	--	After June 12, 2006; New RICE; pre-2007	230, < 10 liters/cylinder	diesel	CI	Emergency	6.9 g/HP-hr NOx	Meet 40 CFR 80.510(b)	Demonstrate compliance by one of 60.4211(b) (1) thru (5)	Test per 60.4212	60.4214(b) No initial notification Per Table 5, keep records of emergency and non emergency via non resettable hour meter
Primary Pond	Rental	--	Deutz	FAL913	Circa 2007	75, < 10 liters/cylinder	diesel	CI	Non-Emergency	§60.4201 per §60.4204(b)	Ultra low sulfur diesel (ULSD) fuel per manufacturer's specifications	Manufacturer's certification, Tier 4 Interim/Stage IIIB	Test per 60.4212	60.4214(a) Certfified, no initial notification. Keep records of corrective action for backpressure limit (60.4214(c)
Inside Plant	Rental	--	John Deere	6090HF485B	Circa 2010	400, < 10 liters/cylinder	diesel	CI	Non-Emergency	§60.4201 per §60.4204(b)	Ultra low sulfur diesel (ULSD) fuel per manufacturer's specifications	Manufacturer's certification, Tier 4 Interim/Stage IIIB	Test per 60.4212	60.4214(a) Certfified, no initial notification. Keep records of corrective action for backpressure limit (60.4214(c)