

## EU 015 No. 5 Power Boiler - Boiler MACT Rule Applicability

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	63 Subpart DDDDD	40CFR63.7480-7575	Subpart DDDDD—National Emission Standards for Hazardous Air Pollutants for Major Sources: Industrial, Commercial, and Institutional Boilers and Process Heaters	
APPLICABLE	63 Subpart DDDDD	40CFR63.7480	What is the purpose of this Subpart?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7485	Am I subject to this subpart?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7490	What is the affected source of this subpart?	
NOT-APPLICABLE	63 Subpart DDDDD	40CFR63.7491	Are any boilers or process heaters not subject to this subpart?	Unit is not among the list of boilers not regulated by this subpart
APPLICABLE	63 Subpart DDDDD	40CFR63.7495	When do I have to comply with this subpart?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7499	What are the subcategories of boilers and process heaters?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7500	What emission limitations, work practice standards, and operating limits must I meet?	
NON-APPLICABLE	63 Subpart DDDDD	40CFR63.7501	How can I assert an affirmative defense if I exceed an emission limitations during a malfunction?	Unit is not subject to any emission limitations
NON-APPLICABLE	63 Subpart DDDDD	40CFR63.7505	What are my general requirements for complying with this subpart?	Unit is not subject to any emissions limits or operating limits
NON-APPLICABLE	63 Subpart DDDDD	40CFR63.7510	What are my initial compliance requirements and by what date must I conduct them?	This subpart does not apply to boilers that burn 100% Gas 1 fuel
APPLICABLE	63 Subpart DDDDD	40CFR63.7515	When must I conduct subsequent performance tests, fuel analyses, or tune-ups?	
NON-APPLICABLE	63 Subpart DDDDD	40CFR63.7520	What stack tests and procedures must I use?	This subpart does not apply to boilers that burn 100% Gas 1 fuel
NON-APPLICABLE	63 Subpart DDDDD	40CFR63.7521	What fuel analyses, fuel specification, and procedures must I use?	This subpart does not apply to boilers that burn 100% Gas 1 fuel
NON-APPLICABLE	63 Subpart DDDDD	40CFR63.7522	Can I use emissions averaging to comply with this subpart?	This subpart does not apply to boilers that burn 100% Gas 1 fuel

<b>NON-APPLICABLE</b>	<b>63 Subpart DDDDD</b>	<b>40CFR63.7525</b>	<b>What are my monitoring, installation, operation, and maintenance requirements?</b>	<b>This subpart does not apply to boilers that burn 100% Gas 1 fuel</b>
<b>APPLICABLE</b>	<b>63 Subpart DDDDD</b>	<b>40CFR63.7530</b>	<b>How do I demonstrate initial compliance with the emission limitations, fuel specifications and work practice standards?</b>	
<b>NON-APPLICABLE</b>	<b>63 Subpart DDDDD</b>	<b>40CFR63.7533</b>	<b>Can I use emission credits earned from implementation of energy conservation measures to comply with this subpart?</b>	<b>This subpart does not apply to boilers that burn 100% Gas 1 fuel</b>
<b>NON-APPLICABLE</b>	<b>63 Subpart DDDDD</b>	<b>40CFR63.7535</b>	<b>How do I monitor and collect data to demonstrate continuous compliance?</b>	<b>This subpart does not apply to boilers that burn 100% Gas 1 fuel</b>
<b>APPLICABLE</b>	<b>63 Subpart DDDDD</b>	<b>40CFR63.7540</b>	<b>How do I demonstrate continuous compliance with the emission limitations, fuel specifications and work practice standards?</b>	
<b>NON-APPLICABLE</b>	<b>63 Subpart DDDDD</b>	<b>40CFR63.7541</b>	<b>How do I demonstrate continuous compliance under the emissions averaging provision?</b>	<b>This subpart does not apply to boilers that burn 100% Gas 1 fuel</b>
<b>APPLICABLE</b>	<b>63 Subpart DDDDD</b>	<b>40CFR63.7545</b>	<b>What notifications must I submit and when?</b>	
<b>APPLICABLE</b>	<b>63 Subpart DDDDD</b>	<b>40CFR63.7550</b>	<b>What reports must I submit and when?</b>	
<b>APPLICABLE</b>	<b>63 Subpart DDDDD</b>	<b>40CFR63.7555</b>	<b>What records must I keep?</b>	
<b>APPLICABLE</b>	<b>63 Subpart DDDDD</b>	<b>40CFR63.7560</b>	<b>In what form and how long must I keep my records?</b>	
<b>APPLICABLE</b>	<b>63 Subpart DDDDD</b>	<b>40CFR63.7565</b>	<b>What parts of the General Provisions apply to me?</b>	
<b>APPLICABLE</b>	<b>63 Subpart DDDDD</b>	<b>40CFR63.7570</b>	<b>Who implements and enforces this subpart?</b>	
<b>APPLICABLE</b>	<b>63 Subpart DDDDD</b>	<b>40CFR63.7575</b>	<b>What definitions apply to this subpart?</b>	

## EU 016 No. 4 Combination Boiler - Boiler MACT Rule Applicability

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	63 Subpart DDDDD	40CFR63.7480-7575	Subpart DDDDD—National Emission Standards for Hazardous Air Pollutants for Major Sources: Industrial, Commercial, and Institutional Boilers and Process Heaters	
APPLICABLE	63 Subpart DDDDD	40CFR63.7480	What is the purpose of this Subpart?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7485	Am I subject to this subpart?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7490	What is the affected source of this subpart?	
NON-APPLICABLE	63 Subpart DDDDD	40CFR63.7491	Are any boilers or process heaters not subject to this subpart?	Unit is not among the list of boilers not regulated by this subpart
APPLICABLE	63 Subpart DDDDD	40CFR63.7495	When do I have to comply with this subpart?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7499	What are the subcategories of boilers and process heaters?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7500	What emission limitations, work practice standards, and operating limits must I meet?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7501	How can I assert an affirmative defense if I exceed an emission limitations during a malfunction?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7505	What are my general requirements for complying with this subpart?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7510	What are my initial compliance requirements and by what date must I conduct them?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7515	When must I conduct subsequent performance tests, fuel analyses, or tune-ups?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7520	What stack tests and procedures must I use?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7521	What fuel analyses, fuel specification, and procedures must I use?	
NON-APPLICABLE	63 Subpart DDDDD	40CFR63.7522	Can I use emissions averaging to comply with this subpart?	There are no other boilers within the same subcategory with which to average.
APPLICABLE	63 Subpart DDDDD	40CFR63.7525	What are my monitoring, installation, operation, and maintenance requirements?	
APPLICABLE	63 Subpart	40CFR63.7530	How do I demonstrate initial compliance with	

<b>APPLICABLE STATUTE</b>	<b>RULE DESCRIPTION</b>	<b>RULE NUMBER</b>	<b>RULE TITLE</b>	<b>RATIONALE FOR NON-APPLICABILITY</b>
	DDDDD		the emission limitations, fuel specifications and work practice standards?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7533	Can I use emission credits earned from implementation of energy conservation measures to comply with this subpart?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7535	How do I monitor and collect data to demonstrate continuous compliance?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7540	How do I demonstrate continuous compliance with the emission limitations, fuel specifications and work practice standards?	
NON-APPLICABLE	63 Subpart DDDDD	40CFR63.7541	How do I demonstrate continuous compliance under the emissions averaging provision?	There are no other boilers within the same sub-category with which to average.
APPLICABLE	63 Subpart DDDDD	40CFR63.7545	What notifications must I submit and when?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7550	What reports must I submit and when?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7555	What records must I keep?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7560	In what form and how long must I keep my records?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7565	What parts of the General Provisions apply to me?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7570	Who implements and enforces this subpart?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7575	What definitions apply to this subpart?	

## EU 044 No. 7 Package Boiler - Boiler MACT Rule Applicability

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	63 Subpart DDDDD	40CFR63.7480-7575	Subpart DDDDD—National Emission Standards for Hazardous Air Pollutants for Major Sources: Industrial, Commercial, and Institutional Boilers and Process Heaters	
APPLICABLE	63 Subpart DDDDD	40CFR63.7480	What is the purpose of this Subpart?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7485	Am I subject to this subpart?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7490	What is the affected source of this subpart?	
NON-APPLICABLE	63 Subpart DDDDD	40CFR63.7491	Are any boilers or process heaters not subject to this subpart?	Unit is not among the list of boilers not regulated by this subpart
APPLICABLE	63 Subpart DDDDD	40CFR63.7495	When do I have to comply with this subpart?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7499	What are the subcategories of boilers and process heaters?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7500	What emission limitations, work practice standards, and operating limits must I meet?	
NON-APPLICABLE	63 Subpart DDDDD	40CFR63.7501	How can I assert an affirmative defense if I exceed an emission limitations during a malfunction?	Unit is not subject to any emission limitations
NON-APPLICABLE	63 Subpart DDDDD	40CFR63.7505	What are my general requirements for complying with this subpart?	Unit is not subject to any emissions limits or operating limits
NON-APPLICABLE	63 Subpart DDDDD	40CFR63.7510	What are my initial compliance requirements and by what date must I conduct them?	This subpart does not apply to boilers that burn 100% Gas 1 fuel
APPLICABLE	63 Subpart DDDDD	40CFR63.7515	When must I conduct subsequent performance tests, fuel analyses, or tune-ups?	
NON-APPLICABLE	63 Subpart DDDDD	40CFR63.7520	What stack tests and procedures must I use?	This subpart does not apply to boilers that burn 100% Gas 1 fuel
NON-APPLICABLE	63 Subpart	40CFR63.7521	What fuel analyses, fuel	This subpart does not apply to boilers that

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
	DDDDD		specification, and procedures must I use?	burn 100% Gas 1 fuel
NON-APPLICABLE	63 Subpart DDDDD	40CFR63.7522	Can I use emissions averaging to comply with this subpart?	This subpart does not apply to boilers that burn 100% Gas 1 fuel
NON-APPLICABLE	63 Subpart DDDDD	40CFR63.7525	What are my monitoring, installation, operation, and maintenance requirements?	This subpart does not apply to boilers that burn 100% Gas 1 fuel
APPLICABLE	63 Subpart DDDDD	40CFR63.7530	How do I demonstrate initial compliance with the emission limitations, fuel specifications and work practice standards?	
NON-APPLICABLE	63 Subpart DDDDD	40CFR63.7533	Can I use emission credits earned from implementation of energy conservation measures to comply with this subpart?	This subpart does not apply to boilers that burn 100% Gas 1 fuel
NON-APPLICABLE	63 Subpart DDDDD	40CFR63.7535	How do I monitor and collect data to demonstrate continuous compliance?	This subpart does not apply to boilers that burn 100% Gas 1 fuel
APPLICABLE	63 Subpart DDDDD	40CFR63.7540	How do I demonstrate continuous compliance with the emission limitations, fuel specifications and work practice standards?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7541	How do I demonstrate continuous compliance under the emissions averaging provision?	This subpart does not apply to boilers that burn 100% Gas 1 fuel
APPLICABLE	63 Subpart DDDDD	40CFR63.7545	What notifications must I submit and when?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7550	What reports must I submit and when?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7555	What records must I keep?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7560	In what form and how long must I keep my records?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7565	What parts of the General Provisions apply to me?	
APPLICABLE	63 Subpart DDDDD	40CFR63.7570	Who implements and enforces this subpart?	
APPLICABLE	63 Subpart	40CFR63.7575	What definitions apply to this	

3/14/2012

---

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
	DDDD		subpart?	