EU 015 No. 5 Power Boiler Rule Applicability

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
NON-APPLICABLE	60 Subpart A	40CFR60.1	Subpart A -- General Provisions	The No. 5 Power Boiler is not subject to NSPS; the boiler was built prior to the applicability date of all potentially applicable NSPS, and has not been modified or reconstructed as defined in 40 CFR 60.
NON-APPLICABLE	60 Subpart D	40CFR60.40	Subpart D -- Fossil Fuel Steam Generators - Applicability and designation of affected facility	No. 5 Power Boiler is not subject to NSPS; the boiler was built prior to the applicability date of Aug.17, 1971, and has not been modified or reconstructed as defined in 40 CFR 60.
NON-APPLICABLE	60 Subpart Db	40CFR60.40b	Subpart Db -- Industrial - Commercial - Institutional Steam Generating Units - Applicability	No. 5 Power Boiler is not subject to NSPS; the boiler was built prior to the applicability date of June 19, 1984, and has not been modified or reconstructed as defined in 40 CFR 60.
NON-APPLICABLE	60 Subpart Dc	40CFR60.40c	Subpart Dc -- Small Industrial - Commercial - Institutional Steam Generating Units -- Applicability	No. 5 Power Boiler is not subject to NSPS; the boiler was built prior to the applicability date of June 9, 1989, and has not been modified or reconstructed as defined in 40 CFR 60, and has a maximum heat input of greater than 100 MMBtu/hr.
APPLICABLE	62-210	62-210.700(2)	Excess Emissions.	
APPLICABLE	62-210	62-210.700(3)	Excess Emissions.	
APPLICABLE	62-296 <	62-296.405		
APPLICABLE	62-296 <	62-296.405(1)	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	Existing Emissions Units.
APPLICABLE	62-296 <	62-296.405(1)(a)	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	Visible emissions 20 percent opacity except for either one six-minute period per hour during which opacity shall not exceed 27 percent, or one two-minute period per hour during which opacity shall not exceed 40 percent.
APPLICABLE	62-296 <	62-296.405(1)(b)	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	Particulate Matter – 0.1 pound per million Btu heat input, as measured by applicable compliance methods
NON-APPLICABLE	62-296 <	62-296.405(1)(c)	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	Unit does not burn liquid or solid fuels.
NON-APPLICABLE	62-296 <	62-296.405(1)(	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing	Applies to Duval County.

		c)1.a	Emissions Units.	
NON-APPLICABLE	62-296 <	62-296.405(1)(c)1.b	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	Applies to Duval County.
NON-APPLICABLE	62-296 <	62-296.405(1)(c)1.c	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	Applies to Duval County.
NON-APPLICABLE	62-296 <	62-296.405(1)(c)1.d	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	Applies to Hillsborough County.
NON-APPLICABLE	62-296 <	62-296.405(1)(c)1.e	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	Applies to Escambia County.
NON-APPLICABLE	62-296 <	62-296.405(1)(c)1.f	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	Applies to Escambia County.
NON-APPLICABLE	62-296 <	62-296.405(1)(c)1.g	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	Applies to Manatee County.
NON-APPLICABLE	62-296 <	62-296.405(1)(c)1.h	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	Applies to Leon and Wakula Counties.
NON-APPLICABLE	62-296 <	62-296.405(1)(c)1.i	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	Applies to Dade, Broward and Palm Beach Counties.
NON-APPLICABLE	62-296 <	62-296.405(1)(c)1.j	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	Applies to units burning solid fuel.
NON-APPLICABLE	62-296 <	62-296.405(1)(c)2	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	Applies to units burning solid fuel.
APPLICABLE	62-296 <	62-296.405(1)(c)3	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	
NON-APPLICABLE	62-296 <	62-296.405(1)(d)	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	Applies only to units located in Duval, Manatee, Leon and Hillsborough Counties.
APPLICABLE	62-296 <	62-296.405(1)(e)	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	

APPLICABLE	62-296 <	62-296.405(1)(e)1	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	Visible emissions test method
APPLICABLE	62-296 <	62-296.405(1)(e)2	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	PM test method
APPLICABLE	62-296 <	62-296.405(1)(e)3	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	NO_x test method
APPLICABLE	62-296 <	62-296.405(1)(e)4	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	SO_2 test method
APPLICABLE	62-296 <	62-296.405(1)(e)5	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	
NON-APPLICABLE	62-296 <	62-296.405(1)(f)1	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	Unit burns natural gas
NON-APPLICABLE	62-296 <	62-296.405(1)(f)1.a	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	Unit burns natural gas
NON-APPLICABLE	62-296 <	62-296.405(1)(f)1.b	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	Unit does not employ SO_2 controls
NON-APPLICABLE	62-296 <	62-296.405(1)(f)1.c	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	Unit is not larger than 1,000 MM Btu/hr
NON-APPLICABLE	62-296 <	62-296.405(1)(f)1.d	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	Unit is not required to operate any CEMs
APPLICABLE	62-296 <	62-296.405(1)(f)2	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	
APPLICABLE	62-296 <	62-296.405(1)(g)	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	
NON-APPLICABLE	62-296 <	62-296.405(2)	New Emissions Units.	Applies only to emissions units constructed after July 1974.
APPLICABLE	62-296 <	62-296.405(3)		

APPLICABLE	62-296 <	62-296.405.(1)(f)	Fossil Fuel Steam Generators with greater than 250 Million Btu per Hour Heat Input, Existing Emissions Units.	
NON-APPLICABLE	62-296 <	62-296.406	Fossil Fuel Steam Generators with less than 250 Million Btu per Hour Heat Input, New and Existing Emissions Units.	Applies only to units with a heat input of less than 250 MM Btu/hr.
NON-APPLICABLE	62-296 >	62-296.702	RACT for PM Emissions -- Fossil Fuel Steam Generators.	The Palatka Mill is not located in a PM air quality maintenance area or within the area of influence of such area.
APPLICABLE	62-297	62-297.310	General Compliance Test Requirements.	
APPLICABLE	62-297	62-297.401	Compliance Test Methods.	
APPLICABLE	62-297	62-297.401(1)(a)	EPA Method 1 - Sample and Velocity Traverses for Stationary sources - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(17)	EPA Method 17 - Determination of Particulate Emissions from Stationary Sources (In-Stack Filtration	
APPLICABLE	62-297	62-297.401(2)	EPA Method 2 - Determination of Stack Gas Velocity and Volumetric Flow Rate - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(3)	EPA Method 3 - Gas Analysis for Carbon Dioxide, Oxygen, Excess Air, and Dry Molecular Weight - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(4)	EPA Method 4 - Determination of Moisture Content in Stack Gases - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(5)	EPA Method 5 - Determination of Particulate Emissions from Stationary Sources - 40 CFR 60 Appendix A	
APPLICABLE	62-297	62-297.401(6)	EPA Method 6 - Determination of Sulfur Dioxide Emissions from Stationary Sources - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(9)(a)	EPA Method 9 - Visual Determination of the Opacity of Emissions from Stationary Sources - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(9)(c)		

EU 016 No. 4 Combination Boiler Rule Applicability

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
NON-APPLICABLE	60 Subpart A	40CFR60.1	Subpart A -- General Provisions	The No. 4 Combination Boiler is not subject to NSPS; the boiler was built prior to the applicability date of all potentially applicable NSPS, and has not been modified or reconstructed as defined in 40 CFR 60.
NON-APPLICABLE	60 Subpart BB	40CFR60.280	Subpart BB -- Kraft Pulp Mills -- Applicability and designation of affected facility.	This NSPS does not cover combination boilers or fossil fuel fired boilers.
NON-APPLICABLE	60 Subpart D	40CFR60.40	Subpart D -- Fossil Fuel Steam Generators - Applicability and designation of affected facility	No. 4 Combination Boiler is not subject to NSPS; the boiler was built prior to the applicability date of Aug.17, 1971, and has not been modified or reconstructed as defined in 40 CFR 60.
NON-APPLICABLE	60 Subpart Db	40CFR60.40b	Subpart Db -- Industrial - Commercial - Institutional Steam Generating Units - Applicability	No. 4 Combination Boiler is not subject to NSPS; the boiler was built prior to the applicability date of June 19, 1984, and has not been modified or reconstructed as defined in 40 CFR 60.
NON-APPLICABLE	60 Subpart Dc	40CFR60.40c	Subpart Dc -- Small Industrial - Commercial - Institutional Steam Generating Units -- Applicability	No. 4 Combination Boiler is not subject to NSPS; the boiler was built prior to the applicability date of June 9, 1989, and has not been modified or reconstructed as defined in 40 CFR 60, and has a maximum heat input of greater than 100 MMBtu/hr.
APPLICABLE	63 Subpart S	40 CFR 63.443(d)(4)	MACT Standards – HAP Reduction in a Boiler or Lime Kiln	
APPLICABLE	63 Subpart S	40 CFR 63.443(e)(1)	Periods of Excess Emissions	
APPLICABLE	63 Subpart A	40CFR63.1—63.16	Subpart A – General Provisions	
APPLICABLE	62-296 <	62-296.404	Kraft (Sulfate) Pulp Mills and Tall Oil Plants.	No. 4 Combination Boiler acts as backup to Thermal Oxidizer for TRS/HAP combustion.
APPLICABLE	62-296 <	62-296.404(3)(a)(1)	Kraft Pulp Mills	
APPLICABLE	62-296 <	62-296.404(3)(f)	Kraft Pulp Mills	
APPLICABLE	62-296 <	62-296.404(4)(e)	Kraft Pulp Mills	
NON-APPLICABLE	62-296 <	62-296.405	Fossil Fuel Steam Generators with more than 250 Million Btu per Hour Heat Input, New and Existing Emission Units.	The unit is classified as a carbonaceous fuel boiler and not a fossil fuel steam generator.
NON-APPLICABLE	62-296 <	62-296.406	Fossil Fuel Steam Generators with less than 250 Million Btu per Hour Heat Input, New and Existing Emission Units	The unit is classified as a carbonaceous fuel boiler and not a fossil fuel steam generator.

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	62-296 <	62-296.410	Carbonaceous Fuel Burning Equipment.	
APPLICABLE	62-296 <	62-296.410(1)	Carbonaceous Fuel Burning Equipment.	
NON-APPLICABLE	62-296 <	62-296.410(1)(a)	Carbonaceous Fuel Burning Equipment.	Applies only to boilers with less than 30 MMBtu/hr heat input.
APPLICABLE	62-296 <	62-296.410(1)(b)	Carbonaceous Fuel Burning Equipment.	
NON-APPLICABLE	62-296 <	62-296.410(2)	New Emissions Units.	Applies only to boilers constructed after July 1, 1974. The No. 4 Combination Boiler was constructed prior to July 1, 1974.
APPLICABLE	62-296 <	62-296.410(3)	Test Methods and Procedures.	
NON-APPLICABLE	62-296 >	62-296.703	Carbonaceous Fuel Burners.	The Palatka Mill is not located in a PM air quality maintenance area or within the area of influence of such area.
APPLICABLE	62-297	62-297.310	General Compliance Test Requirements.	
APPLICABLE	62-297	62-297.401	Compliance Test Methods.	
APPLICABLE	62-297	62-297.401(1)(a)	EPA Method 1 - Sample and Velocity Traverses for Stationary sources - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(2)	EPA Method 2 - Determination of Stack Gas Velocity and Volumetric Flow Rate - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(3)	EPA Method 3 - Gas Analysis for Carbon Dioxide, Oxygen, Excess Air, and Dry Molecular Weight - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(4)	EPA Method 4 - Determination of Moisture Content in Stack Gases - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(5)	EPA Method 5 - Determination of Particulate Emissions from Stationary Sources - 40 CFR 60 Appendix A	
APPLICABLE	62-297	62-297.401(6)	EPA Method 6 - Determination of Sulfur Dioxide Emissions from Stationary Sources - 40 CFR 60 Appendix A	
APPLICABLE	62-297	62-297.401(9)(a)	EPA Method 9 - Visual Determination of the Opacity of Emissions from Stationary Sources - 40 CFR 60 Appendix A	
APPLICABLE	62-297	62-297.440(1)(b)	ASTM Methods.	

EU 017 No. 4 Lime Kiln Rule Applicability

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
NON-APPLICABLE	60 Subpart A	40CFR60.1	Subpart A -- General Provisions	No. 4 Lime Kiln is not subject to NSPS; the kiln was built prior to the applicability date of all potentially applicable NSPS, and has not been modified or reconstructed as defined in 40 CFR 60.
NON-APPLICABLE	60 Subpart BB	40CFR60.280	Subpart BB -- Kraft Pulp Mills -- Applicability and designation of affected facility.	No. 4 Lime Kiln is not subject to NSPS; the boiler was built prior to the applicability date of Sep. 24, 1976, and has not been modified or reconstructed as defined in 40 CFR 60.
APPLICABLE	63 Subpart A		NESHAPs General Provisions	
APPLICABLE	63 Subpart MM	40 CFR 63.860	Subpart MM – NESHAPs for Kraft Pulp Mills	
APPLICABLE	63 Subpart MM	40 CFR 63.860(b)(1)	Subpart MM – NESHAPs for Kraft Pulp Mills	
APPLICABLE	63 Subpart MM	40 CFR 63.860(c)	Subpart MM – NESHAPs for Kraft Pulp Mills	
APPLICABLE	63 Subpart MM	40 CFR 63.861	Definitions	
APPLICABLE	63 Subpart MM	40 CFR 63.862	Standards	
APPLICABLE	63 Subpart MM	40 CFR 63.862(a)(1)(i)(C)	Standards for HAP Metals	
APPLICABLE	63 Subpart MM	40 CFR 63.863(a)(1)(ii)	Bubble for PM	
APPLICABLE	63 Subpart MM	40 CFR 63.863(a)	Compliance Dates	
APPLICABLE	63 Subpart MM	40 CFR 63.864	Monitoring Requirements	
APPLICABLE	63 Subpart MM	40 CFR 63.864(d)(3)	Continuous Opacity Monitoring System	
APPLICABLE	63 Subpart MM	40 CFR 63.864(d)(4)		
APPLICABLE	63 Subpart MM	40 CFR 63.864(k)(1)(i)	On-going Compliance	
APPLICABLE	63 Subpart MM	63.864(k)(2)(ii)		
APPLICABLE	63 Subpart MM	63.865	Performance Test Requirements	
APPLICABLE	63 Subpart MM	63.865(a)		
APPLICABLE	63 Subpart MM	63.865(b)		
APPLICABLE	63 Subpart MM	63.866		
APPLICABLE	63 Subpart MM	63.866(a)		
APPLICABLE	63 Subpart MM	63.866(b)		

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	63 Subpart MM	63.866(c)		
APPLICABLE	63 Subpart MM	63.867	Reporting	
APPLICABLE	63 Subpart MM	63.867(a)		
APPLICABLE	63 Subpart MM	63.867(b)		
APPLICABLE	63 Subpart MM	63.867(c)		
APPLICABLE	62-296 <	62-296.320(4)	General Particulate Emission Limiting Standards.	
APPLICABLE	62-296 <	62-296.320(4)(a)	General Particulate Emission Limiting Standards.	
APPLICABLE	62-296 <	62-296.320(4)(a)1.	General Particulate Emission Limiting Standards.	
APPLICABLE	62-296 <	62-296.320(4)(a)2.	General Particulate Emission Limiting Standards.	
APPLICABLE	62-296 <	62-296.320(4)(a)3.	General Particulate Emission Limiting Standards.	
APPLICABLE	62-296 <	62-296.320(4)(a)3.a.	General Particulate Emission Limiting Standards.	
NON-APPLICABLE	62-296 <	62-296.320(4)(a)3.a.(i)	General Particulate Emission Limiting Standards.	Applies to citrus plants.
APPLICABLE	62-296 <	62-296.320(4)(a)3.a.(ii)	General Particulate Emission Limiting Standards.	
NON-APPLICABLE	62-296 <	62-296.320(4)(a)3.b.	General Particulate Emission Limiting Standards.	Applies only to units with dry controls for PM. The No. 4 Lime Kiln has a wet scrubber for PM control.
APPLICABLE	62-296 <	62-296.320(4)(a)3.c.	General Particulate Emission Limiting Standards.	
APPLICABLE	62-296 <	62-296.320(4)(b)	General Visible Emissions Standard.	
APPLICABLE	62-296 <	62-296.404	Kraft (Sulfate) Pulp Mills and Tall Oil Plants.	
NON-APPLICABLE	62-296 <	62-296.404(1)	Visible Emissions.	Applies only to recovery furnaces.
APPLICABLE	62-296 <	62-296.404(2)	Particulate Matter.	
NON-APPLICABLE	62-296 <	62-296.404(2)(a)	Particulate Matter.	Applies only to recovery furnaces.
APPLICABLE	62-296 <	62-296.404(2)(b)	Particulate Matter.	
APPLICABLE	62-296 <	62-296.404(3)	Total Reduced Sulfur (TRS).	
NON-APPLICABLE	62-296 <	62-296.404(3)(a)	Total Reduced Sulfur (TRS).	Applies only to digester systems, multiple effect evaporator systems, and condensate stripper systems.
NON-APPLICABLE	62-296 <	62-296.404(3)(b)	Total Reduced Sulfur (TRS).	Applies only to tall oil plants.
NON-APPLICABLE	62-296 <	62-296.404(3)(c)	Total Reduced Sulfur (TRS).	Applies only to recovery furnaces.
NON-APPLICABLE	62-296 <	62-296.404(3)(d)	Total Reduced Sulfur (TRS).	Applies only to smelt dissolving tanks.

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	62-296 <	62-296.404(3)(e)	Total Reduced Sulfur (TRS).	
NON-APPLICABLE	62-296 <	62-296.404(3)(f)	Total Reduced Sulfur (TRS).	Applies to other combustion devices used for TRS control.
APPLICABLE	62-296 <	62-296.404(4)	Test Methods and Procedures.	
NON-APPLICABLE	62-296 <	62-296.404(4)(a)	Test Methods and Procedures.	Applies only to recovery furnaces.
APPLICABLE	62-296 <	62-296.404(4)(b)	Test Methods and Procedures.	
NON-APPLICABLE	62-296 <	62-296.404(4)(c)	Test Methods and Procedures.	Applies only to smelt dissolving tanks.
NON-APPLICABLE	62-296 <	62-296.404(4)(d)	Test Methods and Procedures.	Applies only to tall oil plants.
NON-APPLICABLE	62-296 <	62-296.404(4)(e)	Test Methods and Procedures.	Applies to other combustion devices used for TRS control.
APPLICABLE	62-296 <	62-296.404(4)(f)	Test Methods and Procedures.	
APPLICABLE	62-296 <	62-296.404(5)	Continuous Emissions Monitoring Requirements.	
APPLICABLE	62-296 <	62-296.404(5)(a)	Continuous Emissions Monitoring Requirements.	
APPLICABLE	62-296 <	62-296.404(5)(b)	Continuous Emissions Monitoring Requirements.	
NON-APPLICABLE	62-296 <	62-296.404(5)(c)	Continuous Emissions Monitoring Requirements.	Only applies to incinerators used for TRS control.
NON-APPLICABLE	62-296 <	62-296.404(5)(d)	Continuous Emissions Monitoring Requirements.	The No. 4 Lime Kiln is not required to monitor surrogate parameters.
APPLICABLE	62-296 <	62-296.404(6)	Quarterly Reporting Requirements.	
APPLICABLE	62-296 <	62-296.404(6)(a)	Quarterly Reporting Requirements.	
APPLICABLE	62-296 <	62-296.404(6)(b)	Quarterly Reporting Requirements.	
APPLICABLE	62-296 <	62-296.404(6)(c)	Quarterly Reporting Requirements.	
NON-APPLICABLE	62-296 <	62-296.404(6)(c)1.	Quarterly Reporting Requirements.	Applies only to recovery furnaces.
APPLICABLE	62-296 <	62-296.404(6)(c)2.	Quarterly Reporting Requirements.	
NON-APPLICABLE	62-296 <	62-296.404(6)(c)3.	Quarterly Reporting Requirements.	Applies to other TRS emissions units.
APPLICABLE	62-296 <	62-296.404(6)(c)4.	Quarterly Reporting Requirements.	
APPLICABLE	62-296 <	62-296.404(6)(d)	Quarterly Reporting Requirements.	
NON-APPLICABLE	62-296 >	62-296.709	RACT for PM Emissions -- Lime Kilns.	The Palatka Mill is not located in a PM air quality maintenance area or within the area of influence of such area.
APPLICABLE	62-297	62-297.310	General Compliance Test Requirements.	
APPLICABLE	62-297	62-297.401	Compliance Test Methods.	

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	62-297	62-297.401(1)(a)	EPA Method 1 - Sample and Velocity Traverses for Stationary sources - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(10)	EPA Method 10 - Determination of Carbon Monoxide Emissions from Stationary Sources - 40 CFR 60 Appendix A	
APPLICABLE	62-297	62-297.401(16)	EPA Method 16 - Semicontinuous Determination of Sulfur Emissions from Stationary Sources - 40 CFR 60 Appendix A	
APPLICABLE	62-297	62-297.401(16)(a)	EPA Method 16A - Determination of Total Reduced Sulfur Emissions from Stationary Sources (Impinger Technique) - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(2)	EPA Method 2 - Determination of Stack Gas Velocity and Volumetric Flow Rate - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(25)	EPA Method 25 - Determination of Total Gaseous Nonmethane Organic Emissions as Carbon - 40 CFR 60 Appendix A	
APPLICABLE	62-297	62-297.401(25)(a)	EPA Method 25A - Determination of Total Gaseous Organic Concentration Using a Flame Ionization Analyzer - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(3)	EPA Method 3 - Gas Analysis for Carbon Dioxide, Oxygen, Excess Air, and Dry Molecular Weight - 40 CFR 60 Appendix A	
APPLICABLE	62-297	62-297.401(4)	EPA Method 4 - Determination of Moisture Content in Stack Gases - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(5)	EPA Method 5 - Determination of Particulate Emissions from Stationary Sources - 40 CFR 60 Appendix A	
NON-APPLICABLE	62-297	62-297.401(7)	EPA Method 7 - Determination of Nitrogen Oxide Emissions from Stationary 40 CFR 60 Appendix A	CEMS Emissions monitoring
APPLICABLE	62-297	62-297.401(7)(e)	EPA Method 7E - Determination of Nitrogen Oxide Emissions from Stationary Sources (Instrumental Analyzer Procedure) - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(8)	EPA Method 8 - Determination of Sulfuric Acid Mist and Sulfur Dioxide Emissions from Stationary Sources - 40 CFR 60 Appendix A	

EU 018 No.4 Recovery Boiler Rule Applicability

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
NON-APPLICABLE	60 Subpart A	40CFR60.1	Subpart A -- General Provisions	No. 4 Recovery Boiler is not subject to NSPS; the boiler was built prior to the applicability date of some of the NSPS standards, as explained below, or, in the case of Subpart D, the boiler has a federally-enforceable restriction that exempts the unit (see Subpart D rationale below). The boiler has not been modified or reconstructed as defined in 40 CFR 60, since it was originally constructed.
NON-APPLICABLE	60 Subpart BB	40CFR60.280	Subpart BB -- Kraft Pulp Mills -- Applicability and designation of affected facility.	No. 4 Recovery Boiler is not subject to NSPS; the boiler was built prior to the applicability date of Sep. 24, 1976, and has not been modified or reconstructed as defined in 40 CFR 60 since it was originally constructed.
NON-APPLICABLE	60 Subpart D	40CFR60.40	Subpart D -- Fossil Fuel Steam Generators - Applicability and designation of affected facility	No. 4 Recovery Boiler is not subject to NSPS; the boiler was built after the applicability date of Aug.17, 1971, however, based on an EPA applicability determination dated April 30, 1990, units that have an annual capacity factor of less than 10% of the maximum heat input capacity of the boiler are not subject to Subpart D[1]. The No. 4 Recovery Boiler has not been modified or reconstructed as defined in 40 CFR 60 since it was originally constructed.
NON-APPLICABLE	60 Subpart Db	40CFR60.40b	Subpart Db -- Industrial - Commercial - Institutional Steam Generating Units - Applicability	No. 4 Recovery Boiler is not subject to NSPS; the boiler was built prior to the applicability date of June 19, 1984, and has not been modified or reconstructed as defined in 40 CFR 60 since it was originally constructed.
NON-APPLICABLE	60 Subpart Dc	40CFR60.40c	Subpart Dc-- Small Industrial - Commercial - Institutional Steam Generating Units -- Applicability	No. 4 Recovery Boiler is not subject to this NSPS as the boiler's design heat input is greater than the applicability range of 10-100 MM Btu/hr.
APPLICABLE	63 Subpart MM	40 CFR 63.1-63.15	NESHAPs General Provisions	
APPLICABLE	63 Subpart MM	40 CFR 63.860	Subpart MM, MACT for Kraft Pulp Mills	
APPLICABLE	63 Subpart MM	40 CFR 63.860(a)		
APPLICABLE	63 Subpart MM	40 CFR 63.860(b)1		
APPLICABLE	63 Subpart MM	40 CFR 63.860(c)		
APPLICABLE	63 Subpart MM	40 CFR 63.861	Definitions	
APPLICABLE	63 Subpart MM	40 CFR 63.862	Standards	

APPLICABLE	63 Subpart MM	40 CFR 63.862(a)(1)(i)(A)	Standards for HAP metals	
NON-APPLICABLE	63 Subpart MM	40 CFR 63.862(a)(1)(ii)	Bubble for PM	The Mill does not use the bubble provisions for compliance
APPLICABLE	63 Subpart MM	40 CFR 63.863(a)	Compliance Dates	
APPLICABLE	63 Subpart MM	40 CFR 63.864	Monitoring Requirements	
APPLICABLE	63 Subpart MM	40 CFR 63.864(d)(3)	Continuous Opacity Monitoring System	
APPLICABLE	63 Subpart MM	40 CFR 63.864(d)(4)		
APPLICABLE	63 Subpart MM	40 CFR 63.864(k)(1)(i)	On-going Compliance	
APPLICABLE	63 Subpart MM	40 CFR 63.864(k)(2)(i)		
APPLICABLE	63 Subpart MM	40 CFR 63.865	Performance Test Requirements	
APPLICABLE	63 Subpart MM	40 CFR 63.865(a)		
APPLICABLE	63 Subpart MM	40 CFR 63.865(b)		
APPLICABLE	63 Subpart MM	40 CFR 63.866	Recordkeeping	
APPLICABLE	63 Subpart MM	40 CFR 63.866(a)		
APPLICABLE	63 Subpart MM	40 CFR 63.866(b)		
APPLICABLE	63 Subpart MM	40 CFR 63.866(c)		
APPLICABLE	63 Subpart MM	40 CFR 63.867	Reporting	
APPLICABLE	63 Subpart MM	40 CFR 63.867(b)		
APPLICABLE	63 Subpart MM	40 CFR 63.867(c)		
APPLICABLE	62-296 <	62-296.404(1)(a)1	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Visible Emissions	
APPLICABLE	62-296 <	62-296.404(1)(a)2	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Visible Emissions	No. 4 Recovery Boiler has a continuous opacity monitor.
APPLICABLE	62-296 <	62-296.404(2)	Particulate Matter.	
APPLICABLE	62-296 <	62-296.404(2)(a)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Particulate Matter	
NON-APPLICABLE	62-296 <	62-296.404(2)(b)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Particulate Matter	No. 4 Recovery Boiler is not equipped with a wet scrubber.
APPLICABLE	62-296 <	62-296.404(3)	Total Reduced Sulfur (TRS).	
NON-APPLICABLE	62-296 <	62-296.404(3)(a)	Total Reduced Sulfur (TRS).	Applies only to digester systems, multiple effect evaporator systems, and condensate stripper systems.
NON-APPLICABLE	62-296 <	62-296.404(3)(b)	Total Reduced Sulfur (TRS).	Applies only to tall oil plants.
APPLICABLE	62-296 <	62-296.404(3)(c)	Total Reduced Sulfur (TRS).	

APPLICABLE	62-296 <	62-296.404(3)(c)1.	Total Reduced Sulfur (TRS).	
APPLICABLE	62-296 <	62-296.404(3)(c)1.a	Total Reduced Sulfur (TRS).	
NON-APPLICABLE	62-296 <	62-296.404(3)(c)1.b	Total Reduced Sulfur (TRS).	No. 4 Recovery Boiler is not a new design recovery furnace.
NON-APPLICABLE	62-296 <	62-296.404(3)(c)1.c	Total Reduced Sulfur (TRS).	The neutral sulfite semichemical process is not used at the Palatka Mill.
NON-APPLICABLE	62-296 <	62-296.404(3)(c)2	Total Reduced Sulfur (TRS).	No. 4 Recovery Boiler does not meet the criteria for a cross recovery furnace.
APPLICABLE	62-296 <	62-296.404(3)(c)3	Total Reduced Sulfur (TRS).	
NON-APPLICABLE	62-296 <	62-296.404(3)(d)	Total Reduced Sulfur (TRS).	Applies to smelt dissolving tanks.
NON-APPLICABLE	62-296 <	62-296.404(3)(e)	Total Reduced Sulfur (TRS).	Applies to lime kilns and calciners.
NON-APPLICABLE	62-296 <	62-296.404(3)(f)	Total Reduced Sulfur (TRS).	Applies to other combustion devices used for TRS control.
APPLICABLE	62-296 <	62-296.404(4)	Test Methods and Procedures.	
APPLICABLE	62-296 <	62-296.404(4)(a)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Test Methods and Procedures.	
NON-APPLICABLE	62-296 <	62-296.404(4)(b)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Test Methods and Procedures.	Applies to lime kilns and calciners.
NON-APPLICABLE	62-296 <	62-296.404(4)(c)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Test Methods and Procedures.	Applies to smelt dissolving tanks.
NON-APPLICABLE	62-296 <	62-296.404(4)(d)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Test Methods and Procedures.	Applies to tall oil plants.
NON-APPLICABLE	62-296 <	62-296.404(4)(e)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Test Methods and Procedures.	Applies to other combustion devices used for TRS control.
APPLICABLE	62-296 <	62-296.404(4)(f)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Test Methods and Procedures.	
APPLICABLE	62-296 <	62-296.404(5)	Continuous Emissions Monitoring Requirements.	
APPLICABLE	62-296 <	62-296.404(5)(a)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Continuous Emissions Monitoring Requirements.	
APPLICABLE	62-296 <	62-296.404(5)(b)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Continuous Emissions Monitoring Requirements.	

NON-APPLICABLE	62-296 <	62-296.404(5)(c)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Continuous Emissions Monitoring Requirements.	Applies only to incinerators used for TRS control.
NON-APPLICABLE	62-296 <	62-296.404(5)(d)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Continuous Emissions Monitoring Requirements.	Surrogate parameters are not required to be monitored for the No. 4 Recovery Boiler.
APPLICABLE	62-296 <	62-296.404(6)	Quarterly Reporting Requirements.	
APPLICABLE	62-296 <	62-296.404(6)(a)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Quarterly Reporting Requirements.	
APPLICABLE	62-296 <	62-296.404(6)(b)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Quarterly Reporting Requirements.	
APPLICABLE	62-296 <	62-296.404(6)(c)		
APPLICABLE	62-296 <	62-296.404(6)(c)1	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Quarterly Reporting Requirements.	
NON-APPLICABLE	62-296 <	62-296.404(6)(c)2	Quarterly Reporting Requirements.	Applies to lime kilns and calciners.
NON-APPLICABLE	62-296 <	62-296.404(6)(c)3	Quarterly Reporting Requirements.	Applies to other regulated TRS sources.
APPLICABLE	62-296 <	62-296.404(6)(c)4	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Quarterly Reporting Requirements.	
APPLICABLE	62-296 <	62-296.404(6)(d)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Quarterly Reporting Requirements.	
NON-APPLICABLE	62-296 <	62-296.405	Fossil Fuel Steam Generators with more than 250 million Btu per Hour Heat Input.	This unit is not classified as a fossil fuel steam generator.
NON-APPLICABLE	62-296 <	62-296.406	Fossil Fuel Steam Generators with less than 250 Million Btu per Hour Heat Input, New and Existing Em	This unit is not classified as a fossil fuel steam generator.
APPLICABLE	62-297	62-297.310	General Compliance Test Requirements.	
APPLICABLE	62-297	62-297.401	Compliance Test Methods.	
APPLICABLE	62-297	62-297.401(1)(a)	Compliance Test Methods.	
APPLICABLE	62-297	62-297.401(10)	EPA Method 10 - Determination of Carbon Monoxide Emissions from Stationary Sources - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(16)	EPA Method 16 - Semicontinuous Determination of Sulfur Emissions from Stationary Sources - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(16)(a)	EPA Method 16A - Determination of Total Reduced Sulfur Emissions from Stationary Sources (Impinger Technique) - 40 CFR 60 Appendix A.	

APPLICABLE	62-297	62-297.401(2)	EPA Method 2 - Determination of Stack Gas Velocity and Volumetric Flow Rate - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(25)	EPA Method 25 - Determination of Total Gaseous Nonmethane Organic Emissions as Carbon - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(25)(a)	EPA Method 25A - Determination of Total Gaseous Organic Concentration Using a Flame Ionization Analyzer - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(3)	EPA Method 3 - Gas Analysis for Carbon Dioxide, Oxygen, Excess Air, and Dry Molecular Weight - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(34)	EPA Method 103 - Beryllium Screening Method - 40 CFR 61 Appendix B.	
APPLICABLE	62-297	62-297.401(35)	EPA Method 104 - Determination of Beryllium Emissions from Stationary Sources - 40 CFR 61 Appendix B	
APPLICABLE	62-297	62-297.401(4)	EPA Method 4 - Determination of Moisture Content in Stack Gases - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(5)	EPA Method 5 - Determination of Particulate Emissions from Stationary Sources - 40 CFR 60 Appendix A	
NON-APPLICABLE	62-297	62-297.401(7)	EPA Method 7 - Determination of Nitrogen Oxide Emissions from Stationary Sources - 40 CFR 60 Appendix A	CEMS Emissions Monitoring
APPLICABLE	62-297	62-297.401(7)(e)	EPA Method 7E - Determination of Nitrogen Oxide Emissions from Stationary Sources (Instrumental Analyzer Procedure) - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(8)	EPA Method 8 - Determination of Sulfuric Acid Mist and Sulfur Dioxide Emissions from Stationary Sources - 40 CFR 60 Appendix A	
APPLICABLE	62-297	62-297.401(9)(a)	EPA Method 9 - Visual Determination of the Opacity of Emissions from Stationary Sources - 40 CFR 60 Appendix A	

[1] Applicability of Subpart D to Emissions from Oil-Firing in Kraft Pulp Mill Recovery Furnaces, dated April 30, 1990, from Jack R. Farmer of the Emissions Standards Division to John S. Seitz of the Stationary Source Compliance Division. See attachment.

EU 019 No. 4 Smelt Dissolving Tanks (2) Rule Applicability

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
NON-APPLICABLE	60 Subpart A	40CFR60.1	Subpart A -- General Provisions	No. 4 Smelt Dissolving Tanks are not subject to NSPS; the tanks were built prior to the applicability date of Sep. 24, 1976, and have not been modified or reconstructed as defined in 40 CFR 60.
NON-APPLICABLE	60 Subpart BB	40CFR60.280	Subpart BB -- Kraft Pulp Mills -- Applicability and designation of affected facility.	No. 4 Smelt Dissolving Tanks are not subject to NSPS; the tanks were built prior to the applicability date of Sep. 24, 1976, and have not been modified or reconstructed as defined in 40 CFR 60.
APPLICABLE	63 Subpart MM	40 CFR 63.1-63.15	NESHAPs General Provisions	
APPLICABLE	63 Subpart MM	40 CFR 63.860(a)	NESHAPs Subpart MM	
APPLICABLE	63 Subpart MM	40 CFR 63.860(b)1	NESHAPs Subpart MM	
APPLICABLE	63 Subpart MM	40 CFR 63.860(c)	NESHAPs Subpart MM	
APPLICABLE	63 Subpart MM	40 CFR 63.862(a)(1)(i)(B)	Standards for HAP Metals	
NON-APPLICABLE	63 Subpart MM	40 CFR 63.862(a)(1)(ii)	Bubble for PM	The Mill does not use the bubble provisions for compliance
APPLICABLE	63 Subpart MM	40 CFR 63.863(a)	Compliance Dates	
APPLICABLE	63 Subpart MM	40 CFR 63.864(a)(2)	Monitoring Requirements	
APPLICABLE	63 Subpart MM	40 CFR 63.864(a)(4)		
APPLICABLE	63 Subpart MM	40 CFR 63.864(b)(1)		
APPLICABLE	63 Subpart MM	40 CFR 63.864(b)(2)		
APPLICABLE	63 Subpart MM	40 CFR 63.864(c)(1)(ii)		
APPLICABLE	63 Subpart MM	40 CFR 63.864(c)(2)(iii)		
APPLICABLE	63 Subpart MM	40 CFR 63.865(a)	Performance Test Requirements	
APPLICABLE	63 Subpart MM	40 CFR 63.865(b)	Performance Test Requirements	
APPLICABLE	63 Subpart MM	40 CFR 63.865(e)		
APPLICABLE	63 Subpart MM	40 CFR 63.866(a)	Recordkeeping	
APPLICABLE	63 Subpart MM	40 CFR 63.866(b)		
APPLICABLE	63 Subpart MM	40 CFR 63.866(c)(3)		
APPLICABLE	63 Subpart MM	40 CFR 63.866(c)(4)		
APPLICABLE	63 Subpart MM	40 CFR 63.866(c)(5)		
APPLICABLE	63 Subpart MM	40 CFR 63.867(a)	Reporting	
APPLICABLE	63 Subpart MM	40 CFR 63.867(b)		
APPLICABLE	63 Subpart MM	40 CFR 63.867(c)		
APPLICABLE	62-296 <	62-296.320(4)(a)	General Particulate Emission Limiting	

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
			Standards.	
APPLICABLE	62-296 <	62-296.320(4)(a)1.	General Particulate Emission Limiting Standards.	
APPLICABLE	62-296 <	62-296.320(4)(a)2.	General Particulate Emission Limiting Standards.	
APPLICABLE	62-296 <	62-296.320(4)(a)3.	General Particulate Emission Limiting Standards.	
APPLICABLE	62-296 <	62-296.320(4)(a)3.a.	General Particulate Emission Limiting Standards.	
NON-APPLICABLE	62-296 <	62-296.320(4)(a)3.a.(i)	General Particulate Emission Limiting Standards.	Applies to citrus plants.
APPLICABLE	62-296 <	62-296.320(4)(a)3.a.(ii)	General Particulate Emission Limiting Standards.	
NON-APPLICABLE	62-296 <	62-296.320(4)(a)3.b.	General Particulate Emission Limiting Standards.	Applies only to units with dry controls for PM. The No. 4 SDT has a wet scrubber for PM control.
APPLICABLE	62-296 <	62-296.320(4)(a)3.c.	General Particulate Emission Limiting Standards.	
APPLICABLE	62-296 <	62-296.320(4)(b)	General Visible Emission Standard.	
APPLICABLE	62-296 <	62-296.404	Kraft (Sulfate) Pulp Mills and Tall Oil Plants.	
NON-APPLICABLE	62-296 <	62-296.404(1)	Visible Emissions.	Applies only to recovery furnaces.
NON-APPLICABLE	62-296 <	62-296.404(2)(a)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Particulate Matter	Applies only to recovery furnaces.
APPLICABLE	62-296 <	62-296.404(2)(b)	Particulate Matter.	
APPLICABLE	62-296 <	62-296.404(3)	Total Reduced Sulfur (TRS).	
NON-APPLICABLE	62-296 <	62-296.404(3)(a)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Total Reduced Sulfur (TRS).	Applies only to digester systems, multiple effect evaporator systems, and condensate stripper systems.
NON-APPLICABLE	62-296 <	62-296.404(3)(b)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Total Reduced Sulfur (TRS).	Applies only to tall oil plants.
NON-APPLICABLE	62-296 <	62-296.404(3)(c)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Total Reduced Sulfur (TRS).	Applies only to kraft recovery furnaces.
APPLICABLE	62-296 <	62-296.404(3)(d)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Total Reduced Sulfur (TRS).	Smelt Dissolving Tank Vents.
NON-APPLICABLE	62-296 <	62-296.404(3)(e)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Total Reduced Sulfur (TRS).	Applies only to lime kilns and calciners.
NON-APPLICABLE	62-296 <	62-296.404(3)(f)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Total Reduced Sulfur (TRS).	Applies to other combustion devices used for TRS control.

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	62-296 <	62-296.404(4)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Test Methods and Procedures.	
NON-APPLICABLE	62-296 <	62-296.404(4)(a)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Test Methods and Procedures.	Applies only to kraft recovery furnaces.
NON-APPLICABLE	62-296 <	62-296.404(4)(b)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Test Methods and Procedures.	Applies only to lime kilns and calciners.
APPLICABLE	62-296 <	62-296.404(4)(c)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Test Methods and Procedures.	
APPLICABLE	62-296 <	62-296.404(4)(c)1.	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Test Methods and Procedures.	
NON-APPLICABLE	62-296 <	62-296.404(4)(c)2.	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Test Methods and Procedures.	Applies only to units with dry controls for PM. The No. 4 SDT has a wet scrubber for PM control.
APPLICABLE	62-296 <	62-296.404(4)(c)3.	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Test Methods and Procedures.	
NON-APPLICABLE	62-296 <	62-296.404(4)(d)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Test Methods and Procedures.	Applies only to tall oil plants.
NON-APPLICABLE	62-296 <	62-296.404(4)(e)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Test Methods and Procedures.	Applies to other combustion devices used for TRS control.
APPLICABLE	62-296 <	62-296.404(4)(f)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Test Methods and Procedures.	
APPLICABLE	62-296 <	62-296.404(5)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Continuous Emissions Monitoring Requirements.	
NON-APPLICABLE	62-296 <	62-296.404(5)(a)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Continuous Emissions Monitoring Requirements.	Applies only to kraft recovery furnaces.
NON-APPLICABLE	62-296 <	62-296.404(5)(b)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Continuous Emissions Monitoring Requirements.	The No. 4 SDT is not required to have a continuous TRS monitor.
NON-APPLICABLE	62-296 <	62-296.404(5)(c)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Continuous Emissions Monitoring Requirements.	Applies only to incinerators.
APPLICABLE	62-296 <	62-296.404(5)(d)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Continuous Emissions Monitoring Requirements.	
APPLICABLE	62-296 <	62-296.404(6)	Quarterly Reporting Requirements.	
APPLICABLE	62-296 <	62-296.404(6)(a)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Quarterly Reporting Requirements.	

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	62-296 <	62-296.404(6)(b)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Quarterly Reporting Requirements.	
APPLICABLE	62-296 <	62-296.404(6)(c)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Quarterly Reporting Requirements.	
NON-APPLICABLE	62-296 <	62-296.404(6)(c)1.	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Quarterly Reporting Requirements.	Applies only to kraft recovery furnaces.
NON-APPLICABLE	62-296 <	62-296.404(6)(c)2.	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Quarterly Reporting Requirements.	Applies to lime kilns and calciners.
APPLICABLE	62-296 <	62-296.404(6)(c)3.	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Quarterly Reporting Requirements.	
APPLICABLE	62-296 <	62-296.404(6)(c)4.	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Quarterly Reporting Requirements.	
APPLICABLE	62-296 <	62-296.404(6)(d)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants -- Quarterly Reporting Requirements.	
NON-APPLICABLE	62-296 >	62-296.710	RACT for PM Emissions -- Smelt Dissolving Tanks.	The Palatka Mill is not located in a PM air quality maintenance area or within the area of influence of such area.
APPLICABLE	62-297	62-297.310	General Compliance Test Requirements.	
APPLICABLE	62-297	62-297.401	Compliance Test Methods.	
APPLICABLE	62-297	62-297.401(1)(a)	Compliance Test Methods.	
APPLICABLE	62-297	62-297.401(16)	EPA Method 16 - Semicontinuous Determination of Sulfur Emissions from Stationary Sources - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(16)(a)	EPA Method 16A - Determination of Total Reduced Sulfur Emissions from Stationary Sources (Impinger Technique) - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(2)	EPA Method 2 - Determination of Stack Gas Velocity and Volumetric Flow Rate - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(3)	EPA Method 3 - Gas Analysis for Carbon Dioxide, Oxygen, Excess Air, and Dry	

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
			Molecular Weight - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(4)	EPA Method 4 - Determination of Moisture Content in Stack Gases - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(5)	EPA Method 5 - Determination of Particulate Emissions from Stationary Sources - 40 CFR 60 Appendix A	
APPLICABLE	62-297	62-297.401(9)(a)	EPA Method 9 - Visual Determination of the Opacity of Emissions from Stationary Sources - 40 CFR 60 Appendix A.	

EU 031 Tall Oil Plant Rule Applicability

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
NON-APPLICABLE	60 Subpart A	40CFR60.1	Subpart A -- General Provisions	The NSPS do not cover Tall Oil Plants.
NON-APPLICABLE	60 Subpart BB	40CFR60.280	Subpart BB -- Kraft Pulp Mills -- Applicability and designation of affected facility.	The NSPS do not cover Tall Oil Plants.
APPLICABLE	62-296 <	62-296.404	Kraft (Sulfate) Pulp Mills and Tall Oil Plants.	
NON-APPLICABLE	62-296 <	62-296.404(1)	Visible Emissions.	Applies only to recovery furnaces.
NON-APPLICABLE	62-296 <	62-296.404(2)	Particulate Matter.	Applies only to recovery furnaces.
APPLICABLE	62-296 <	62-296.404(2)(b)	Particulate Matter.	
APPLICABLE	62-296 <	62-296.404(3)	Total Reduced Sulfur (TRS).	
NON-APPLICABLE	62-296 <	62-296.404(3)(a)	Total Reduced Sulfur (TRS).	Applies only to digester systems, multiple effect evaporator systems, and condensate stripper systems.
APPLICABLE	62-296 <	62-296.404(3)(b)	Total Reduced Sulfur (TRS).	
NON-APPLICABLE	62-296 <	62-296.404(3)(c)	Total Reduced Sulfur (TRS).	Applies only to recovery furnaces.
NON-APPLICABLE	62-296 <	62-296.404(3)(d)	Total Reduced Sulfur (TRS).	Applies only to smelt dissolving tanks.
NON-APPLICABLE	62-296 <	62-296.404(3)(e)	Total Reduced Sulfur (TRS).	Applies only to lime kilns and calciners.
NON-APPLICABLE	62-296 <	62-296.404(3)(f)	Total Reduced Sulfur (TRS).	Applies to other combustion devices used for TRS control.
APPLICABLE	62-296 <	62-296.404(4)	Test Methods and Procedures.	
NON-APPLICABLE	62-296 <	62-296.404(4)(a)	Test Methods and Procedures.	Applies only to recovery furnaces.
NON-APPLICABLE	62-296 <	62-296.404(4)(b)	Test Methods and Procedures.	Applies only to lime kilns and calciners.
NON-APPLICABLE	62-296 <	62-296.404(4)(c)	Test Methods and Procedures.	Applies only to smelt dissolving tanks.
APPLICABLE	62-296 <	62-296.404(4)(d)	Test Methods and Procedures.	
NON-APPLICABLE	62-296 <	62-296.404(4)(e)	Test Methods and Procedures.	Applies to other combustion devices used for TRS control.
APPLICABLE	62-296 <	62-296.404(4)(f)	Test Methods and Procedures.	
APPLICABLE	62-296 <	62-296.404(5)	Continuous Emissions Monitoring	

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
			Requirements.	
NON-APPLICABLE	62-296 <	62-296.404(5)(a)	Continuous Emissions Monitoring Requirements.	The Tall Oil Plant is not required to have a continuous TRS monitor.
NON-APPLICABLE	62-296 <	62-296.404(5)(b)	Continuous Emissions Monitoring Requirements.	The Tall Oil Plant is not required to have a continuous TRS monitor.
NON-APPLICABLE	62-296 <	62-296.404(5)(c)	Continuous Emissions Monitoring Requirements.	Only applies to incinerators used for TRS control.
APPLICABLE	62-296 <	62-296.404(5)(d)	Continuous Emissions Monitoring Requirements.	
APPLICABLE	62-296 <	62-296.404(6)	Quarterly Reporting Requirements.	
APPLICABLE	62-296 <	62-296.404(6)(a)	Quarterly Reporting Requirements.	The report shall include the following information:
APPLICABLE	62-296 <	62-296.404(6)(b)	Quarterly Reporting Requirements.	
APPLICABLE	62-296 <	62-296.404(6)(c)	Quarterly Reporting Requirements.	
NON-APPLICABLE	62-296 <	62-296.404(6)(c)1.	Quarterly Reporting Requirements.	Applies only to recovery furnaces.
NON-APPLICABLE	62-296 <	62-296.404(6)(c)2.	Quarterly Reporting Requirements.	Applies only to lime kilns and calciners.
APPLICABLE	62-296 <	62-296.404(6)(c)3.	Quarterly Reporting Requirements.	
APPLICABLE	62-296 <	62-296.404(6)(c)4.	Quarterly Reporting Requirements.	
APPLICABLE	62-296 <	62-296.404(6)(d)	Quarterly Reporting Requirements.	
APPLICABLE	62-297	62-297.310	General Compliance Test Requirements.	
APPLICABLE	62-297	62-297.401	Compliance Test Methods.	
APPLICABLE	62-297	62-297.401(1)(a)	EPA Method 1 - Sample and Velocity Traverses for Stationary sources - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(16)	EPA Method 16 - Semicontinuous Determination of Sulfur Emissions from Stationary Sources - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(16)(a)	EPA Method 16A - Determination of Total Reduced Sulfur Emissions from Stationary Sources (Impinger Technique) - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(16)(b)	EPA Method 16B - Determination of Total Reduced Sulfur Emissions from Stationary Sources - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(2)	EPA Method 2 - Determination of Stack Gas Velocity and Volumetric Flow Rate	

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
			- 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(3)	EPA Method 3 - Gas Analysis for Carbon Dioxide, Oxygen, Excess Air, and Dry Molecular Weight - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(4)	EPA Method 4 - Determination of Moisture Content in Stack Gases - 40 CFR 60 Appendix A.	

EU 035 ClO_2 Plant/Methanol Tank Rule Applicability

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	62-296 <	62-296.320(2)	General VE	
NON-APPLICABLE	60 Subpart Kb	40 CFR 60.116(b)	Methanol Storage Tank – NSPS Subpart Kb	MeOH storage tank capacity of 15,000 gallons less than Kb threshold of 75 m^3 (19,813 gallons)
NON-APPLICABLE	62-296 <	62-204.800(7)(b)(17)	Methanol Storage Tank –adoption of federal NSPS rules-Subpart Kb	MeOH storage tank capacity of 15,000 gallons less than Kb threshold of 75 m^3 (19,813 gallons)
APPLICABLE	62-296 <	62-296.320(2)	Methanol Storage Tank -Objectionable Odor Prohibited	

EU 036 No. 3 Bleach Plant Rule Applicability

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	40 CFR 63	40 CFR 63.445(a)(2)	Standards for the bleaching system	
APPLICABLE	40 CFR 63	40 CFR 63.445(b)	Standards for the bleaching system	
APPLICABLE	40 CFR 63	40 CFR 63.445(c)(1)	Standards for the bleaching system	
APPLICABLE	40 CFR 63	40 CFR 63.445(d)	Standards for the bleaching system	
APPLICABLE	40 CFR 63	40 CFR 63.450(a)-(d)	Standards for enclosures and closed-vent systems	
APPLICABLE	40 CFR 63	40 CFR 63.453(a)	Monitoring Requirements	
APPLICABLE	40 CFR 63	40 CFR 63.453(c)-(d)	Monitoring Requirements	
APPLICABLE	40 CFR 63	40 CFR 63.453(k)	Monitoring Requirements	
APPLICABLE	40 CFR 63	40 CFR 63.453(n)-(o)	Monitoring Requirements	
APPLICABLE	40 CFR 63	40 CFR 63.454(a)-(b)	Recordkeeping Requirements	
APPLICABLE	40 CFR 63	40 CFR 63.454(d)	Recordkeeping Requirements	
APPLICABLE	40 CFR 63	40 CFR 63.455(a)	Reporting Requirements	
APPLICABLE	40 CFR 63	40 CFR 63.455(d)	Reporting Requirements	
APPLICABLE	40 CFR 63	40 CFR 63.457(a)-(b)	Test Methods and Procedures	
APPLICABLE	40 CFR 63	40 CFR 63.457(d)-(e)	Test Methods and Procedures	
APPLICABLE	40 CFR 63	40 CFR 63.457(h)-(i)	Test Methods and Procedures	
APPLICABLE	62-212	62-212.400	PSD	
APPLICABLE	62-210	62-210.700	Excess Emissions	
APPLICABLE	63 Subpart A	40 CFR 63.1(a)(1)-(4)	Subpart A – Applicability	
APPLICABLE	63 Subpart A	40 CFR 63.1(a)(11)-(14)	Subpart A – Applicability	
APPLICABLE	63 Subpart A	40 CFR 63.1(b)(2)-(3)	Subpart A – Applicability	
APPLICABLE	63 Subpart A	40 CFR 63.1(c)(1)-(2)	Subpart A – Applicability	
APPLICABLE	63 Subpart A	40 CFR 63.1(c)(5)	Subpart A – Applicability	
APPLICABLE	63 Subpart A	40 CFR 63.1(e)	Subpart A – Applicability	

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	63 Subpart A	40 CFR 63.2	Subpart A – Definitions	
APPLICABLE	63 Subpart A	40 CFR 63.3	Subpart A – Units and Abbreviations	
APPLICABLE	63 Subpart A	40 CFR 63.4(a)(1)	Subpart A – Prohibited Activities and Circumvention	
APPLICABLE	63 Subpart A	40 CFR 63.4(a)(3)	Subpart A – Prohibited Activities and Circumvention	
APPLICABLE	63 Subpart A	40 CFR 63.4(a)(5)	Subpart A – Prohibited Activities and Circumvention	
APPLICABLE	63 Subpart A	40 CFR 63.4(b)-(c)	Subpart A – Prohibited Activities and Circumvention	
APPLICABLE	63 Subpart A	40 CFR 63.5(a)	Subpart A – Construction and Reconstruction	
APPLICABLE	63 Subpart A	40 CFR 63.5(b)(1)	Subpart A – Construction and Reconstruction	
APPLICABLE	63 Subpart A	40 CFR 63.5(b)(3)-(6)	Subpart A – Construction and Reconstruction	
APPLICABLE	63 Subpart A	40 CFR 63.5(d)(1)	Subpart A – Construction and Reconstruction	
APPLICABLE	63 Subpart A	40 CFR 63.5(d)(3)-(4)	Subpart A – Construction and Reconstruction	
APPLICABLE	63 Subpart A	40 CFR 63.5(e)	Subpart A – Construction and Reconstruction	
APPLICABLE	63 Subpart A	40 CFR 63.5(f)	Subpart A – Construction and Reconstruction	
APPLICABLE	63 Subpart A	40 CFR 63.6(a)	Subpart A – Compliance with Standards and Maintenance Requirements	
APPLICABLE	63 Subpart A	40 CFR 63.6(e)-(g)	Subpart A – Compliance with Standards and Maintenance Requirements	
APPLICABLE	63 Subpart A	40 CFR 63.6(i)-(j)	Subpart A – Compliance with Standards and Maintenance Requirements	
APPLICABLE	63 Subpart A	40 CFR 63.8(a)(1)-(2)	Subpart A – Monitoring Requirements	
APPLICABLE	63 Subpart A	40 CFR 63.8(a)(4)	Subpart A – Monitoring Requirements	
APPLICABLE	63 Subpart A	40 CFR 63.8(b)(1)	Subpart A – Monitoring Requirements	
APPLICABLE	63 Subpart A	40 CFR 63.8(b)(3)	Subpart A – Monitoring Requirements	
APPLICABLE	63 Subpart A	40 CFR 63.(c)(1)-(3)	Subpart A – Monitoring Requirements	
APPLICABLE	63 Subpart A	40 CFR 63.8(c)(6)-(8)	Subpart A – Monitoring Requirements	
APPLICABLE	63 Subpart A	40 CFR 63.8(d)	Subpart A – Monitoring Requirements	

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	63 Subpart A	40 CFR 63.8(e)	Subpart A – Monitoring Requirements	
APPLICABLE	63 Subpart A	40 CFR 63.8(f)(1)-(5)	Subpart A – Monitoring Requirements	
APPLICABLE	63 Subpart A	40 CFR 63.8(g)	Subpart A – Monitoring Requirements	
APPLICABLE	63 Subpart A	40 CFR 63.9(a)-(b)	Subpart A – Notification Requirements	
APPLICABLE	63 Subpart A	40 CFR 63.9(c)	Subpart A – Notification Requirements	
APPLICABLE	63 Subpart A	40 CFR 63.9(g)(1)	Subpart A – Notification Requirements	
APPLICABLE	63 Subpart A	40 CFR 63.9(h)-(j)	Subpart A – Notification Requirements	
APPLICABLE	63 Subpart A	40 CFR 63.10(a)-(c)	Subpart A – Recordkeeping and Reporting Requirements	
APPLICABLE	63 Subpart A	40 CFR 63.10(d)(1)-(2)	Subpart A – Recordkeeping and Reporting Requirements	
APPLICABLE	63 Subpart A	40 CFR 63.10(d)(4)-(5)	Subpart A – Recordkeeping and Reporting Requirements	
APPLICABLE	63 Subpart A	40 CFR 63.10(e)(1)	Subpart A – Recordkeeping and Reporting Requirements	
APPLICABLE	63 Subpart A	40 CFR 63.10(e)(2)(i)	Subpart A – Recordkeeping and Reporting Requirements	
APPLICABLE	63 Subpart A	40 CFR 63.10(e)(3)	Subpart A – Recordkeeping and Reporting Requirements	
APPLICABLE	63 Subpart A	40 CFR 63.10(f)	Subpart A – Recordkeeping and Reporting Requirements	
APPLICABLE	63 Subpart A	40 CFR 63.12	Subpart A – State Authority and Delegation	
APPLICABLE	63 Subpart A	40 CFR 63.13	Subpart A – Addresses of State Air Pollution Control Agencies and EPA Regional Offices	
APPLICABLE	63 Subpart A	40 CFR 63.14	Subpart A – Incorporations by References	
APPLICABLE	63 Subpart A	40 CFR 63.15	Subpart A – Availability of Information and Confidentiality	

EU 037 NCG Collection/Thermal Oxidizer Rule Applicability

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	**60 Subpart A**	**40CFR60.1**	**Subpart A -- General Provisions**	
APPLICABLE	60 Subpart A	40CFR60.7	Notification and record keeping.	
APPLICABLE	60 Subpart A	40CFR60.8	Performance tests.	
NON-APPLICABLE	60 Subpart A	40CFR60.11	Compliance with standards and maintenance requirements.	
APPLICABLE	60 Subpart A	40CFR60.11(a)	Compliance with standards and maintenance requirements.	
NON-APPLICABLE	60 Subpart A	40CFR60.11(b)	Compliance with standards and maintenance requirements.	40 CFR 60 Subpart BB does not set an opacity standard for digesters, multiple effect evaporators, condensate strippers or from incinerators burning waste gases from these units
NON-APPLICABLE	60 Subpart A	40CFR60.11(c)	Compliance with standards and maintenance requirements.	40 CFR 60 Subpart BB does not set an opacity standard for digesters, multiple effect evaporators or condensate strippers or from incinerators burning waste gases from these units
APPLICABLE	60 Subpart A	40CFR60.11(d)	Compliance with standards and maintenance requirements.	
NON-APPLICABLE	60 Subpart A	40CFR60.11(e)	Compliance with standards and maintenance requirements.	40 CFR 60 Subpart BB does not set an opacity standard for digesters, multiple effect evaporators or condensate strippers or from incinerators burning waste gases from these units
APPLICABLE	60 Subpart A	40CFR60.11(f)	Compliance with standards and maintenance requirements.	
APPLICABLE	60 Subpart A	40CFR60.12	Circumvention.	
APPLICABLE	60 Subpart A	40CFR60.13	Monitoring requirements.	
APPLICABLE	60 Subpart A	40CFR60.13(a)	Monitoring requirements.	
APPLICABLE	60 Subpart A	40CFR60.13(b)	Monitoring requirements.	
NON-APPLICABLE	60 Subpart A	40CFR60.13(c)	Monitoring requirements.	40 CFR 60 Subpart BB does not require an opacity monitor for digesters, multiple effect evaporators or condensate strippers or for incinerators burning waste gases from these units
NON-APPLICABLE	60 Subpart A	40CFR60.13(d)(1)	Monitoring requirements.	40 CFR 60 Subpart BB does not require a continuous emissions monitoring system for

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
				digesters, multiple effect evaporators and condensate strippers which are vented to an incineration device.
NON-APPLICABLE	60 Subpart A	40CFR60.13(d)(2)	Monitoring requirements.	40 CFR 60 Subpart BB does not require an opacity monitor for digesters, multiple effect evaporators or condensate strippers or from incinerators burning waste gases from these units
NON-APPLICABLE	60 Subpart A	40CFR60.13(e)	Monitoring requirements.	40 CFR 60 Subpart BB does not require a continuous emissions monitoring system for digesters, multiple effect evaporators and condensate strippers which are vented to an incineration device.
APPLICABLE	60 Subpart A	40CFR60.13(f)	Monitoring requirements.	
APPLICABLE	60 Subpart A	40CFR60.13(g)	Monitoring requirements.	
APPLICABLE	60 Subpart A	40CFR60.13(h)	Monitoring requirements.	
APPLICABLE	60 Subpart A	40CFR60.13(i)	Monitoring requirements.	
NON-APPLICABLE	60 Subpart A	40CFR60.13(j)	Monitoring requirements.	40 CFR 60 Subpart BB does not require a continuous emissions monitoring system for digesters, multiple effect evaporators and condensate strippers which are vented to an incineration device.
NON-APPLICABLE	60 Subpart A	40CFR60.18	General control device requirements.	Applies to flares.
APPLICABLE	60 Subpart A	40CFR60.19	General notification and reporting requirements	
APPLICABLE	60 Subpart BB	40CFR60.280	Subpart BB -- Kraft Pulp Mills	
APPLICABLE	60 Subpart BB	40CFR60.280	Applicability and designation of affected facility.	
NON-APPLICABLE	60 Subpart BB	40CFR60.282	Standard for particulate matter	40 CFR 60 Subpart BB does not set a particulate matter limit for digesters, multiple effect evaporators,r condensate strippers, or incinerators burning waste gases from these units.
APPLICABLE	60 Subpart BB	40CFR60.283	Standard for total reduced sulfur (TRS).	
APPLICABLE	60 Subpart BB	40CFR60.283(a)	Standard for total reduced sulfur (TRS).	
APPLICABLE	60 Subpart BB	40CFR60.283(a)(1)	Standard for total reduced sulfur (TRS).	
NON-APPLICABLE	60 Subpart BB	40CFR60.283(a)(1)(i)	Standard for total reduced sulfur (TRS).	TRS gases are not combusted in a lime kiln.
NON-APPLICABLE	60 Subpart BB	40CFR60.283(a)(1)(ii)	Standard for total reduced sulfur (TRS).	TRS gases are not combusted in a recovery boiler.
APPLICABLE	60 Subpart BB	40CFR60.283(a)(1)(iii)	Standard for total reduced sulfur (TRS).	

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
NON-APPLICABLE	60 Subpart BB	40CFR60.283(a)(1)(iv)	Standard for total reduced sulfur (TRS).	This emissions unit does not address brown stock washers.
NON-APPLICABLE	60 Subpart BB	40CFR60.283(a)(1)(v)	Standard for total reduced sulfur (TRS).	TRS gases are controlled by combustion .
NON-APPLICABLE	60 Subpart BB	40CFR60.283(a)(1)(vi)	Standard for total reduced sulfur (TRS).	Uncontrolled emissions from the digester system contain TRS greater than 0.01 lb/ton ADP.
NON-APPLICABLE	60 Subpart BB	40CFR60.283(a)(2)	Standard for total reduced sulfur (TRS).	This emissions unit is not a recovery furnace.
NON-APPLICABLE	60 Subpart BB	40CFR60.283(a)(3)	Standard for total reduced sulfur (TRS).	This emissions unit is not a recovery furnace.
NON-APPLICABLE	60 Subpart BB	40CFR60.283(a)(4)	Standard for total reduced sulfur (TRS).	This emissions unit is not a smelt dissolving tank.
NON-APPLICABLE	60 Subpart BB	40CFR60.283(a)(5)	Standard for total reduced sulfur (TRS).	This emissions unit is not a lime kiln.
APPLICABLE	60 Subpart BB	40CFR60.284	Monitoring of emissions and operations.	
NON-APPLICABLE	60 Subpart BB	40CFR60.284(a)	Monitoring of emissions and operations.	40 CFR 60 Subpart BB does not require a continuous emissions monitoring system for digesters, multiple effect evaporators and condensate strippers which are vented to an incineration device.
APPLICABLE	60 Subpart BB	40CFR60.284(b)	Monitoring of emissions and operations.	
APPLICABLE	60 Subpart BB	40CFR60.284(b)(1)	Monitoring of emissions and operations.	
NON-APPLICABLE	60 Subpart BB	40CFR60.284(b)(2)	Monitoring of emissions and operations.	Applies only to lime kilns and smelt dissolving tanks.
NON-APPLICABLE	60 Subpart BB	40CFR60.284(c)	Monitoring of emissions and operations.	TRS continuous emissions monitoring not required.
APPLICABLE	60 Subpart BB	40CFR60.284(d)	Monitoring of emissions and operations.	
NON-APPLICABLE	60 Subpart BB	40CFR60.284(d)(1)	Monitoring of emissions and operations.	Applies only to recovery furnaces.
NON-APPLICABLE	60 Subpart BB	40CFR60.284(d)(2)	Monitoring of emissions and operations.	Applies only to lime kilns.
APPLICABLE	60 Subpart BB	40CFR60.284(d)(3)	Monitoring of emissions and operations.	
NON-APPLICABLE	60 Subpart BB	40CFR60.284(d)(3)(i)	Monitoring of emissions and operations.	Only applies if continuous TRS monitoring is required.
APPLICABLE	60 Subpart BB	40CFR60.284(d)(3)(ii)	Monitoring of emissions and operations.	
NON-APPLICABLE	60 Subpart BB	40CFR60.284(e)	Monitoring of emissions and operations.	Only applies to recovery furnaces.
NON-	60 Subpart BB	40CFR60.285	Test methods and procedures.	For incinerators, no emissions compliance

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE				testing is required.
NON-APPLICABLE	60 Subpart BB	40CFR60.286	Innovative technology waiver	Innovative control technology waiver has not been requested or granted.
APPLICABLE	63 Subpart S	40 CFR 63, Subpart A	General Provisions	
APPLICABLE	63 Subpart S	40 CFR 63.443(a)(1)(i)	MACT Standards – LVHC System	
APPLICABLE	63 Subpart S	40 CFR 63.443(c)	MACT Standards – Closed Vent Systems	
APPLICABLE	63 Subpart S	40 CFR 63.443(d)(4)	MACT Standards – HAP Reduction in a Boiler or Lime Kiln	
APPLICABLE	63 Subpart S	40 CFR 63.443(e)	MACT Standards – Excess Emissions	
APPLICABLE	63 Subpart S	40 CFR 63.446(b)	MACT Standards – Pulping Process Condensates	
APPLICABLE	63 Subpart S	40 CFR 63.446(c)	MACT Standards – Pulping Process Condensates	
APPLICABLE	63 Subpart S	40 CFR 63.446(d)	MACT Standards – Pulping Process Condensates	
APPLICABLE	63 Subpart S	40 CFR 63.446(e)(5)	MACT Standards – Pulping Process Condensates	
APPLICABLE	63 Subpart S	40 CFR 63.446(h)	MACT Standards – Pulping Process Condensates	
APPLICABLE	63 Subpart S	40 CFR 63.450	MACT Standards – Closed Vent Systems	
APPLICABLE	63 Subpart S	40 CFR 63.453(g)	Monitoring – Steam Stripper	
APPLICABLE	63 Subpart S	40 CFR 63.453(i)	MACT Standards – Monitoring Condensates	
APPLICABLE	63 Subpart S	40 CFR 63.453(k)	MACT Standards – Monitoring – Closed Vent Systems	
APPLICABLE	63 Subpart S	40 CFR 63.453(l)	MACT Standards – Monitoring – Condensate Closed Collection	
APPLICABLE	63 Subpart S	40 CFR 63.453(m)	MACT Standards – CMS for Alternatives	
APPLICABLE	63 Subpart S	40 CFR 63.453(n)	MACT Standards – Monitoring – Parameter Monitoring	
APPLICABLE	63 Subpart S	40 CFR 63.453(o)	MACT Standards – Operating Parameter Ranges	
APPLICABLE	63 Subpart S	40 CFR 63.454	MACT Standards – Recordkeeping	
APPLICABLE	63 Subpart S	40 CFR 63.455	MACT Standards – Reporting	

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	63 Subpart S	40 CFR 63.457	Test Methods and Procedures	
APPLICABLE	63 Subpart S	40 CFR 63.962	MACT Standards – Subpart RR – Individual Drains	
APPLICABLE	63 Subpart S	40 CFR 63.963	MACT Standards – Subpart RR- Individual Drains	
APPLICABLE	62-204	62-204.800(7)(b)35.	Chapter 40, Code of Federal Regulations, Part 60, Standards of Performance for New Stationary Source	40 CFR 60, Subpart BB, Kraft Pulp Mills.
APPLICABLE	62-204	62-204.800(7)(c)	NSPS controls over other state rules.	
APPLICABLE	62-204	62-204.800(7)(d)	NSPS Subpart A adopted by reference.	
APPLICABLE	62-204	62-204.800(7)(e)	40 CFR 60 appendices adopted by reference.	
APPLICABLE	62-296 <	62-296.401(1)	Incinerators.	
NON-APPLICABLE	62-296 <	62-296.401(2)	Incinerators.	The Thermal Oxidizer has a charging rate of less than 50 tons/day.
NON-APPLICABLE	62-296 <	62-296.401(3)	Incinerators.	The Thermal Oxidizer has a charging rate of less than 50 tons/day.
NON-APPLICABLE	62-296 <	62-296.401(4)	Biological Waste Incineration Facilities.	No biological wastes are incinerated at this facility.
NON-APPLICABLE	62-296 <	62-296.401(5)	Human Crematories.	The facility does not have a human crematory.
NON-APPLICABLE	62-296 <	62-296.401(6)	Air Curtain Incinerators.	This is not an air curtain incinerator.
APPLICABLE	62-296 <	62-296.404	Kraft (Sulfate) Pulp Mills and Tall Oil Plants.	
NON-APPLICABLE	62-296 <	62-296.404(1)	Visible Emissions.	VE standards only apply to recovery furnaces.
NON-APPLICABLE	62-296 <	62-296.404(2)	Particulate Matter.	Particulate matter emissions standard only apply to recovery furnaces.
APPLICABLE	62-296 <	62-296.404(3)	Total Reduced Sulfur (TRS).	
APPLICABLE	62-296 <	62-296.404(3)(a)	Total Reduced Sulfur (TRS).	
APPLICABLE	62-296 <	62-296.404(3)(a)1.	Total Reduced Sulfur (TRS).	
NON-APPLICABLE	62-296 <	62-296.404(3)(a)2.	Total Reduced Sulfur (TRS).	Applies to sources with a means other than combustion to control TRS gases.
APPLICABLE	62-296 <	62-296.404(3)(a)3.	Total Reduced Sulfur (TRS).	
NON-APPLICABLE	62-296 <	62-296.404(3)(a)4.	Total Reduced Sulfur (TRS).	Applies to sources with a means other than combustion to control TRS gases.
NON-APPLICABLE	62-296 <	62-296.404(3)(b)	Total Reduced Sulfur (TRS).	Applicable only to tall oil plants.
NON-APPLICABLE	62-296 <	62-296.404(3)(c)	Total Reduced Sulfur (TRS).	Applicable only to recovery furnaces.

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
NON-APPLICABLE	62-296 <	62-296.404(3)(d)	Total Reduced Sulfur (TRS).	Applicable only to smelt dissolving tanks.
NON-APPLICABLE	62-296 <	62-296.404(3)(e)	Total Reduced Sulfur (TRS).	Applicable only to lime kilns and calciners.
APPLICABLE	62-296 <	62-296.404(3)(f)	Total Reduced Sulfur (TRS).	
APPLICABLE	62-296 <	62-296.404(4)	Test Methods and Procedures.	
NON-APPLICABLE	62-296 <	62-296.404(4)(a)	Test Methods and Procedures.	Applicable only to recovery furnaces.
NON-APPLICABLE	62-296 <	62-296.404(4)(b)	Test Methods and Procedures.	Applicable only to lime kilns and calciners.
NON-APPLICABLE	62-296 <	62-296.404(4)(c)	Test Methods and Procedures.	Applicable only to smelt dissolving tanks.
NON-APPLICABLE	62-296 <	62-296.404(4)(d)	Test Methods and Procedures.	Applicable only to tall oil plants.
APPLICABLE	62-296 <	62-296.404(4)(e)	Test Methods and Procedures.	
APPLICABLE	62-296 <	62-296.404(4)(f)	Test Methods and Procedures.	
APPLICABLE	62-296 <	62-296.404(5)	Continuous Emissions Monitoring Requirements.	
NON-APPLICABLE	62-296 <	62-296.404(5)(a)	Continuous Emissions Monitoring Requirements.	Applicable only to recovery furnaces.
NON-APPLICABLE	62-296 <	62-296.404(5)(b)	Continuous Emissions Monitoring Requirements.	This emissions unit is not required to have a CEM for TRS.
APPLICABLE	62-296 <	62-296.404(5)(c)	Continuous Emissions Monitoring Requirements.	
NON-APPLICABLE	62-296 <	62-296.404(5)(d)	Continuous Emissions Monitoring Requirements.	Surrogate parameters are not required to be measured for this emissions unit.
APPLICABLE	62-296 <	62-296.404(6)	Quarterly Reporting Requirements.	
APPLICABLE	62-296 <	62-296.404(6)(a)	Quarterly Reporting Requirements.	
APPLICABLE	62-296 <	62-296.404(6)(b)	Quarterly Reporting Requirements.	
APPLICABLE	62-296 <	62-296.404(6)(c)	Quarterly Reporting Requirements.	
NON-APPLICABLE	62-296 <	62-296.404(6)(c)1.	Quarterly Reporting Requirements.	Applicable only to recovery furnaces.
NON-APPLICABLE	62-296 <	62-296.404(6)(c)2.	Quarterly Reporting Requirements.	Applicable only to lime kilns and calciners.
APPLICABLE	62-296 <	62-296.404(6)(c)3.	Quarterly Reporting Requirements.	
APPLICABLE	62-296 <	62-296.404(6)(c)4.	Quarterly Reporting Requirements.	
APPLICABLE	62-296 <	62-296.404(6)(d)	Quarterly Reporting Requirements.	
APPLICABLE	62-297	62-297.310	General Compliance Test Requirements.	
APPLICABLE	62-297	62-297.401(1)(a)	Compliance Test Methods.	
APPLICABLE	62-297	62-297.401(16)	EPA Method 16 - Semicontinuous Determination of Sulfur Emissions from Stationary Sources - 40	

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
			CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(16)(a)	EPA Method 16A	
APPLICABLE	62-297	62-297.401(2)	EPA Method 2 - Determination of Stack Gas Velocity and Volumetric Flow Rate - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(3)	EPA Method 3 - Gas Analysis for Carbon Dioxide, Oxygen, Excess Air, and Dry Molecular Weight - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(4)	EPA Method 4 - Determination of Moisture Content in Stack Gases - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(5)	EPA Method 5 - Determination of Particulate Emissions from Stationary Sources - 40 CFR 60 Appendix A	
APPLICABLE	62-297	62-297.401(6)(c)	EPA Method 6 - Determination of Sulfur Dioxide Emissions from Stationary Sources - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(8)	EPA Method 8 - Determination of Sulfuric Acid Mist and Sulfur Dioxide Emissions from Stationary Sources - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(9)(a)	EPA Method 9 - Visual Determination of the Opacity of Emissions from Stationary Sources - 40 CFR 60 Appendix A.	

EU ID 039 Bark Hog Rule Applicability

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	62-296 <	62-296.320		
APPLICABLE	62-296 <	62-296.320(4)(b)	General Visible Emissions Standard	
APPLICABLE	62-296 <	62-296.320(4)(c)	Unconfined Emissions of Particulate Matter	
APPLICABLE	62-296 <	62-296.212(400)(6)	BACT for operation of bark hog	
APPLICABLE	62-296 <	62-296.320(4)(c) 1.3. & 4	No person shall cause, let, permit, suffer or allow the emissions of unconfined particulate matter from any activity, including vehicular movement; transportation of materials; construction, alteration, demolition or wrecking; or industrially related activities such as loading, unloading, storing or handling; without taking reasonable precautions to prevent such emissions.	

EU 043 Paper Machines Rule Applicability

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	40 CFR 63	40 CFR 63 Subpart S	MACT Standards -National Emission Standards for Hazardous Air Pollutants: Pulp and Paper Industry	
APPLICABLE	40 CFR 63	40 CFR 63.440(a)	Applicability-the rule applies to processes that produce pulp, paper, or paperboard. The mill operates five paper machines. No substantive requirements apply to paper machines.	
APPLICABLE	62-4	62-4.160	General Permit Conditions	
APPLICABLE	62-4	62-4.130	Plant Operation - Problems	
APPLICABLE	62-210	62-210	Stationary Sources – General Requirements	
APPLICABLE	62-210	62-210.300	Permits Required	
APPLICABLE	62-210	62-210.350	Public Notice and Comment	
APPLICABLE	62-296	62-296	Stationary Sources – Emissions Standards	
APPLICABLE	62-296	62-296.320	General Pollutant Emissions Limiting Standards	
APPLICABLE	62-297	62-297	Stationary Sources – Emissions Monitoring	
APPLICABLE	62-297	62-297.310	General Test Requirements	

EU 044 No. 7 Package Boiler Rule Applicability

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	60 Subpart Db	40 CFR 60.44b(a)(1)(ii)	NSPS Subpart Db	
APPLICABLE	60 Subpart Db	40 CFR 60.44b(h)	NSPS Subpart Db	
APPLICABLE	60 Subpart Db	40 CFR 60.44b(i)	NSPS Subpart Db	
APPLICABLE	60 Subpart Db	40 CFR 60.46b(a)	NSPS Subpart Db	
APPLICABLE	60 Subpart Db	40 CFR 60.46b(c)	NSPS Subpart Db	
APPLICABLE	60 Subpart Db	40 CFR 60.46b(e)(1)	NSPS Subpart Db	
APPLICABLE	60 Subpart Db	40 CFR 60.46b(e)(4)	NSPS Subpart Db	
APPLICABLE	60 Subpart Db	40 CFR 60.48b(b)	NSPS Subpart Db	
APPLICABLE	60 Subpart Db	40 CFR 60.48b(c)	NSPS Subpart Db	
APPLICABLE	60 Subpart Db	40 CFR 60.48b(d)	NSPS Subpart Db	
APPLICABLE	60 Subpart Db	40 CFR 60.48b(e)(2)	NSPS Subpart Db	
APPLICABLE	60 Subpart Db	40 CFR 60.48b(f)	NSPS Subpart Db	
APPLICABLE	60 Subpart Db	40 CFR 60.48b(g)(1)	NSPS Subpart Db	
APPLICABLE	60 Subpart Db	40 CFR 60.49b(a)(1)	NSPS Subpart Db	
APPLICABLE	60 Subpart Db	40 CFR 60.49b(a)(2)	NSPS Subpart Db	
APPLICABLE	60 Subpart Db	40 CFR 60.49b(a)(3)	NSPS Subpart Db	
APPLICABLE	60 Subpart Db	40 CFR 60.49b(b)	NSPS Subpart Db	
APPLICABLE	60 Subpart Db	40 CFR 60.49b(g)	NSPS Subpart Db	
APPLICABLE	60 Subpart Db	40 CFR 60.49b(h)(2)	NSPS Subpart Db	
APPLICABLE	60 Subpart Db	40 CFR 60.49b(i)	NSPS Subpart Db	
APPLICABLE	60 Subpart Db	40 CFR 60.49b(o)	NSPS Subpart Db	
APPLICABLE	62-210 <	62-210.700(1)	Excess Emissions	
APPLICABLE	62-210 <	62-210.700(4)	Excess Emissions	
APPLICABLE	62-210 <	62-210.700(5)	Excess Emissions	
APPLICABLE	62-210 <	62-210.700(6)	Excess Emissions	
APPLICABLE	62-296 <	62-296.406(2)		
APPLICABLE	62-296 <	62-296.406(3)		
APPLICABLE	62-297 <	62-297.310(1)		
APPLICABLE	62-297 <	62-297.310(2)		
APPLICABLE	62-297 <	62-297.310(3)		
APPLICABLE	62-297 <	62-297.310(4)	EPA Method 9	
APPLICABLE	62-297 <	62-297.310(5)		
APPLICABLE	62-297 <	62-297.310(6)(b)	EPA Method 9	

EU 045 Wide-web Flexographic Printers Rule Applicability

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	40 CFR 63	40 CFR 63.820	MACT Standards -National Emission Standards for Hazardous Air Pollutants: Printing and Publishing Industry	
APPLICABLE	40 CFR 63	40 CFR 63.820(a)	Applicability-the mill operates flexographic printers subject to this rule	
APPLICABLE	40 CFR 63	40 CFR 63.821	Designation of affected sources.	
APPLICABLE	40 CFR 63	40 CFR 63.821(b)	The mill shall apply no more than 400 kg per month, for every month, of organic HAP on the product and packaging wide-web flexographic printing presses; or 500 kg per month, for every month, of inks, coatings, varnishes, adhesives, primers, solvents, thinners, reducers, and other materials on product and packaging wide-web flexographic printing presses.	
APPLICABLE	40 CFR 63	40 CFR 63.829(e)	Recordkeeping	
NON-APPLICABLE	40 CFR 63	40 CFR 63.3300(a)	Any web coating line that is a product and packaging rotogravure or wide-web flexographic press which is included in the affected source under subpart KK, **is not** subject to the requirements of 40 CFR 63 Subpart JJJJ.	The Subpart JJJJ rules exempts web costing lines subject to the Subpart KK rules.

EU 046 Condensate Stripper System Rule Applicability

APPLICABLE STATUE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	62-204 <	62-204.800(7)(b)33	NSPS - Part 60, Subpart BB - adapted by reference	
APPLICABLE	62-296 <	62-296.404(3)(a)1	Kraft (Sulfate) Pulp Mills and Tall Oil Plants	
APPLICABLE	62-296 <	62-296.404(3)(a)3	Kraft (Sulfate) Pulp Mills and Tall Oil Plants	
APPLICABLE	62-296 <	62-296.404(6)(a)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants	
APPLICABLE	62-296 <	62-296.404(6)(b)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants	
APPLICABLE	62-296 <	62-296.404(6)(c)3	Kraft (Sulfate) Pulp Mills and Tall Oil Plants	
APPLICABLE	62-296 <	62-296.404(6)(c)4	Kraft (Sulfate) Pulp Mills and Tall Oil Plants	
APPLICABLE	62-296 <	62-296.404(6)(d)	Kraft (Sulfate) Pulp Mills and Tall Oil Plants	
APPLICABLE	40 CFR 63	40 CFR 63.443(a)(1)(i)	MACT Standards - LVHC system	
APPLICABLE	40 CFR 63	40 CFR 63.443(c)	MACT Standards - Closed Vent Systems	
APPLICABLE	40 CFR 63	40 CFR 63.443(d)(4)	MACT Standards - HAP Reduction in Lime Kiln or Boiler	
APPLICABLE	40 CFR 63	40 CFR 63.443(e)	MACT Standards - Excess Emissions	
APPLICABLE	40 CFR 63	40 CFR 63.446(b)	MACT Standards - Pulping Process Condensates	
APPLICABLE	40 CFR 63	40 CFR 63.446(c)	MACT Standards - Pulping Process Condensates	
APPLICABLE	40 CFR 63	40 CFR 63.446(d)	MACT Standards - Pulping Process Condensates	
APPLICABLE	40 CFR 63	40 CFR 63.446(e)	MACT Standards - Pulping Process Condensates	
APPLICABLE	40 CFR 63	40 CFR 63.446(f)	MACT Standards - Pulping Process Condensates	
APPLICABLE	40 CFR 63	40 CFR 63.446(h)	MACT Standards - Pulping Process Condensates	
APPLICABLE	40 CFR 63	40 CFR 63.450(i)	MACT Standards - Closed Vent Systems	

APPLICABLE STATUE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	40 CFR 63	40 CFR 63.453(i)	MACT Standards - Monitoring Condensates	
APPLICABLE	40 CFR 63	40 CFR 63.453(k)	MACT Standards - Monitoring Closed Vent Systems	
APPLICABLE	40 CFR 63	40 CFR 63.453(l)	MACT Standards - Monitoring Condensate Closed Collection	
APPLICABLE	40 CFR 63	40 CFR 63.453(m)	MACT Standards - CMS for Alternatives	
APPLICABLE	40 CFR 63	40 CFR 63.453(n)	MACT Standards - Monitoring Parameter Monitoring	
APPLICABLE	40 CFR 63	40 CFR 63.453(o)	MACT Standards - Operating Parameter Ranges	
APPLICABLE	40 CFR 63	40 CFR 63.454	MACT Standards - Recordkeeping	
APPLICABLE	40 CFR 63	40 CFR 63.454(b)	MACT Standards - Recordkeeping	
APPLICABLE	40 CFR 63	40 CFR 63.455	MACT Standards - Reporting	
APPLICABLE	40 CFR 63	40 CFR 63.455(a)	MACT Standards - Inspection Plan	
APPLICABLE	40 CFR 63	40 CFR 63.457	Test Methods and Procedures	
APPLICABLE	40 CFR 63	40 CFR 63.962	MACT Standards - Subpart RR - Individual Drains	
APPLICABLE	40 CFR 63	40 CFR 63.964	MACT Standards - Individual Drains	

EU 047 Brown Stock Washer System Rule Applicability

APPLICABLE STATUE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	40 CFR 63	63.440(a)(1)	Applicability	
APPLICABLE	40 CFR 63	63.440(b)(1)	Applicability	
APPLICABLE	40 CFR 63	63.440(d)(1)	Applicability	
APPLICABLE	40 CFR 63	63.440(g)	Applicability	
APPLICABLE	40 CFR 63	63.443(a)(1)	Standards for the Pulping System	
APPLICABLE	40 CFR 63	63.443(c)	Standards for the Pulping System	
APPLICABLE	40 CFR 63	63.443(d)(4)	MACT Standards - HAP Reduction in a Boiler or Lime Kiln	
APPLICABLE	40 CFR 63	63.443(e)(1)	Periods of Excess Emissions	
APPLICABLE	40 CFR 63	63.446(a)	Standards for the Pulping Process Condensates	
APPLICABLE	40 CFR 63	63.446(b)(4)	Standards for the Pulping Process Condensates	
APPLICABLE	40 CFR 63	63.446(c)	Standards for the Pulping Process Condensates	
APPLICABLE	40 CFR 63	63.446(d)	Standards for the Pulping Process Condensates	
APPLICABLE	40 CFR 63	63.446(e)	Standards for the Pulping Process Condensates	
APPLICABLE	40 CFR 63	63.446(f)	Standards for the Pulping Process Condensates	
APPLICABLE	40 CFR 63	63.446(h)	Standards for the Pulping Process Condensates	
APPLICABLE	40 CFR 63	63.446(i)	Standards for the Pulping Process Condensates	
APPLICABLE	40 CFR 63	63.450	Standards for Enclosures and Closed-Vent Systems	
APPLICABLE	40 CFR 63	63.453(a)	Monitoring Requirements	
APPLICABLE	40 CFR 63	63.453(i)	Monitoring Requirements	
APPLICABLE	40 CFR 63	63.453(k)	Monitoring Requirements	
APPLICABLE	40 CFR 63	63.453(l)	Monitoring Requirements	
APPLICABLE	40 CFR 63	63.453(m)	Monitoring Requirements	
APPLICABLE	40 CFR 63	63.453(n)	Monitoring Requirements	
APPLICABLE	40 CFR 63	63.453(o)	Monitoring Requirements	

APPLICABLE STATUE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	40 CFR 63	63.454(a)	Recordkeeping Requirements	
APPLICABLE	40 CFR 63	63.454(b)	Recordkeeping Requirements	
APPLICABLE	40 CFR 63	63.454(d)	Recordkeeping Requirements	
APPLICABLE	40 CFR 63	63.455(a)	Reporting Requirements	
APPLICABLE	40 CFR 63	63.455(b)	Reporting Requirements	
APPLICABLE	40 CFR 63	63.457(a)	Test Methods and Procedures	
APPLICABLE	40 CFR 63	63.457(c)	Test Methods and Procedures	
APPLICABLE	40 CFR 63	63.457(d)	Test Methods and Procedures	
APPLICABLE	40 CFR 63	63.457(e)	Test Methods and Procedures	
APPLICABLE	40 CFR 63	63.457(f)	Test Methods and Procedures	
APPLICABLE	40 CFR 63	63.457(g)	Test Methods and Procedures	
APPLICABLE	40 CFR 63	63.457(j)	Test Methods and Procedures	
APPLICABLE	40 CFR 63	63.457(m)	Test Methods and Procedures	
APPLICABLE	62-210	62-210.700	Excess Emissions	
APPLICABLE	62-296	62-296.310	General Test Requirements	
APPLICABLE	62-296	62-296.320(4)	General VE Limit	
APPLICABLE	62-296	62-296.410(1)(b)	Carbonaceous Fuel Burning Equipment	
APPLICABLE	62-296	62-296.410(3)	Test Methods and Procedures	
APPLICABLE	62-297	62-297.401(1)(a)	EPA Method 1 - Sample and Velocity Traverses for Stationary Sources	
APPLICABLE	62-297	62-297.401(2)	EPA Method 2 - Determination of Stack Gas Velocity and Volumetric Flow Rate	
APPLICABLE	62-297	62-297.401(3)	EPA Method 3 - Gas Analysis for Carbon Dioxide, Oxygen, Excess Air, and Dry Molecular Weight	
APPLICABLE	62-297	62-297.401(4)	EPA Method 4 - Determination of Moisture Content in Stack Gases	
APPLICABLE	62-297	62-297.401(5)	EPA Method 5 - Determination of Particulate Emissions from Stationary Sources	
APPLICABLE	62-297	62-297.401(6)	EPA Method 6 - Determination of Sulfur Dioxide	

APPLICABLE STATUE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
			Emissions from Stationary Sources	
APPLICABLE	62-297	62-297.401(9)(a)	EPA Method 9 - Visual Determination of the Opacity of Emissions from Stationary Sources	

EU 048 Oxygen Delignification System Rule Applicability

APPLICABLE STATUTE	RULE DESCRIP	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	40 CFR 63	40 CFR 63 Subpart S	MACT Standards -National Emission Standards for Hazardous Air Pollutants: Pulp and Paper Industry	
APPLICABLE	40 CFR 63	40 CFR 63.441	Definition of oxygen delignification system	
APPLICABLE	40 CFR 63	40 CFR 63.443(a)(1)(5)	At existing affected sources, the total HAP emissions shall be controlled	
APPLICABLE	40 CFR 63	40 CFR 63.450(b), (c), (d)	Standards for enclosures and closed-vent systems	
APPLICABLE	40 CFR 63	40 CFR 63.453	Monitoring requirements	
APPLICABLE	40 CFR 63	40 CFR 63.454	Recordkeeping requirements	
APPLICABLE	40 CFR 63	40 CFR 63.455	Reporting requirements	
APPLICABLE	40 CFR 63	40 CFR 63.457	Testing requirements	

EU 050 Converting Department Rule Applicability

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	40 CFR 63	63.443(d)(4)	MACT Standards -National Emission Standards for Hazardous Air Pollutants: Paper and Other Web Coating	
APPLICABLE	40 CFR 63	40 CFR 63.3320(b)(2)	No more than 4 percent of the mass of coating materials applied for each month.	
APPLICABLE	40 CFR 63	40 CFR 63.3320(b)(3)	Use formulation data to determine the organic HAP mass fraction of a coating material	
APPLICABLE	40 CFR 63	63.3360(a)	Determine the organic HAP or volatile matter and coating solids content of coating materials according to procedures in §63.3360(c) and (d). If applicable, determine the mass of volatile matter retained in the coated web or otherwise not emitted to the atmosphere according to §63.3360(g).	
APPLICABLE	40 CFR 63	40 CFR 63.3370(b)]	Each coating material applied at an existing affected source is applied as-purchased and contains no more than 0.04 kg organic HAP per kg coating material or 0.2 kg organic HAP per kg coating solids.	
APPLICABLE	40 CFR 63	40 CFR 63.3400	The first compliance report must cover the period beginning on the compliance date that is specified under 63.3330 and ending on June 30 or December 31, whichever date is the first date following the end of the calendar half immediately following the compliance date that is specified in 63.3330.	
APPLICABLE	40 CFR 63	63.3410(a)(1)(iv)	Maintain records of organic HAP content data on a monthly basis for the purpose of demonstrating compliance with the requirements of 63.3360(a)	

EU 051 Reciprocating Internal Combustion Engines Rule Applicability

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	40 CFR 60	40 CFR Subpart IIII	NSPS Standards of Performance for Stationary Compression Ignition Internal Combustion Engines	
APPLICABLE	40 CFR 60	40 CFR 60.4200	Applicability-the mill operates at least one new (post-7/1/06), less than 500 HP in size, subject to this rule	
NON-APPLICABLE	40 CFR 60	40 CFR 60.4202	Emission standards for stationary CI internal combustion engine manufacturers	Mill does not manufacture engines
APPLICABLE	40 CFR 60	40 CFR 60.4205	Emission standards for owners/operators of emergency engines	
APPLICABLE	40 CFR 60	40 CFR 60.4206	Length of time that emission standards must be met by owners/operators of emergency engines	
APPLICABLE	40 CFR 60	40 CFR 60.4207	Fuel requirements for owners/operators of emergency engines	
APPLICABLE	40 CFR 60	40 CFR 60.4209	Monitoring requirements for owners/operators of emergency engines	
APPLICABLE	40 CFR 60	40 CFR 60.4211	Compliance requirements for owners/operators of emergency engines	
APPLICABLE	40 CFR 60	40 CFR 60.4214	Notification, reporting and recordkeeping requirements for owners/operators of emergency engines	
APPLICABLE	40 CFR 60	40 CFR 60.4219	Definitions	

APPLICABLE STATUTE	RULE DESCRIPTION	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	40 CFR 63	40 CFR 63 Subpart ZZZZ	MACT Standards -National Emission Standards for Hazardous Air Pollutants: Stationary Reciprocating Internal Combustion Engines	
APPLICABLE	40 CFR 63	40 CFR 63.6585; 40 CFR 63.6590	Applicability-the mill operates a number of existing (pre-6/12/06) and new RICE units (post 6/12/06), all less than 500 HP in size, subject to this rule	
APPLICABLE	40 CFR 63	40 CFR 63.6595	Date of compliance for existing RICE units at mill is May 3, 2013; date of compliance for new RICE units at mill is 1/18/08 or upon date of startup if new unit is installed after 1/18/08.	
APPLICABLE	40 CFR 63	40 CFR 63.6602	Emission standards for existing RICE units less than 500 HP in size	
APPLICABLE	40 CFR 63	40 CFR 63.6605	General requirements	
POTENTIALLY APPLICABLE	40 CFR 63	40 CFR 63.6612	Compliance demonstration and performance testing requirements	
POTENTIALLY APPLICABLE	40 CFR 63	40 CFR 63.6620	Performance testing requirements	
APPLICABLE	40 CFR 63	40 CFR 63.6625	Operate and maintain the stationary RICE according to the manufacturer's emission-related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions	
APPLICABLE	40 CFR 63	40 CFR 63.6640	Demonstrate continuous compliance with the emission limitations and operating limitations	
APPLICABLE	40 CFR 63	40 CFR 63.6645	Notification requirements	
APPLICABLE	40 CFR 63	40 CFR 63.6645	Recordkeeping requirements	
APPLICABLE	40 CFR 63	40 CFR 63.6660	Format and availability of records to be maintained	
APPLICABLE	40 CFR 63	40 CFR 63.6675	Definitions	