



**FLORIDA DEPARTMENT OF
ENVIRONMENTAL PROTECTION**
Southeast District Office
400 North Congress Avenue, 3rd Floor
West Palm Beach, Florida 33401
561-681-6600

**RICK SCOTT
GOVERNOR**

**HERSCHEL T. VINYARD JR.
SECRETARY**

July 12, 2013

Sent by Electronic Mail – Received Receipt Requested
vince.munne@fpl.com

NOTICE OF ADMINISTRATIVELY CORRECTED PERMIT

In the Matter of a Request for Administrative Correction:

PERMITTEE

Florida Power and Light (PSL)
6501 South S.R. A1A
Jensen Beach, FL 34957

Project No. 1110071-012-AF
Administrative Correction to Permit No. 1110071-011-AF

Authorized Representative:

Mr. Vince Munne
Environmental Compliance

St. Lucie Nuclear Power Plant
St. Lucie County

Enclosed are Administratively Corrected Conditions to the Air FESOP Permit No. 1110071-011-AF, for the operation of the St. Lucie Nuclear Power Plant located in St. Lucie County at 6501 South Ocean Drive, Jensen Beach, St. Lucie County, Florida. This correction is issued pursuant to Rule 62-210.360, Florida Administrative Code (F.A.C.), and Chapter 403, Florida Statutes (F.S.). This change is made to correct an Emission Unit Number and SCC codes. This corrective action does not alter the effective dates of the existing permit.

This letter must be attached to the original permit and becomes part of that permit. The remaining provisions of the permit are not changed by this action and remain in effect.

The Department of Environmental Protection (Department) will consider the above-noted action final unless a timely petition for an administrative hearing is filed pursuant to Sections 120.569 and 120.57, F.S. Mediation under Section 120.573, F.S., will not be available for this proposed action.

A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative hearing in accordance with Sections 120.569 and 120.57, F.S. The petition must contain the information set forth below and must be filed (received) by the Agency Clerk in the Department's Office of General Counsel, 3900 Commonwealth Boulevard, MS #35, Tallahassee, Florida 32399-3000. Petitions filed by the permit applicant or any of the parties listed below must be filed within 14 (fourteen) days of receipt of this notice. Petitions filed by any other person must be filed within 14 (fourteen) days of receipt of this proposed action. A petitioner must mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention (in a proceeding initiated by another party) will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, F.A.C.

A petition that disputes the material facts on which the Permitting Authority's action is based must contain the following information: (a) The name and address of each agency affected and each agency's file or identification number, if known; (b) The name, address, and telephone number of the petitioner; the name, address and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the agency determination; (c) A statement of when and how each petitioner received notice of the agency action or proposed

NOTICE OF ADMINISTRATIVELY CORRECTED PERMIT

decision; (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate; (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the agency's proposed action; (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action including an explanation of how the alleged facts relate to the specific rules or statutes; and, (g) A statement of the relief sought by the petitioner, stating precisely the action the petitioner wishes the agency to take with respect to the agency's proposed action.

A petition that does not dispute the material facts upon which the Permitting Authority's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the permitting authority's final action may be different from the position taken by it in this notice. Persons whose substantial interests will be affected by any such final decision of the permitting authority on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Any party to this order (permit) has the right to seek judicial review of it under Section 120.68, F.S., by the filing of a Notice of Appeal, under Rule 9.110 of the Florida Rules of Appellate Procedure, with the Clerk of the Department in the Office of General Counsel, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida, 32399-3000 or with the Clerk of the Department of Environmental Protection Southeast District at 400 North Congress Avenue, 3rd Floor, West Palm Beach, Florida 33401; and, by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal.


The Notice of Appeal must be filed within thirty days from the date this notice is filed with the Clerk of the permitting authority.

Executed in West Palm Beach, Florida.



Jill S. Creech, P.E.
Southeast District Director

07/12/13
Date


JSC/JKS/JL/sdt/lh


CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this Notice of Administratively Corrected Permit or a link to these documents available electronically on a publicly accessible server, was sent by electronic mail with received receipt requested to the persons listed below:

- Mr. Vince Munne, FPL: vince.munne@fpl.com
- Mr. Jeffrey Zuczek, FPL: jeffrey.zuczek@fpl.com
- Ms. Katy Forney, U.S. EPA-Region 4: forney.kathleen@epamail.epa.gov
- Ms. Ana Oquendo, EPA-Region 4: oquendo.ana@epamail.epa.gov
- Ms. Barbara Friday, DEP-BAR: barbara.friday@dep.state.fl.us (for posting with U.S. EPA, Region 4)

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to §120.52(7), Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.



(Clerk)



(Date)

NOTICE OF ADMINISTRATIVELY CORRECTED PERMIT

To correct inaccuracies, conditions /requirements contained in permit No. 1110071-011-AF have been corrected as indicated below. ~~Strikethrough~~ is used to denote the deletion of text. Underlines are used to denote the addition of text. All changes are emphasized with red text.

1. The emission unit identification number EU004 was previously utilized for this facility. Therefore, all references to emission unit EU004 in permit number 1110071-011-AF shall be changed to EU005, and the description of EU005 changed to “Miscellaneous Reciprocating Engine Driven Equipment less than 600 hp”.

2. Specific Condition **A.6.** shall be corrected as follows:

A.6. Nitrogen Oxide (NOx) Monitoring: Fuel consumption will be totaled on a monthly basis for each of four~~four~~^{five} categories of engines. The four~~four~~^{five} categories are: Diesel Engines greater than 600 hp (SCC 2-02-004-01) ~~2-03-001-01~~, Diesel Engines less than 600 hp (SCC 2-02-001-02)~~2-02-004-01~~, ~~LP Rich Burn (SCC 2-02-002-53)~~, LPG/Propane engines (SCC 2-02-010-01)~~LP Lean Burn (SCC 2-02-002-54)~~, and Gasoline engines (SCC 2-03-003-01). A monthly NOx emissions total (tons) will be calculated for each category of engine using the latest AP-42 emission factors, unless more accurate data is available. The total NOx emissions will be calculated and tracked on a 12-month rolling total to determine compliance with the 99.4 ton limitation. [**Application No. 1110071-011-AF**]