REFERENCED ATTACHMENTS.

The Following Attachments Are Included for Applicant Convenience:

Table H, Permit History.
Table 1, Summary of Air Pollutant Standards and Terms.
Table 2, Summary of Compliance Requirements.
Time Sensitive Action Chart.

TABLE H

PERMIT HISTORY

E.U. ID No.	Description	Permit No.	Effective Date	Expiration Date	Project Type
All	Facility	1130014-001-AV	04/20/1999	04/20/2004	Initial Title V Operation
All	Facility	1130014-002-AV	02/11/1998	06/01/1998	Ownership Transfer
All	Facility Process Modification	1130014-003-AC	Withdrawn	N/A	Construction (Withdrawn)
All	Facility	1130014-004-AV	04/28/2005	10/28/2008	Renewal
All	Facility	1130014-005-AV	09/08/2009	09/08/2014	Renewal
All	Facility	1130014-006-AV	Withdrawn	N/A	Response to RAI for Project 1130014-005-AV
All	Facility	1130014-007-AV	Pending	12/10/2014	Renewal (concurrent with 1130014-008-AC)
All	Facility	1130014-008-AC	Pending	11/12/2014	Construction (increase flares SO_2 limit)

TABLE 1

SUMMARY OF AIR POLLUTANT STANDARDS AND TERMS

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description	Fuel(s)	Hrs/Yr	Pollutant Name	Standard Allowable Emissions	Equivalent Emissions*			Regulatory Citation(s)	See Permit Condition(s)
						lbs/hr Per unit	lbs/hr Both units	TPY Both units		
010	Flares		8760	SO_2	185.24 tons per rolling 12 months		42.29	185.24	40 CFR 50.4 and 75 FR 35520	A.3.
011	Boilers	NG		VE	20%, up to 40% for two min period/hr				Rule 62-296.406, F.A.C.	B.5.

TABLE 2

SUMMARY OF COMPLIANCE REQUIREMENTS

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description	Fuel(s)	Pollutant Name	Emission Monitoring[1]	Emission Control	Compliance Method EPA Method	Testing Time Frequency	Frequency Base Date [2]	Min. Compliance Test Duration	See Permit Condition(s)
010	Flares		Process Gas S			ASTM				A.11.
			SO_2			Recordkeeping				A.8.
011	Boilers	NG	VE			EPA Method 5	Once during permit cycle			B.13.
013	1000 HP RICE	NG			Work practice standards					C.4. & C.5.
013	160 HP emergency fire pump				Work practice standards					C.3. & C.5.

Air Permit Time Sensitive Action Chart

[If any of the time deadlines in the Air Permit Action List are inconsistent with a time deadline in a permit condition, the time deadline in the permit condition shall be followed.]

SOURCE	ACTION	DUE DATE	PERMIT CONDITION
Facility-Wide	Annual Operating Report [Rule 62-210.370(3), F.A.C.]	April 1 - annually	RR5.
Facility-Wide	EAOR Title V Annual Emissions Fee Invoice and Fee Payment [Rule 62-213.205, F.A.C.]	April 1 - annually	RR6.
Facility-Wide	Annual Statement of Compliance [Rules 62-213.440(3) and 62-213.900, F.A.C.]	Within 60 days after end of each CY; 60 days after submittal of transfer of responsibility; 60 days after permanent shutdown	RR.7
Facility-Wide	Permit Renewal Application	April 29, 2019	TV17
EU 010	On-Site Recordkeeping [Rule 62-213.440, F.A.C. and permit 0630011-008-AC] : • Daily quantities of salt water disposal fluids • Quantities and types of gas fed daily to each flare (including excess emissions • SO_2 emissions identifying the average hourly emissions per day and rolling 12 month • Hourly process gas feed for all days during which excess emissions occurred • Hourly average gas feed for the two-hour period preceding the excess emissions • Sulfur content of the process gas sent to each flare	At time of inspection	A.8., A.9., & A.11.
	Excess Emissions Notification from Malfunction exceeding the emission limits or emissions flared during startup and shutdown [Rule 62-4.130, F.A.C.]	Immediately	A.6.
	Excess Emission Report [Permit 1130014-005-AV]	30 days after end of each quarter	A.7.
EU 011	On-Site Recordkeeping of Fuel [Rule 62-4.070(3) F.A.C.]	At time of inspection	B.10.
	Excess Emissions Notification from malfunction [Rule 62-4.130, F.A.C.]	Immediately	B.9.
	Excess Emissions Malfunction Report [Rule 62-4.130 and 62-210.700(6), F.A.C.]	Quarterly, if requested by DEP	B.9.
	Compliance Test Notification [Rule 62-297.310(7), F.A.C.]	15 days prior to test	B.13.
	Compliance Test for Visible Emissions [Rule 62-297.310(7), F.A.C.]	Year before permit renewal	B.13.
EU013	On Site Recordkeeping Maintenance, Deviations, Malfunctions [40 CFR 63.6655]	At time of inspection	C.10, C.11., C.12., C.13., & C.14.
	Annual Report (emergency fire pump engine only)	March 31, 2016 and every year after by March 31 for each calendar year	C.15.b.

CY = Calendar Year
FFY = Federal Fiscal Year