



COMMISSION

Kevin Beckner
Victor D. Crist
Ken Hagan
Al Higginbotham

Lesley "Les" Miller, Jr.
Sandra L. Murman
Mark Sharpe

DIVISION DIRECTORS

Legal & Admin. Richard Tschantz, Esq.
Air Management Jerry Campbell, P.E.
Waste Management Hooshang Boostani, P.E.
Water Management Sam Elrabi, P.E.
Wetlands Management Scott Emery, Ph.D.

EXECUTIVE DIRECTOR

Richard D. Garrity, Ph.D.

ENVIRONMENTAL PROTECTION COMMISSION OF
HILLSBOROUGH COUNTY, as Delegated by

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION

NOTICE OF PERMIT

Mr. Michael Miller
Operations Manager
Buckeye Terminals, LLC
848 McCloskey Blvd.
Tampa, FL 33605

Dear Mr. Miller:

Enclosed is Permit Number 0570083-022-AC to construct three new pipelines that will be used to transport the petroleum products from ships and barges to Buckeye's storage tanks, issued pursuant to Section 403.087, Florida Statutes.

Any party to this order (permit) has the right to seek judicial review of the permit pursuant to Section 120.68, Florida Statutes, by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the EPC in the Legal Department at 3629 Queen Palm Dr., Tampa, Florida 33619; and by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 days from the date this Notice is filed with the clerk of the EPC.

Executed in Tampa, Florida.

Sincerely,

Richard D. Garrity, Ph.D.
Executive Director

RDG/LAW/law

An agency with values of environmental stewardship in a culture of fairness and cooperation

Roger P. Stewart Center

3629 Queen Palm Drive, Tampa, FL 33619 - (813) 627-2600 - www.epchc.org

An Affirmative Action / Equal Opportunity Employer



COMMISSION

Kevin Beckner
Victor D. Crist
Ken Hagan
Al Higginbotham

Lesley "Les" Miller, Jr.
Sandra L. Murman
Mark Sharpe

DIVISION DIRECTORS

Legal & Admin. Richard Tschantz, Esq.
Air Management Jerry Campbell, P.E.
Waste Management Hooshang Boostani, P.E.
Water Management Sam Elrabi, P.E.
Wetlands Management Scott Emery, Ph.D.

EXECUTIVE DIRECTOR

Richard D. Garrity, Ph.D.

PERMITTEE:

Buckeye Terminals, LLC
Tampa Terminal
848 McCloskey Boulevard
Tampa, FL 33605

PERMIT/CERTIFICATION

Permit No.: 0570083-022-AC
County: Hillsborough
Expiration Date: August 14, 2015
Project: New Ship/Barge Unloading Pipelines

This permit is issued under the provisions of Chapter 403, Florida Statutes, and Florida Administrative Code Rules 62-204, 62-210, 62-212, 62-296, 62-297, and 62-4. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the EPC and made a part hereof and specifically described as follows:

This permit authorizes the construction of three new pipelines that will be used to transport the petroleum products from ships and barges to Buckeye's storage tanks. The construction of the new pipelines includes the installation of 38 new valves and 64 new flanges. The facility receives gasoline, diesel, and additives by ship, truck, and pipeline. The gasoline received by pipeline can have a maximum MTBE content of 1.2% by weight. Denatured ethanol consisting of approximately 5% gasoline and 95% ethanol (ethyl alcohol) is received by ship or truck. The petroleum products are transferred and stored in a total of 13 fixed and floating roof storage tanks and then distributed into tanker trucks through the loading rack with three loading bays or through a pipeline.

The terminal also receives denatured ethanol by truck at the denatured ethanol truck station. The station has one truck unloading and loading arm and is located on a skid next to the truck loading rack. When denatured ethanol is unloaded from trucks, it is pumped to the storage tanks. Trucks unloading denatured ethanol are under negative pressure. The denatured ethanol truck station can also be used to load trucks with denatured ethanol that is pumped from the storage tanks. Only denatured ethanol is loaded into trucks at this station.

VOC emissions from the truck loading rack and from the loading of ethanol by truck are controlled by a refurbished John Zink Carbon Vapor Recovery Unit (VRU), Series No. S71294A, or a John Zink Company air assisted, Vapor Combustion Unit (VCU), Model No. S91634-702.

The facility is also subject to 40 CFR 63 Subpart BBBB - National Emission Standards for Hazardous Air Pollutants for Source Category: Gasoline Distribution Bulk Terminals, Bulk Plants, and Pipeline Facilities. This NESHAP has not been adopted by the State of Florida.

An agency with values of environmental stewardship in a culture of fairness and cooperation

Roger P. Stewart Center

3629 Queen Palm Drive, Tampa, FL 33619 - (813) 627-2600 - www.epchc.org

An Affirmative Action / Equal Opportunity Employer

PERMITTEE:
Buckeye Terminals, LLC

PERMIT/CERTIFICATION NO.: 0570083-022-AC
PROJECT: New Ship/Barge Unloading Pipelines


SPECIFIC CONDITIONS:

D) Installing an additional loading arm or storage tank.

*Not applicable to routine maintenance, repair, or replacement of component parts of an emission unit. The cost of replacement of component parts in an emissions unit shall count toward the fixed capital cost for reconstruction.

34. If the permittee wishes to transfer this permit to another owner, an "Application for Transfer of Permit" (DEP Form 62-210.900(7)) shall be submitted, in duplicate, to the Environmental Protection Commission of Hillsborough County within 30 days after the sale or legal transfer of the permitted facility. [Rule 62-4.120, F.A.C.]

ENVIRONMENTAL PROTECTION COMMISSION
OF HILLSBOROUGH COUNTY



Richard D. Garrity, Ph.D.
Executive Director