



COMMISSION
Kevin Beckner Lesley "Les" Miller, Jr.
Victor D. Crist Sandra L. Murman
Ken Hagan Mark Sharpe
Al Higginbotham

DIVISION DIRECTORS
Legal & Admin. Richard Tschantz, Esq.
Air Management Jerry Campbell, P.E.
Waste Management Hooshang Boostani, P.E.
Water Management Sam Elrabi, P.E.
Wetlands Management Scott Emery, Ph.D.

EXECUTIVE DIRECTOR
Richard D. Garrity, Ph.D.

ENVIRONMENTAL PROTECTION COMMISSION OF
HILLSBOROUGH COUNTY, as Delegated by

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION

NOTICE OF PERMIT ISSUANCE

CERTIFIED MAIL

David Shellhouse
Vice President, Southeastern Operations
Florida Gas Transmission Company (FGT)
2405 Lucien Way, Suite 200
Maitland, FL 32751

File No.: 0570438-014-AO
County: Hillsborough

Enclosed is Permit Number 0570438-014-AO for the operation of three Solar Saturn, Model No. T-1001S-312E, natural gas fired turbine compressor engines at Compressor Station No. 30, located at 2564 East Knights Griffin Road, Plant City, FL issued pursuant to Section 403.087, Florida Statutes. Please read this new permit thoroughly as there are changes from the previous permit.

The EPC will issue the final permit with the attached conditions unless a timely petition for an administrative hearing is filed pursuant to Section 120.569 and 120.57 F.S. before the deadline for filing a petition. The procedures for petitioning for a hearing are set forth below.

A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative proceeding (hearing) under Sections 120.569 and 120.57, F.S. The petition must contain the information set forth below and must be filed (received) in the Legal Department of the EPC at 3629 Queen Palm Drive, Tampa, Florida 33619, Phone 813-627-2600, Fax 813-627-2602. Petitions filed by the permit applicant or any of the parties listed below must be filed within 14 (fourteen) days of receipt of this notice of intent. Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), F.S. must be filed within 14 (fourteen) days of receipt of this permit. Under Section 120.60(3), however, any person who asked the EPC for notice of agency action may file a petition within 14 (fourteen) days of receipt of that notice, regardless of the date of publication.

An agency with values of environmental stewardship, integrity, honesty and a culture of fairness and cooperation

Roger P. Stewart Center
3629 Queen Palm Drive, Tampa, FL 33619 • (813) 627-2600 • www.epchc.org

An Affirmative Action/Equal Opportunity Employer




supporting materials, and all other materials available to the EPC that are relevant to the permit decision. Interested persons may contact Diana M. Lee, P.E., at the above address or call (813) 627-2600, for additional information.

Any party to this order has the right to seek judicial review of it under Section 120.68 of the Florida Statutes, by filing a notice of appeal under rule 9.110 of the Florida rules of Appellate Procedure with the EPC's Legal Office at 3629 Queen Palm Drive, Tampa, Florida 33619 and with the clerk of the Department of Environmental Protection in the Office of General Counsel, Mail Station 35, 3900 Commonwealth Boulevard, Tallahassee, Florida 32399-3000, and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate district court of appeal. The notice must be filed within thirty days after this order is filed with the clerk of the Department.

Executed in Tampa, Florida

ENVIRONMENTAL PROTECTION COMMISSION
OF HILLSBOROUGH COUNTY



Richard D. Garrity, Ph.D.
Executive Director

RDG/LAW/law

CERTIFICATE OF SERVICE

This is to certify that this NOTICE OF PERMIT and all copies were mailed before the close of business on 5/8/14 to the listed persons.

FILING AND ACKNOWLEDGEMENT FILED, on this date, pursuant to Section 120.52(7), Florida Statutes, with the clerk, receipt of which is hereby acknowledged.

Teresa Beckus 5/8/14
Clerk Date



COMMISSION

Kevin Beckner Lesley "Les" Miller, Jr.
Victor D. Crist Sandra L. Murman
Ken Hagan Mark Sharpe
Al Higginbotham

DIVISION DIRECTORS

Legal & Admin. Richard Tschantz, Esq.
Air Management Jerry Campbell, P.E.
Waste Management Hooshang Boostani, P.E.
Water Management Sam Elrabi, P.E.
Wetlands Management Scott Emery, Ph.D.

EXECUTIVE DIRECTOR
Richard D. Garrity, Ph.D.

PERMITTEE:

Florida Gas Transmission Company
2405 Lucien Way, Suite 200
Maitland, FL 32751

PERMIT/CERTIFICATION

Permit No: 0570438-014-AO
County: Hillsborough
Expiration Date: February 12, 2019
Project: Three Natural Gas Fired Turbine
Compressor Engines

This permit is issued under the provisions of Chapter 403, Florida Statutes, and Florida Administrative Code Rules 62-204, 62-210, 62-212, 62-296, 62-297, and 62-4. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans and other documents, attached hereto or on file with the EPC and made a part of hereof and specifically described as follows:

This permit authorizes the operation of Compressor Station No. 30, which consists of three Solar Saturn, Model No. T-1001S-312E, natural gas fired turbine compressor engines. The turbines are powered by natural gas supplied by the Florida Gas Transmission Company pipeline. The turbines are used to compress the natural gas in the pipeline in order to maintain a constant pressure for the transportation of the natural gas to customers throughout Florida. The turbine compressor engines are contained in an enclosed building in order to minimize the noise effects from the compressor engines. Turbine Nos. 3001 (EU 001) and 3002 (EU 002) have the same maximum heat input rate of 13.13 MMBtu/hr. Turbine No. 3003 (EU 003) has a maximum heat input rate of 15.76 MMBtu/hr.

Also onsite are miscellaneous support equipment which consists of two 250 gallon storage tanks that store oily water and pipeline condensate. The tanks are exempt from permitting pursuant to Rule 62-210.300(3)(b), F.A.C. In addition, there is one General Motors, 51.5 HP, emergency generator. The engine was manufactured prior to 2000 and is fired on natural gas. The emergency generator is exempt from permitting pursuant to Rule 62-210.300(3)(a)35., F.A.C., however, the generator is subject to 40 CFR 63 Subparts A and ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.

Emissions are minimized by limiting the type of fuel that can be combusted in the turbines to natural gas only, and limiting the sulfur and nitrogen content in the natural gas.

Location: 2564 East Knights Griffin Road, Plant City, FL 33565

UTM: 17-391.90E 3106.61N NEDS NO: 0438

An agency with values of environmental stewardship, integrity, honesty and a culture of fairness and cooperation

Roger P. Stewart Center
3629 Queen Palm Drive, Tampa, FL 33619 • (813) 627-2600 • www.epchc.org

An Affirmative Action/Equal Opportunity Employer




PERMITTEE:
Florida Gas Transmission Company

PERMIT/CERTIFICATION NO.: 0570438-014-AO
PROJECT: Three Natural Gas Fired Turbine Compressor
Engines

SPECIFIC CONDITIONS:

ENVIRONMENTAL PROTECTION COMMISSION
OF HILLSBOROUGH COUNTY



Richard D. Garrity, Ph.D.
Executive Director