J.8. Permittee shall take all appropriate actions to avoid outages; however, if they occur the Department shall be notified within 24 hours. Such notification shall include pertinent information as to the cause and what steps are being taken to correct the problem and to prevent its recurrence, such notification does not release Permittee from any liability for failure to comply with the Department's rules. A cumulative monthly record of outage hours shall be maintained during each calendar year. These records shall be maintained and available for Department inspection. All RTO outages shall be reported to the Department, per Rule 62-4.130, F.A.C. [Rules 62-210.700(4) & (6) and 62-4.130, F.A.C., and permit 0050001-018-AC]

{Permitting Note: The 216 hours per calendar year are in addition to the startup, shutdown or malfunction emissions allowed for no more than two hours in any 24-hour period allowed by the Department's Excess Emissions Rule (62-210.700(1), F.A.C.). The uncontrolled emissions emitted during these hours have been incorporated in the potential emission calculation for the RTO and were also incorporated in the PSD avoidance determination for this construction project. These emissions were requested because the air stripper (EU012) cannot be shut down, due to the applicability of OCPSF wastewater standards on the strippers. Therefore, the strippers must continue to operate when the RTO is off line. These uncontrolled 216 hours of emissions equate to approximately 4.512 tons of VOC per year.}

J.9. Compliance Assurance Monitoring. This emissions unit is subject to the Compliance Assurance Monitoring (CAM) requirements contained in the attached Appendix CAM. Failure to adhere to the monitoring requirements specified does not necessarily indicate an exceedance of a specific emissions limitation; however, it may constitute good reason to require compliance testing pursuant to Rule 62-297.310(7)(b), F.A.C. [40 CFR 64; Rules 62-204.800 and 62-213.440(1)(b)1.a., F.A.C.]

J.10. Determination of Process Variables. See the related testing provisions in Appendix TR, Facility-wide Testing Requirements. [Rule 62-297.310(5), F.A.C.]

Test Methods and Procedures

J.11. Test Methods. When required, tests shall be performed in accordance with the following reference methods:

Method	Description of Method and Comments
9	Visual Determination of the Opacity of Emissions from Stationary Sources
25A	Method for Determining Gaseous Organic Concentrations (Flame Ionization)

The above methods are described in 40 CFR 60, Appendix A, and adopted by reference in Rule 62-204.800, F.A.C. No other methods may be used unless prior written approval is received from the Department. [Rule 62-297.401(25)(a), F.A.C.]

J.12. Common Testing Requirements. Unless otherwise specified, tests shall be conducted in accordance with the requirements and procedures specified in Appendix TR, Facility-Wide Testing Requirements, of this permit. [Rule 62-297.310, F.A.C.]

J.13. Annual Compliance Tests Required. During each federal fiscal year (October 1st to September 30th), each EU shall be tested to demonstrate compliance with the emissions standards for visible emissions. [Rule 62-297.310(7), F.A.C.]

J.14. Compliance Tests Prior To Renewal. Compliance tests shall be performed for VOC once every 5 years. The testing shall be scheduled within 12 months of the facility's Title V permit renewal application due date so the results can be included with the submission of the application. Notification of compliance testing and completed test reports may be submitted by electronic mail to nwdair@dep.state.fl.us. [Rules 62-210.300(2)(a) and 62-297.310(7)(a), F.A.C.]

J.15. Additional Compliance Test Requirements. The VOC test shall be conducted on the inlet and outlet of the oxidizer to verify the 96% destruction efficiency and demonstrate compliance with emissions standards for VOC. [Rule 62-4.070(3), F.A.C., and permit 0050001-018-AC.]