Table 2, Summary of Compliance Requirements

Orlando Utilities Commission
Indian River Plant

Permit # 0090008-005-AV
Facility ID # 0090008

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 005, 006 **Combustion Turbines C and D**

Pollutant/ Parameter	Fuel	Compliance Method	Frequency of Sampling	Frequency Base Date *	Min. Compliance Test Duration	CMS	Permit Condition
SO2	#2 oil gas	Fuel sampling & analysis	After each fuel oil shipment	Per 40 CFR 60.335			C.8.
VE	#2 oil gas	EPA Method 9	annual	20-Jan			C.8.
CO	#2 oil gas	EPA Method 10	annual	20-Jan			C.8.
NOx	#2 oil gas	EPA Method 20**	annual	20-Jan			C.8.
PM/PM10	#2 oil gas	EPA Method 5	renewal				
VOC SAM		EPA Method 18 EPA Method 8	renewal renewal				C.8. C.8.

Notes:

*Frequency base date established for planning purposes only; see Rule 62-297.310, F.A.C.

**With ASP for revised Method 1

*** Compliance with total VOC emission limits will be assumed, provided the CO allowable emission rate is achieved. PSD-FL-173