Table 1, Summary of Air Pollutant Standards

Orlando Utilities Commission
Indian River Plant

Permit # 0090008-005-AV
Facility ID # 0090008

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 005, 006 **Combustion Turbines C and D**

			Allowable Emissions					See Permit
Pollutant/Parameter	Fuel	Hours/Year	Standard	TPY/unit	TPY/2 units	lbs./hour / unit	Regulatory Citations	Condition
SO2	Gas	4,380	0.3% Sulfur Fuel	1.05	2.10	0.5	PSD-FL-173	B.9.
	Oil		0.3% Sulfur Fuel	476.5	953	217.6		
NOx	Gas		25 ppm@15% O2	295.75	591.5	135.0	PSD-FL-173	B.10.
	Oil		42 ppm@15% O2	253	506	115.5		
VE	Gas		10% opacity				AC 05-193720	B.9.
	Oil		10% opacity					
PM/PM10	Gas		0.003 lb/MMBtu	9.75	19.5	4.5		B.9.
	Oil		0.08 lb/MMBtu	118.5	237	54.1		
CO	Gas		25 ppmvd	156.5	313	71.5		B.9.
	Oil		25 ppmvd	79.5	159	36.3		
VOC	Gas		5 ppmvd	18.5	37	8.4		B.9.
	Oil		15 ppmvd	56	112	25.6		
Sulfuric Acid Mist	Gas			0.035	0.07	0.02		B.9.
	Oil			14.25	28.5	6.5		