Table 2, Summary of Compliance Requirements

Orlando Utilities Commission
Indian River Plant

Permit # 0090008-005-AV
Facility ID # 0090008

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 004, 007 Combustion Turbines A and B

Pollutant/ Parameter	Fuel	Compliance Method	Frequency of Sampling	Frequency Base Date *	Min. Compliance Test Duration	CMS**	Permit Condition
SO2	#2 oil gas	Fuel sampling & analysis	Daily sampling of as-fired fuel	Per 40 CFR 60.334(b)			C.8.
VE	#2 oil	EPA Method 9	annual	20-Jan			C.8.
NOx	#2 oil gas	EPA Method 20	annual	20-Jan			C.8.

Notes:
*Frequency base date established for planning purposes only; see Rule 62-297.310, F.A.C.
**CMS = continuous monitoring system