Table 1, Summary of Air Pollutant Standards

Orlando Utilities Commission
Indian River Plant

Permit # 0090008-005-AV
Facility ID # 0090008

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 004, 007 **Combustion Turbines A and B**

			Allowable Emissions			Equivalent Emissions*			See Permit
Pollutant/Parameter	Fuel	Hours/Year	lbs/hour/unit	TPY/unit	TPY/2 units	lbs./hour	TPY	Regulatory Citations	Condition
SO2	Gas	8,760	0.34	1.5	3-			PSD-FL-130	A.7.
	Oil		143	625	1250	285.4	1250		
NOx	Gas		75	329	658			PSD-FL-130	A.7.
	Oil		118	518	1037	237	1037		
VE	Gas		5% opacity				n/a	PSD-FL-130	A.8.
	Oil		10% opacity						

Notes: ** -- Annual emissions (TPY) based on 3 hours per day at 0.3 lb/mmBtu and 21 hours per day at 0.1lb/MMBtu.
* -- Equivalent Emissions provided for information only.