Table 1, Summary of Air Pollutant Standards and Terms

Florida Power and Light Company
Port Everglades Plant

Draft/Proposed Permit No. 0110036-011-AV
Facility ID No. 0110036

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
005	Simple Cycle Combustion Turbines, GT 1 - GT 12

The following apply to each individual unit, unless otherwise specified.

Pollutant Name or Parameter	Fuel(s)	Hours/Year	Allowable Emissions Standard(s)	lbs./hour	TPY	Equivalent Emissions* lbs./hour	Equivalent Emissions* TPY	Regulatory Citation(s)	See permit condition(s)
VE	natural gas, No. 2 fuel oil and/or Jet A	8,760	< 20%			N/A	N/A	Rule 62-296.320(4)(b)1., F.A.C.	III.A.5.
NOx	No. 2 fuel oil and/or Jet A	8,760	0.90 lb/MMBtu			7581.6**	33207**	Rule 62-296.570(4)(b)5., F.A.C.	III.A.6.
NOx	natural gas	8,760	0.50 lb/MMBtu			4212**	18449**	Rule 62-296.570(4)(b)5., F.A.C.	III.A.6.

Notes:
* The "Equivalent Emissions" listed are for informational purposes only.
** The values are the combined total from the bank of 12 CTs.
N/A represents not applicable.