Table 2, Summary of Compliance Requirements

Florida Power and Light Company
Port Everglades Plant

Draft/Proposed Permit No. 0110036-011-AV
Facility ID No. 0110036

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	**Brief Description**
005	Simple Cycle Combustion Turbines, GT 1 - GT 12

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
VE	natural gas, No. 2 fuel oil and/or Jet A	EPA Method 9	annual ***		30-minute test	No	III.A.9.-12.
NOx	natural gas, No. 2 fuel oil and/or Jet A	EPA Method 7E, 19 and/or 20	renewal ***		3 1-hour test runs	No	III.A.9.-12.

Notes:
* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
**CMS [=] continuous monitoring system
N/A represents not applicable.
*** see the specific conditions in the permit.