Table 2, Summary of Compliance Requirements

Wheelabrator South Broward, Inc. — Permit No. **0112119-015-AV**

South Broward Waste-to-Energy Facility — Facility ID No. 0112119

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E. U. ID No.	Brief Description	Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date	Min. Compliance Test Duration	CMS[1]	See Permit Condition(s)
001	Municipal Solid Waste (MSW)	VE	MSW	EPA Method 9	Annually		30 minutes	Yes	**A.29.**
002	Combustors	VE- Fugitive Ash		EPA Method 22	Annually		1 hour	No	**A.29.**
003	(192,000 lbs/hr - steam)	PM							**A.29.**
	(863 TPD - MSW)	PM_{10}	MSW	EPA Method 5	Annually		1 hour	No	**A.29.**
	(323.6 MMBtu/hour - MSW)	CO	MSW	EPA Method 10, 10A, 10B	Daily		1 hour	Yes	**A.29.**
		NO_X	MSW	EPA Method 19	Daily		1 hour	Yes	**A.29.**
		SO_2	MSW	EPA Method 19	Daily		1 hour	Yes	**A.29.**
		HCl	MSW	EPA Method 26, 26A	Annually		1 hour	No	**A.29.**
		dioxin/furan	MSW	EPA Method 23	Annually[2]		N/A	No	**A.29.**
		Cd	MSW	EPA Method 29	Annually		1 hour	No	**A.29.**
		Hg	MSW	EPA Method 29 or 101A	Annually		1 hour	No	**A.29.**
		Pb	MSW	EPA Method 29 or 12	Annually		1 hour	No	**A.29.**
		Be	MSW	EPA Method 29	Every 5 years		N/A	No	**A.29.**
		Fl	MSW	EPA Method 13A, 13B	Every 5 years		1 hour	No	**A.29.**
004	Lime Silo	VE		EPA Method 9	Annually		30 minutes	No	**B.10**
		PM		EPA Method 5	Every 5 years[3]		1 hour	No	**B.10.**
005	Ash Handling	VE		EPA Method 22	Annually		1 hour	No	**B.10.**

Notes:

1. CMS [=] continuous monitoring system used for monitoring requirement in lieu of fuel sampling and analysis if marked 'yes'.
   (Acceptable as long as CMS is maintained and calibrated as required.)
2. Test at least one unit annually, subject to 40 CFR 60.38b(b) and 40 CFR 60.58b(g) requirements.
3. Particulate matter tests are not required unless visible emissions tests indicate standards have been violated.