P.E. CERTIFICATION STATEMENT

PERMITTEE

Florida Power & Light Company (FPL)
700 Universe Boulevard
Juno Beach, Florida 33408

Air Permit No. 0250003-016-AC
Permit Expires: 07/01/2014
Minor Air Construction Permit

Turkey Point
Revision to Construction Permit

PROJECT DESCRIPTION

This permit revision makes minor changes to a previous construction permit, (0250003-008-AC) which applied Best Available Retrofit Technology (BART). This revision is to account for Unit 2 being shut down and placed on inactive reserve for an extended period. Units 1 & 2 are each 440 MW gas and oil fired boilers subject to the particulate and sulfur dioxide emission controls which meet BART requirements. In the event Unit 2 is taken off the inactive reserve status and begins operation, this revision specifies that only natural gas should be used until the new BART controls for particulates are installed on this unit.

This project is subject to the general preconstruction review requirements in Rule 62-212.300, Florida Administrative Code (F.A.C.) and is not subject to the preconstruction review requirements for major stationary sources in Rule 62-212.400, F.A.C. for the Prevention of Significant Deterioration (PSD) of Air Quality.

I HEREBY CERTIFY *that the air pollution control engineering features described in the above referenced application and subject to the proposed permit conditions provide reasonable assurance of compliance with applicable provisions of Chapter 403, Florida Statutes, and Florida Administrative Code Chapters 62-4 and 62-204 through 62-297. However, I have not evaluated and I do not certify any other aspects of the proposal (including, but not limited to, the electrical, civil, mechanical, structural, hydrological, geological, and meteorological features).*

_____ _____

Martin Costello, P.E. (Date)
Registration Number 47587