Appendix U-1: List of Unregulated Emissions Units and/or Activities.

Miami-Dade Water and Sewer Department FINALPermit No.: 0250314-017-AV
Alexander Orr Jr. Water Treatment Plant Facility ID No.: 0250314

Unregulated Emissions Units and/or Activities. An emissions unit which emits no "emissions-limited pollutant" and which is subject to no unit-specific work practice standard, though it may be subject to regulations applied on a facility-wide basis (e.g., unconfined emissions, odor, general opacity) or to regulations that require only that it be able to prove exemption from unit-specific emissions or work practice standards.

The below listed emissions units and/or activities are neither 'regulated emissions units' nor 'insignificant emissions units'.

E.U. ID No.	Brief Description of Emissions Units and/or Activity
005	Engine driving pump rated at 1,500 hp fired with diesel fuel
006	Engine driving pump rated at 2,113 hp fired with diesel fuel or natural gas
018	Natural Gas Engine Driven Pump, Caterpillar Model G3512 LE-130. Pump # 3
019	Natural Gas Engine Driven Pump, Caterpillar Model G3512 LE-130 Pump # 4
021	Backup lime kiln generator rated at 250 kW
022	Railcar lime Unloading Rack