Appendix I-1: List of Insignificant Emissions Units and/or Activities.

The facilities, emissions units, or pollutant-emitting activities listed in Rule 62-210.300(3)(a), F.A.C., Categorical Exemptions, or that meet the criteria specified in Rule 62-210.300(3)(b)1., F.A.C., Generic Emissions Unit Exemption, are exempt from the permitting requirements of Chapters 62-210, 62-212 and 62-4, F.A.C.; provided, however, that exempt emissions units shall be subject to any applicable emission limiting standards and the emissions from exempt emissions units or activities shall be considered in determining the potential emissions of the facility containing such emissions units. Emissions units and pollutant-emitting activities exempt from permitting under Rules 62-210.300(3)(a) and (b)1., F.A.C., shall not be exempt from the permitting requirements of Chapter 62-213, F.A.C., if they are contained within a Title V source; however, such emissions units and activities shall be considered insignificant for Title V purposes provided they also meet the criteria of Rule 62-213.430(6)(b), F.A.C. No emissions unit shall be entitled to an exemption from permitting under Rules 62-210.300(3)(a) and (b)1., F.A.C., if its emissions, in combination with the emissions of other units and activities at the facility, would cause the facility to emit or have the potential to emit any pollutant in such amount as to make the facility a Title V source.

The below listed emissions units and/or activities are considered insignificant pursuant to Rule 62-213.430(6), F.A.C.

Brief Description of Emissions Units and/or Activities

1. Lime Feeders (6) gravimetric belt type 2,083 lb/hr each.
2. Diesel Fuel Oil Storage Tanks, 360,000 gallons total capacity.
3. Diesel Fuel Oil Storage Tanks (day tank at pump room), 1000 gallons.
4. LPG Storage Tank for Kiln Backup Engine (Auxiliary Motor), 500 gallons.
5. Aboveground Waste Oil Tank, (300 gallons).
6. Lime Solids Discharge Screw, Bucket Elevator and Screw Conveyor, 5 ton/hr.
7. Lime Storage Bins, (3) Chemical House No. 1, 1,050 tons.
8. Lime Storage Bins, (3) Chemical House No. 2, 1,050 tons.
9. Lime Transfer from truck loading chute from silos at lime plant.
10. Exhaust Units (Chemical House No. 1).
11. Exhaust Units (Chemical House No. 2).
12. Kiln Backup Engine (Auxiliary Motor).
13. Emergency Diesel Engine Driven Starting Air Compressor-Hatz-2M40LZ.
14. Emergency Diesel Engine Driven Starting Air Compressor-Lister H15TX20.
15. Two 1,050 tons each lime silos.
16. Relocatable emergency generators stored and maintained for off-site use.
17. Relocatable engine-driven pumps used temporarily for emergencies and/or facility maintenance or repair.
18. Relocatable engine-driven generators used temporarily for emergencies and/or facility maintenance and repair.