The compliance plan is required according to Rule 62-213.405, F.A.C. to bring the standby diesel fueled Compression Ignition (CI) Reciprocating Internal Combustion Engine (RICE) driven electrical generators (E.U. Nos. 013, 014, 015, 019, and 020) at the facility into compliance with the requirements of Subpart ZZZZ.

Compliance Schedule for Installation and Testing of Oxidation Catalysts on EMD model Nos. 20-645E4 (EUs 013, 014, and 015 and 20-645F4B (EUs 019, and 020)	
Activity	On or Before
Notify Department when Installation of Oxidation Catalysts on 1st EMD EU Commences	March 1
Notify Department when Installation of Oxidation Catalysts on 1st EMD EU is completed	Within 5 days after completion
Notify Department when Installation of Oxidation Catalysts on 2nd EMD EU is completed	Within 5 days after completion
Notify Department when Installation of Oxidation Catalysts on 3rd EMD EU is completed	Within 5 days after completion
Notify Department when Installation of Oxidation Catalysts on 4th EMD EU is completed	Within 5 days after completion
Notify Department when Installation of Oxidation Catalysts on 5th EMD EU is completed	Within 5 days after completion
Complete Installation of Oxidation Catalysts on all five EMD EUs	May 1, 2015
Complete Initial Compliance Demonstration Performance Tests of all five EMD EUs	June 1, 2015
Submit Initial Compliance Demonstration Performance Test Reports	Within 60 days of Test Completion

The facility shall provide monthly status reports, due the 15th day of each month, and notify the department immediately if it is discovered that a milestone will not be met as described above.

The responsible official shall notify the Department in writing, within 15 days after the date for completion of each milestone, detailing the achievement of compliance, of progress achieved, requirements met or unmet, corrective measures adopted, and an explanation of any measures not met by the completion date for the compliance milestone. The responsible official shall certify that such notice is complete and accurate. Any deviation from the compliance plan shall constitute a violation of the permit condition and shat be subject to the provisions of paragraph 62-213.300(2)(d), F.A.C.