TABLE 1

SUMMARY OF AIR POLLUTANT STANDARDS AND TERMS

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID Nos.	Brief Description	Fuels	Hrs/Yr	Pollutant Name	Standard Allowable Emissions	Equivalent Emissions		Regulatory Citations	See Permit Conditions
						lbs/hr Each unit	TPY Each unit		
004, 005, and 006	Boilers	No. 2 Fuel Oil & Natural Gas	8,760	VE	20% except ≤ 27% 6 min/hr			Rule 62-296.406(1), F.A.C.	C.4.
				SO_2	0.10% by weight sulfur		[1]13.01	1050002-005-AC	C.5.

Notes:
[1] Equivalent Emissions are based on the maximum heat input of 29.05 MMBtu/hour and operating 8,760 hours/year and are for informational purposes only.