Table 1-1, Summary of Air Pollutant Standards and Terms

BAPTIST MEDICAL CENTER
PRUDENTIAL DRIVE FACILITY

DRAFT PERMIT NO.: 0310010-008-AV
FACILITY ID NO.: 0310010

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.
Note: The "Equivalent Emissions" listed are for informational purposes only.

				Allowable Emissions			Equivalent Emissions*			
Eu ID No.	Pollutant Name	Fuel(s)	Hours/Year	Standard(s)	lbs./hour	TPY	lbs./hour	TPY	Regulatory Citation(s)	See permit condition(s)
# 005	NOx	GAS	8760	STD=0.0150 x (14.4/Y) + F			41.86	183.35	40 CFR 60.332	III, 005, 4.
	SO2	GAS		1 GR S PER 100 FT3 BURNED				0.46	Applicant's Request	III, 005, 6.
	SO2	OIL		0.015 % BY VOL. AT 15% O2, DRY				2.58	40 CFR 60.333(a)	III, 005, 5.
	VE			15 % OPACITY					62-4.070, FAC	III, 005, 7.
# 012	NOx	GAS	8760	STD=0.0150 x (14.4/Y) + F			37.91	166.05	40 CFR 60.332	III, 012, 4.
	SO2	GAS		1 GR S PER 100 FT3 BURNED				0.48	Applicant's Request	III, 012, 6.
	SO2	OIL		0.015 % BY VOL. AT 15% O2, DRY				2.67	40 CFR 60.333(a)	III, 012, 5.
	VE			15 % OPACITY					62-4.070, FAC	III, 012, 7.
# 013	NOx	GAS	8760	STD=0.0150 x (14.4/Y) + F			44.53	195.04	40 CFR 60.332	III, 013, 4.
	SO2	GAS		1 GR S PER 100 FT3 BURNED				0.57	Applicant's Request	III, 013, 6.
	SO2	OIL		0.015 % BY VOL. AT 15% O2, DRY				3.15	40 CFR 60.333(a)	III, 013, 5.
	VE			15 % OPACITY					62-4.070, FAC	III, 013, 7.
#015	PM		8760	0.05% S FUEL			0.37	1.64	62-296.406(3), FAC	III, 015, 5.
	SO2			0.05% S FUEL			2.06	9.03	62-296.406(2), FAC	III, 015, 5.
	VE			TWENTY (20) % OPACITY; 27%, 6 MIN/HR					40 CFR 60.43c	III, 015, 6.
#016	PM		8760	0.05% S FUEL			0.37	1.64	62-296.406(3), FAC	III, 016, 5.
	SO2			0.05% S FUEL			2.06	9.03	62-296.406(2), FAC	III, 016, 5.
	VE			TWENTY (20) % OPACITY; 27%, 6 MIN/HR					40 CFR 60.43c	III, 016, 6.
#017	VE			20% OPACITY					62-296.406(1), FAC	III, 017, 7.
	0310010-008sum1-AV.XLS									