**Table 2-1, Summary of Compliance Requirements**

**BAPTIST MEDICAL CENTER**
**PRUDENTIAL DRIVE FACILITY**

**DRAFT Permit No.: 0310010-008-AV**
**Facility ID No.: 0310010**

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.
Notes: * The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
**CMS [=] continuous monitoring system

| EU ID No. | Pollutant Name or Parameter | Fuel(s) | Compliance Method | Testing Time Frequency | Frequency Base Date * | Min. Compliance Test Duration | CMS** | See permit condition(s) |
|---|---|---|---|---|---|---|---|---|
| # 005 | NOx | Gas | EPA RM 20 | Annually | 2/1/2010 | | | III, 005, 8. |
| | SO2 & NOx | Oil | EPA RM 20 | Upon Request | | | | III, 005, 8. |
| | S.C. | Gas | SUPPLIER CERT. | 6 Months | | | | III, 005, 12 |
| | S.C. | Oil | SUPPLIER CERT. | Each Shipment | | | | III, 005, 11 |
| | VE | | EPA RM 9 | Annually | | 30 Minutes | | III, 005, 9. |
| # 012 | NOx | Gas | EPA RM 20 | Annually | 2/1/2010 | | | III, 012, 8. |
| | SO2 & NOx | Oil | EPA RM 20 | Upon Request | | | | III, 012, 8. |
| | S.C. | Gas | SUPPLIER CERT. | 6 Months | | | | III, 012, 12. |
| | S.C. | Oil | SUPPLIER CERT. | Each Shipment | | | | III, 012, 11 |
| | VE | | EPA RM 9 | Annually | | 30 Minutes | | III, 012, 9. |
| # 013 | NOx | Gas | EPA RM 20 | Annually | 2/1/2010 | | | III, 013, 8. |
| | SO2 & NOx | Oil | EPA RM 20 | Upon Request | | | | III, 013, 8. |
| | S.C. | Gas | SUPPLIER CERT. | 6 Months | | | | III, 013, 12. |
| | S.C. | Oil | SUPPLIER CERT. | Each Shipment | | | | III, 013, 11 |
| | VE | | EPA RM 9 | Annually | | 30 Minutes | | III, 013, 9. |
| #014 | Natural Gas Usage | | Recordkeeping | Daily | | | | III, 014, 6. |
| #015 | VE | | EPA RM 9 | Annually | 2/1/2010 | ONE (1) HOUR | | III, 015, 7. and 8. |
| | S.C. | Oil | SUPPLIER CERT. | Each Shipment | | | | III, 015, 9. |
| | Fuel combusted | gas, oil | Recordkeeping | Monthly | | | | III, 015, 10. |
| #016 | VE | | EPA RM 9 | Annually | 2/1/2010 | ONE (1) HOUR | | III, 016, 7. and 8. |
| | S.C. | Oil | SUPPLIER CERT. | Each Shipment | | | | III, 016, 9. |
| | Fuel combusted | gas, oil | Recordkeeping | Monthly | | | | III, 016, 10. |
| #017 | VE | | EPA RM 9 | Prior to Expiration | 2/1/2010 | ONE (1) HOUR | | III, 017, 8. and 9. |
| | Natural Gas Usage | | Recordkeeping | Monthly | | | | III, 017, 10. |

S.C. = SULFUR CONTENT

0310010-008sum2-AV.xls