Appendix I-1, List of Insignificant Emission Units and/or Activities

Baptist Medical Center
Prudential Drive Facility
Full Care Medical Center

FINAL Permit No.: 0310010-008-AV
Facility ID No.: 0310010

The facilities, emissions units, or pollutant-emitting activities listed in Rule 62-210.300(3)(a), FAC, Categorical Exemptions, or that meet the criteria specified in Rule 62-210.300(3)(b)1., FAC, Generic Emissions Unit Exemption, are exempt from the permitting requirements of Chapters 62-210, 62-212 and 62-4, FAC; provided, however, that exempt emissions units shall be subject to any applicable emission limiting standards and the emissions from exempt emissions units or activities shall be considered in determining the potential emissions of the facility containing such emissions units. Emissions units and pollutant-emitting activities exempt from permitting under Rules 62-210.300(3)(a) and (b)1., FAC, shall not be exempt from the permitting requirements of Chapter 62-213, FAC, if they are contained within a Title V source; however, such emissions units and activities shall be considered insignificant for Title V purposes provided they also meet the criteria of Rule 62-213.430(6)(b), FAC. No emissions unit shall be entitled to an exemption from permitting under Rules 62-210.300(3)(a) and (b)1., FAC, if its emissions, in combination with the emissions of other units and activities at the facility, would cause the facility to emit or have the potential to emit any pollutant in such amount as to make the facility a Title V source.

The below listed emissions units and/or activities are considered insignificant pursuant to Rule 62-213.430(6), FAC.

Brief Description of Emissions Units and/or Activities

Fire Pump [No.2 fuel oil fired], 275 gallon storage tank

Main Hospital Emergency Generator [1,250 kw, No.2 fuel oil fired], 8,000 gallon storage tank

Wolfson Children's Hospital Emergency Generator [2,000 kw, No.2 fuel oil fired], 20,000 gallon storage tank

New Tower Emergency Generator [2,000 kw, No. 2 fuel oil fired]

Pavilion Emergency Generator [500 kw, No.2 fuel oil fired], 2,000 gallon storage tank

Outpatient Center Emergency Generator [600 kw, No.2 fuel oil fired], 400 gallon storage tank

20,000 Gallon Aboveground Fuel Storage Tank [No. 2 fuel oil]

Three Turbine Day Tanks at Energy Complex [No.2 fuel oil, (560, 560, and 300 gallons each)]

Laboratory Hoods throughout medical facility [Sterilization operations]

Heart Hospital Emergency Generator [1,250 kw, No. 2 fuel oil fired], 6,000 gallon storage tank

Life Flight Helicopter Jet Aviation Fuel Storage Tank, 6,000 gallons

Emergency Generator No. 1 at Energy Complex [2,500 kw, No. 2 fuel oil fired], 14,400 gallon storage tank

Emergency Generator No. 2 at Energy Complex [2,500 kw, No. 2 fuel oil fired], 14,400 gallon storage tank