Table 2-1, Summary of Compliance Requirements

BAPTIST MEDICAL CENTER
PRUDENTIAL DRIVE FACILITY

FINAL Permit No.: 0310010-008-AV
Facility ID No.: 0310010

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.
Notes: * The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
**CMS [=] continuous monitoring system

EU ID No.	Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
# 005	NOx	Gas	EPA RM 20	Annually	2/1/2010			III, 005, 8.
	SO2 & NOx	Oil	EPA RM 20	Upon Request				III, 005, 8.
	S.C.	Gas	SUPPLIER CERT.	6 Months				III, 005, 12
	S.C.	Oil	SUPPLIER CERT.	Each Shipment				III, 005, 11
	VE		EPA RM 9	Annually		30 Minutes		III, 005, 9.
# 012	NOx	Gas	EPA RM 20	Annually	2/1/2010			III, 012, 8.
	SO2 & NOx	Oil	EPA RM 20	Upon Request				III, 012, 8.
	S.C.	Gas	SUPPLIER CERT.	6 Months				III, 012, 12.
	S.C.	Oil	SUPPLIER CERT.	Each Shipment				III, 012, 11
	VE		EPA RM 9	Annually		30 Minutes		III, 012, 9.
# 013	NOx	Gas	EPA RM 20	Annually	2/1/2010			III, 013, 8.
	SO2 & NOx	Oil	EPA RM 20	Upon Request				III, 013, 8.
	S.C.	Gas	SUPPLIER CERT.	6 Months				III, 013, 12.
	S.C.	Oil	SUPPLIER CERT.	Each Shipment				III, 013, 11
	VE		EPA RM 9	Annually		30 Minutes		III, 013, 9.
#014	Natural Gas Usage		Recordkeeping	Daily				III, 014, 6.
#015	VE		EPA RM 9	Annually	2/1/2010	ONE (1) HOUR		III, 015, 7. and 8.
	S.C.	Oil	SUPPLIER CERT.	Each Shipment				III, 015, 9.
	Fuel combusted	gas, oil	Recordkeeping	Monthly				III, 015, 10.
#016	VE		EPA RM 9	Annually	2/1/2010	ONE (1) HOUR		III, 016, 7. and 8.
	S.C.	Oil	SUPPLIER CERT.	Each Shipment				III, 016, 9.
	Fuel combusted	gas, oil	Recordkeeping	Monthly				III, 016, 10.
#017	VE		EPA RM 9	Prior to Expiration	2/1/2010	ONE (1) HOUR		III, 017, 8. and 9.
	Natural Gas Usage		Recordkeeping	Monthly				III, 017, 10.

S.C. = SULFUR CONTENT

0310010-008sum2-AV.xls