Table 2-1, Summary of Compliance Requirements

Millennium Specialty Chemicals

Permit No.: 0310039-012-AV
Facility ID No.: 0310039

permit.

E.U. ID No.	Brief Description
4	#4 Boiler

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
Particulate Matter	Natural Gas No. 2 Fuel Oil No. 6 Fuel Oil Glidfuel	EPA 5	On Request				III.A.9., A.14.
Sulfur Dioxide	Natural Gas No. 2 Fuel Oil No. 6 Fuel Oil Glidfuel	Fuel Analysis Fuel Analysis EPA Method 6	Batch/Daily Batch/Daily Upon Request				III.A.8., A.13., A.14., A.18.
Visible Emissions	Natural Gas No. 2 Fuel Oil No. 6 Fuel Oil Glidfuel	EPA 9	Annually	Each FFY			III.A.10.

Notes:
* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
**CMS [=] continuous monitoring system

[electronic file name: 03100392.xls]

Table 2-1, Summary of Compliance Requirements

Millennium Specialty Chemicals

Permit No.: 0310039-012-AV
Facility ID No.: 0310039

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
5	#5 Boiler

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
Particulate Matter	Natural Gas No. 2 Fuel Oil No. 6 Fuel Oil Glidfuel	EPA 5	On Request				III.B.9., B.14.
Sulfur Dioxide	Natural Gas No. 2 Fuel Oil No. 6 Fuel Oil Glidfuel	Fuel Analysis Fuel Analysis EPA Method 6	Batch/Daily Batch/Daily Upon Request				III.B.8., B.13., B.14., B.18.
Visible Emissions	Natural Gas No. 2 Fuel Oil No. 6 Fuel Oil Glidfuel	EPA 9	Annually	Each FFY			III.B.10.

Notes:
* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
**CMS [=] continuous monitoring system

[electronic file name: 03100392.xls]

Table 2-1, Summary of Compliance Requirements

Millennium Specialty Chemicals

Permit No.: 0310039-012-AV
Facility ID No.: 0310039

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
6	#6 Boiler

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
Particulate Matter	Natural Gas No. 2 Fuel Oil No. 6 Fuel Oil Glidfuel	EPA 5	On Request				III.C.9.; C.14.
Sulfur Dioxide	Natural Gas No. 2 Fuel Oil No. 6 Fuel Oil Glidfuel	Fuel Analysis Fuel Analysis EPA Method 6	Batch/Daily Batch/Daily Upon Request				III.C.8., C.13., C.14., C.18.
Visible Emissions	Natural Gas No. 2 Fuel Oil No. 6 Fuel Oil Glidfuel	EPA 9	Annually	Each FFY			III.C.10.

Notes:
* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
**CMS [=] continuous monitoring system

[electronic file name: 03100392.xls]

Table 2-1, Summary of Compliance Requirements

Millennium Specialty Chemicals

Permit No.: 0310039-012-AV
Facility ID No.: 0310039

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
11	#7 Boiler

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
Particulate Matter	Natural Gas No. 2 Fuel Oil No. 6 Fuel Oil Glidfuel	EPA 5	On Request				III.D.10.; D.15.
Sulfur Dioxide	Natural Gas No. 2 Fuel Oil No. 6 Fuel Oil Glidfuel	Fuel Analysis Fuel Analysis EPA Method 6	Batch/Daily Batch/Daily Upon Request				III.D.9., D.14., D.15., D.20.
Integrated Oil Meter	No. 2 Fuel Oil No. 6 Fuel Oil Glidfuel	Meter Readings	Daily			Y	III.D.19., D.21.
Visible Emissions	Natural Gas No. 2 Fuel Oil No. 6 Fuel Oil Glidfuel	EPA 9	Annually	Each FFY			III.D.11.

Notes:
* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
**CMS [=] continuous monitoring system

[electronic file name: 03100392.xls]