FINAL DETERMINATION

PERMITTEE

JEA
21 West Church Street
Jacksonville, Florida 32202

PERMITTING AUTHORITY

Florida Department of Environmental Protection (Department)
Division of Air Resource Management
Office of Permitting and Compliance
2600 Blair Stone Road, MS #5505
Tallahassee, Florida 32399-2400

PROJECT

Air Permit No. 0310045-037-AC/PSD-FL-265F
Minor Air Construction Permit
Northside Generating Station & St. Johns River Power Park

Air Permit No. 0310045-037-AC/PSD-FL-265F revises Permit No. 0310045-022-AC (PSD-FL-265E) to remove the conditions regarding the mercury Continuous Emission Monitoring System requirements and allows the firing of up to 240 tons per day of biomass for each of the Northside Generating Station Boiler Nos. 1 and 2; and, revises the description of St. Johns River Power Park Units 1 and 2 in Permit 0310045-030-AV to allow the operation of one scrubber tower during low load operations. Northside Generating Station & St. Johns River Power Park is an electric power plant categorized under Standard Industrial Classification No. 4911. The project was not subject to the Prevention of Significant Deterioration (PSD) preconstruction review.

NOTICE AND PUBLICATION

The Department distributed a draft air construction permit package on October 8, 2012. The applicant published the Public Notice in the Florida Times Union on October 12, 2012. The Department received the proof of publication on October 16, 2012. No requests for administrative hearings or requests for extensions of time to file a petition for administrative hearing were received.

COMMENTS

No comments on the Draft Permit were received from the public, the Local Air Program, the EPA Region 4 Office or the applicant.

CONCLUSION

The final action of the Department is to issue the permit as noticed.