Table 2-1, Summary of Compliance Requirements

JEA
Kennedy Generating Station

Permit # 0310047-021-AV
Facility ID # 0310047

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 015 CT No. 7 – 170 MW General Electric PG7241 FA combustion turbine-electrical generator.

Pollutant/ Parameter	Fuel	Compliance Method	Frequency of Sampling	Frequency Base Date *	Min. Compliance Test Duration	CMS**	Permit Condition
SO2	Gas	EPA Method 19 and 20					**A.25.**
	Oil						
NOx	Gas	EPA Method 9				Yes	**A.25.**
	Oil						
VE	Gas	EPA Method 9	annual				**A.25.**
	Oil						
CO	Gas	EPA Method 10	annual				
	Oil						
VOC	Gas	EPA Method 18, 25, or 25A					
	Oil						

Notes:
*Frequency base date established for planning purposes only; see Rule 62-297.310, F.A.C.
**CMS = continuous monitoring system