This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this per

E.U. 016 CT No. 8 – 172 MW General Electric PG7241 FA combustion turbine-electrical g

Pollutant/ Parameter	Fuel	Compliance Method	Frequency of Sampling	Frequency Base Date *	Min. Compliance Test Duration	CMS**	Permit Condition
SO2	Gas	EPA Method 19 and 20	annual			Yes	**B.16.**
	Oil						
NOx	Gas	EPA Method 9					**B.16.**
	Oil						
VE	Gas	EPA Method 9					**B.16.**
	Oil						
CO	Gas	EPA Method 10	annual				
	Oil						

Notes:

*Frequency base date established for planning purposes only; see Rule 62-297.310, F.A.C.

**CMS = continuous monitoring system

mit.
generator.