Table 1-1, Summary of Air Pollutant Standards and Terms

JEA **Permit # 0310047-021-AV**

Kennedy Generating Station **Facility ID # 0310047**

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 015 CT No. 7 – 170 MW General Electric PG7241 FA combustion turbine-electrical generator.

			Allowable Emissions			Equivalent Emissions*			See Permit
lutant/Parame	Fuel	Hours/Year	lbs/hour	TPY		lbs./hour	TPY	Regulatory Citations	Condition
SO2	Gas	4050	9.7	62				0310047-002-AC	**A.14.**
	Oil	1260	98	62				0310047-013-AC	
NOx	Gas	4050	99	200				0310047-002-AC	**A.10.**
	Oil	1260	318	200				0310047-013-AC	
VE	Gas	4050	10% opacity					0310047-002-AC	**A.8.**
	Oil	1260	10% opacity						
CO	Gas	4050	48					0310047-002-AC	**A.12.**
	Oil	1260	97					0310047-013-AC	
VOC	Gas	4050	2.9					0310047-002-AC	**A.13.**
	Oil	1260	19					0310047-013-AC	

Notes: ** -- Annual emissions (TPY) based on 3 hours per day at 0.3 lb/mmBtu and 21 hours per day at 0.1lb/MMBtu.

* -- Equivalent Emissions provided for information only.