JEA

Kennedy Generating Station

Permit # 0310047-021-AV

Facility ID # 0310047

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 016 CT No. 8 – 172 MW General Electric PG7241 FA combustion turbine-electrical generator.

			Allowable Emissions			Equivalent Emissions*			See Permit
lutant/Parame	Fuel	Hours/Year	lbs/hour			lbs./hour	TPY	Regulatory Citations	Condition
SO2	Gas	3500	2 grains sulfur (S)/100 SCF of gas					0310047-015-AC	**B.10.**
	Oil	500	0.05% sulfur by weight					0310047-018-AC	
								0310047-019-AC	
NOx	Gas	3500	108.3					0310047-015-AC	**B.10.**
	Oil	500	335					0310047-018-AC	
								0310047-019-AC	
VE	Gas	3500	10% opacity					0310047-015-AC	**B.10.**
	Oil	500	10% opacity					0310047-018-AC	
								0310047-019-AC	
CO	Gas	3500	32					0310047-015-AC	**B.10.**
	Oil	500	66					0310047-018-AC	
								0310047-019-AC	

Notes: ** -- Annual emissions (TPY) based on 3 hours per day at 0.3 lb/mmBtu and 21 hours per day at 0.1lb/MMBtu.

* -- Equivalent Emissions provided for information only.