STATEMENT OF BASIS

St. Vincent's Medical Center
Facility ID No.: 0310068
Duval County

Title V Air Operation Permit Renewal
REVISED DRAFT/PROPOSED Permit Project No.: 0310068-008-AV
Renewal to Title V Air Operation Permit No.: 0310068-007-AV

The initial Title V Air Operation Permit, No. 0310068-001-AV, was effective on December 16, 1998. This Title V Air Operation Permit Renewal is issued under the provisions of Chapter 403, Florida Statutes (FS), and Chapters 62-4, 62-210 and 62-213, Florida Administrative Code (FAC). The above named permittee is hereby authorized to operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit.

This permit is for the purpose of renewing Title V Air Operation Permit, No. 0310068-007-AV. St. Vincent's Medical Center is a full care medical center including hospital, consists of three (3) boilers, and a gas turbine cogeneration unit.

E.U. ID No.	**Brief Description**	
002	Boiler No. 1 (West)	This emission unit is a $25x10^6$ Btu per hour Babcock & Wilcox Boiler. The primary fuel is natural gas with No. 2 Fuel Oil as an emergency back-up fuel. Compliance Assurance Monitoring (CAM) does not apply.
003	Boiler No. 2 (Center)	This emission unit is a $25x10^6$ Btu per hour Babcock & Wilcox Boiler. The primary fuel is natural gas with No. 2 Fuel Oil as an emergency back-up fuel. CAM does not apply.
004	Boiler No. 3 (East)	This emission unit is a $25x10^6$ Btu per hour Babcock & Wilcox Boiler. The primary fuel is natural gas with No. 2 Fuel Oil as an emergency back-up fuel. CAM does not apply.
005	Gas Turbine Cogenerator No. 1	This emission unit is a $25x10^6$ Btu per hour Kawasaki turbine engine generator. The primary fuel is natural gas with No. 2 Fuel Oil as an emergency back-up fuel. The turbine engine generator will produce a maximum of 1,500 kW and 12,000 pounds of steam per hour. CAM does not apply.

Also included in this permit are miscellaneous insignificant emissions units and/or activities.

Based on the Title V Air Operation Permit Renewal application received July 30, 2010, this facility is not a major source of hazardous air pollutants (HAPs).