FACILITY PERMIT REVIEW SHEET

DATE: 12/15/2010 **APPLICATION NUMBER:** 0310496-005-AO

FACILITY NAME: Wood Group Pratt & Whitney Industrial Turbine Services, LLC

FACILITY DESCRIPTION: Gas turbine Engine Test Cells

PERMIT PROCESSOR: _____

MAJOR FOR CRITERIA POLLUTANTS AND/OR HAPs (Circle)

CO **PB** **NO_X** **PM** **SO_2** **VOC** **HAP**

SUBJECT TO: (Circle)

NSR(PSD) **PERMIT NUMBER:** _____

NSR(NAA) **PERMIT NUMBER:** _____

BACT **EU NUMBER:** _____

MACT **EU NUMBER:** _____

RACT **EU NUMBER:** _____

NSPS **EU NUMBER:** _____

FACILITY EMISSION SUMMARY

	POTENTIAL EMISSIONS	ALLOWABLE EMISSIONS	
	TPY	LBS/HR	TPY
PM	0.38		
PM10	0.38		
SO_2	0.03		
NO_X	27.5		
CO	0.10		
VOC	0.01		
TOC	0.13		
PB	0.0004		
TOTAL HAP	0.039		
SINGLE HAP (highest)	0.025		

COMMENTS: **VE must be less than 20% opacity.**

Effective 2/27/97