Jacksonville Electric Authority (JEA)
Greenland Energy Center

Facility ID No. 0310561
Duval County

Final Title V Air Operation Permit Revision

Permit No. 0310561-006-AV

Permitting Authority:

State of Florida
Department of Environmental Protection
Division of Air Resource Management
Office of Permitting and Compliance
Power Plants Section

2600 Blair Stone Road
Mail Station #5505
Tallahassee, Florida 32399-2400

Telephone: (850) 717-9000
Fax: (850) 717-9001

Compliance Authority:

City of Jacksonville Environmental Quality Division

214 North Hogan Street, 7th Floor
Jacksonville, Florida 32202

Telephone: (904) 255-7100
Fax: (904) 588-0518

Title V Air Operation Permit

Permit No. 0310561-006-AV

Table of Contents

Section **Page Number**

Placard Page 1

I. Facility Information.
A. Facility Description. 2
B. Summary of Emissions Units. 2
C. Applicable Regulations. 2

II. Facility-wide Conditions. 3

III. Emissions Units and Conditions.
A. EU 001 & 002: Combustion Turbine Units 1 and 2. 5
B. EU 004: Emergency Fire Pump. 13

IV. Acid Rain Part. 15
Phase II Acid Rain Application/Compliance Plan.

V. Clean Air Interstate Rule Part. 20

VI. Appendices. 26
Appendix A, Glossary of Terms.
Appendix A1, 40 CFR 60, NSPS Subpart A - General Conditions.
Appendix A2, 40 CFR 63, NESHAP Subpart A - General Conditions.
Appendix I, List of Insignificant Emissions Units and/or Activities.
Appendix KKKK, 40 CFR 60, NSPS Subpart KKKK - Standards of Performance for Stationary Combustion Turbines.
Appendix RR, Facility-wide Reporting Requirements.
Appendix TR, Facility-wide Testing Requirements.
Appendix TV, Title V General Conditions.

Referenced Attachments. ..... At End
Figure 1, Summary Report-Gaseous and Opacity Excess Emission and Monitoring System Performance (40 CFR 60, July, 1996).
Table H, Permit History.
Table 1, Summary of Air Pollutant Standards and Terms.
Table 2, Summary of Compliance Requirements.

Florida Department of Environmental Protection

Bob Martinez Center
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Rick Scott
Governor

Jennifer Carroll
Lt. Governor

Herschel T. Vinyard Jr.
Secretary

PERMITTEE:
JEA – Greenland Energy Center
21 West Church Street
Jacksonville, Florida 32202

Permit No. 0310561-006-AV
Greenland Energy Center
Facility ID No. 0310561
Title V Air Operation Permit Revision

The purpose of this project is to revise the Title V air operation permit by removing carbon monoxide requirements for the above referenced facility. The existing Greenland Energy Center is located at 6850 Energy Center Drive, Jacksonville, in Duval County. UTM Coordinates are: Zone 17, 450.2 km East and 3336.4 km North. Latitude 30 09' 28.28" North and Longitude 81 31' 01.02" West.

The Title V air operation permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213 and 62-214. The above named permittee is hereby authorized to operate the facility in accordance with the terms and conditions of this permit.

0310561-003-AV Effective Date: January 1, 2012
0310561-006-AV Revision Effective Date: August 2, 2012
Renewal Application Due Date: May 20, 2016
Expiration Date: December 31, 2016

Executed in Tallahassee, Florida.

Jeffery F. Koerner, Program Administrator
Office of Permitting and Compliance
Division of Air Resource Management

JFK/jkh/tbc

SECTION I. FACILITY INFORMATION.

Subsection A. Facility Description.

The facility is an electric-generating facility referred to as Greenland Energy Center (GEC). The plant consists of two natural gas-fired simple cycle combustion turbine (CT) units that use ultra low sulfur fuel oil (ULSFO) as a backup fuel and a 1.875 million gallon fuel oil storage tank for the CTs. (Note: a 20,000 gallon fuel oil storage tank is temporarily installed until the 1.875 million gallon fuel oil storage tank is operational.) Additional ancillary equipment includes a natural gas fired fuel heater to condition the natural gas supplied to each CT and a diesel-engine powered emergency fire pump.

Subsection B. Summary of Emissions Units.

EU No.	Brief Description
Regulated Emissions Units	
001	Unit 1 – General Electric PG7241FA gas turbine electric generator
002	Unit 2 – General Electric PG7241FA gas turbine electric generator
004	One Emergency Fire Pump Engine rated at 197 hp (EPA Tier 3 certified) with 550 gallon fuel tank
Insignificant Emissions Units and Activities	
1.875 million gallon ULSFO storage tank	
20,000 gallon ULSFO storage tank	
5.84 MMBtu/hr natural gas fired fuel gas heater	

Subsection C. Applicable Regulations.

Based on the Title V Air Operation Permit revision application received on April 25, 2012, this facility is not a major source of hazardous air pollutants (HAP). The existing facility is a PSD major source of air pollutants in accordance with Rule 62-212.400, F.A.C. A summary of applicable regulations is shown in the following table.

Regulation	EU No(s).
Federal Rule Citations	
40 CFR 60, Subpart A, NSPS General Provisions	001, 002 & 004
40 CFR 60, Subpart KKKK (Standards of Performance for Stationary CTs)	001 & 002
40 CFR 75 Acid Rain Monitoring Provisions	001 & 002
40 CFR 60, Subpart IIII (Standards of Performance for Stationary CI Internal Combustion engines)	004
40 CFR 63, Subpart A, NESHAP General Provisions	004
40 CFR 63, Subpart ZZZZ (National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines)	004
State Rule Citations	
Rule 62-212.400, F.A.C., Prevention of Significant Deterioration(PSD)	001 & 002
Rule 62-213, F.A.C., Operation Permits for Major Sources of Air Pollution	001, 002 & 004
Rule 62-210.300, F.A.C., Permits Required	001, 002 & 004
Rule 62-296.470, F.A.C., Implementation Federal Clean Air Interstate Rule	001 & 002
Rule 62-297, F.A.C., Stationary Sources Emissions Monitoring	001 & 002

The following conditions apply facility-wide to all emission units and activities:

FW1. Appendices. The permittee shall comply with all documents identified in Section VI, Appendices, listed in the Table of Contents. Each document is an enforceable part of this permit unless otherwise indicated. [Rule 62-213.440, F.A.C.]

Emissions and Controls

FW2. Not federally Enforceable. Objectionable Odor Prohibited. No person shall cause, suffer, allow or permit the discharge of air pollutants, which cause or contribute to an objectionable odor. An "objectionable odor" means any odor present in the outdoor atmosphere which by itself or in combination with other odors, is or may be harmful or injurious to human health or welfare, which unreasonably interferes with the comfortable use and enjoyment of life or property, or which creates a nuisance. [Rule 62-296.320(2) and 62-210.200(Definitions), F.A.C.]

FW3. General Volatile Organic Compounds (VOC) Emissions or Organic Solvents (OS) Emissions. The permittee shall allow no person to store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds or organic solvents without applying known and existing vapor emission control devices or systems deemed-necessary and ordered by the Department. [Rule 62-296.320(1), F.A.C.]

{Permitting Note: Nothing is deemed necessary and ordered at this time.}

FW4. General Visible Emissions. No person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity equal to or greater than 20% opacity. EPA Method 9 is the method of compliance pursuant to Chapter 62-297, F.A.C. This regulation does not impose a specific testing requirement. [Rule 62-296.320(4)(b), F.A.C.]

FW5. Unconfined Particulate Matter. No person shall cause, let, permit, suffer or allow the emissions of unconfined particulate matter from any activity, including vehicular movement; transportation of materials; construction; alteration; demolition or wrecking; or industrially related activities such as loading, unloading, storing or handling; without taking reasonable precautions to prevent such emissions. Reasonable precautions to prevent emissions of unconfined particulate matter at this facility include watering as needed to prevent emissions from unpaved areas. [Rule 62-296.320(4)(c), F.A.C.; and proposed by applicant in Title V air operation permit application Attachment C, received July 12, 2011.]

Annual Reports and Fees

See Appendix RR, Facility-wide Reporting Requirements for additional details.

FW6. Annual Operating Report. The permittee shall submit an annual report that summarizes the actual operating rates and emissions from this facility. Annual operating reports shall be submitted to the Compliance Authority by April 1st of each year. [Rule 62-210.370(3), F.A.C.]

FW7. Annual Emissions Fee Form and Fee. The annual Title V emissions fees are due (postmarked) by March 1st of each year. The completed form and calculated fee shall be submitted to: Major Air Pollution Source Annual Emissions Fee, P.O. Box 3070, Tallahassee, Florida 32315-3070. The forms are available for download by accessing the Title V Annual Emissions Fee On-line Information Center at the following Internet web site: http://www.dep.state.fl.us/air/emission/tvfee.htm. [Rule 62-213.205, F.A.C.]

FW8. Annual Statement of Compliance. The permittee shall submit an annual statement of compliance to the compliance authority at the address shown on the cover of this permit within 60 days after the end of each calendar year during which the Title V permit was effective. [Rules 62-213.440(3)(a)2. & 3. and (b), F.A.C.]

FW9. Prevention of Accidental Releases (Section 112(r) of CAA). If and when the facility becomes subject to 112(r), the permittee shall:

a. Submit its Risk Management Plan (RMP) to the Chemical Emergency Preparedness and Prevention Office (CEPPO) RMP Reporting Center. Any Risk Management Plans, original submittals, revisions or

updates to submittals, should be sent to: RMP Reporting Center, Post Office Box 10162, Fairfax, VA 22038, Telephone: 703/227-7650.

b. Submit to the permitting authority Title V certification forms or a compliance schedule in accordance with Rule 62-213.440(2), F.A.C.

[40 CFR 68]

FW10. Source Obligation.

a. At such time that a particular source or modification becomes a major stationary source or major modification (as these terms were defined at the time the source obtained the enforceable limitation) solely by virtue of a relaxation in any enforceable limitation which was established after August 7, 1980, on the capacity of the source or modification otherwise to emit a pollutant, such as a restriction on hours of operation, then the requirements of subsections 62-212.400(4) through (12), F.A.C., shall apply to the source or modification as though construction had not yet commenced on the source or modification.

b. At such time that a particular source or modification becomes a major stationary source or major modification (as these terms were defined at the time the source obtained the enforceable limitation) solely by exceeding its projected actual emissions, then the requirements of subsections 62-212.400(4) through (12), F.A.C., shall apply to the source or modification as though construction had not yet commenced on the source or modification.

[Permit No. 0310561-001-AC/PSD-FL-401, Specific Condition II.7.]

Subsection A. Emissions Units 001 and 002

The specific conditions in this section apply to the following emissions units:

EU No.	Brief Description
001	Unit 1 – General Electric PG7241FA gas turbine electric generator
002	Unit 2 – General Electric PG7241FA gas turbine electric generator

This subsection of the permit consists of two gas-fired simple cycle electric generating units that use ultra low sulfur distillate fuel oil as backup fuel. The units are General Electric (GE) Model PG7241FA gas turbine-electrical generator sets. The combustion turbines are equipped with GE's dry-low NO_X (DLN) combustors; a Mark VI automated combustion turbine control system; and, an inlet air filtration system. The combustion turbines are designed for operation in simple cycle mode, only. The two units are designated individually as "Unit 1" and "Unit 2."

Each of the gas turbine-electrical generator sets has a nominal generating capacity of 176 MW on natural gas and 190 MW on ultra low sulfur distillate fuel oil (ULSFO) containing no more than 15 ppm sulfur.

The efficient combustion of natural gas and restricted firing of fuel oil minimizes the products of incomplete combustion including carbon monoxide (CO), particulate matter (PM/PM_{10}), and volatile organic compounds (VOC). The use of only low sulfur fuel minimizes the formation of sulfuric acid mist (SAM) and sulfur dioxide (SO_2). DLN combustion technology is employed for gas firing and water injection for oil firing to reduce NO_X emissions.

The exhaust stacks for each CT are 115 feet tall and 20 feet in diameter. At full load, actual stack flow rates are nominally 2,428,785 cubic feet per minute at 1,111° F for gas firing and nominally 2,527,700 cubic feet per minute at 1,094° F for fuel oil firing.

Initial start-up dates are as follows: Unit 1 - January 16, 2011; Unit 2 – March 5, 2011; and, Unit 4 (fire pump diesel engine) - January 16, 2011. The new facility commenced construction on January 28, 2010.

{Permitting notes: The CT emissions units are regulated under Acid Rain, Phase II; 40 CFR 60, Subpart KKKK, Standards of Performance for Stationary Combustion Turbines; Rule 62-212.400(5), F.A.C., Prevention of Significant Deterioration (PSD) [PSD-FL-401 & PSD-FL-401A]; Rule 62-212.400(6), F.A.C., Best Available Control Technology (BACT) Determination; and, Rule 62-296.470, F.A.C., Clean Air Interstate Rule (CAIR). These emissions units are exempt from 40 CFR 64 Compliance Assurance Monitoring (CAM) since these are subject to federal standards in 40 CFR Subpart KKKK, which was promulgated after November 11, 1990 and which contain monitoring requirements that provide a reasonable assurance of compliance.}

Essential Potential to Emit (PTE) Parameters

A.1. Permitted Capacity. The nominal heat input rate to each of the combustion turbines is 1,806 million British Thermal Units per hour (MMBtu/hr) when firing natural gas and 1,994 MMBtu/hr when firing fuel oil (based on a compressor inlet air temperature of 59° F, the higher heating value (HHV) of each fuel, and 100% load). Heat input rates will vary depending upon gas turbine characteristics, ambient conditions, alternate methods of operation, and evaporative cooling. The permittee shall provide manufacturer's performance curves (or equations) that correct for site conditions to the Permitting and Compliance Authorities within 45 days of completing the initial compliance testing. Operating data may be adjusted for the appropriate site conditions in accordance with the performance curves and/or equations on file with the Department. [0310561-001-AC/PSD-FL-401, Specific Condition 8]

A.2. Emissions Unit Operating Rate Limitation After Testing. See the related testing provisions in Appendix TR, Facility-wide Testing Requirements. [Rule 62-297.310(2), F.A.C.]

A.3. Methods of Operation.

a. *Simple Cycle, Intermittent Operation.* The combustion turbines shall operate only in simple cycle mode not to exceed the permitted hours of operation allowed by this permit. This restriction is based on the permittee's request, which formed the basis of the PSD applicability and BACT determinations and

resulted in the emission standards specified in this permit. For any request to convert these units to combined cycle operation by installing/connecting to heat recovery steam generators, including changes to the fuel quality or quantity related to combined cycle conversion which may cause an increase in short or long-term emissions, the permittee shall submit a full PSD permit application complete with a new proposal of the Best Available Control Technology as if the units had never been built.

b. *Fuels.*
   (1) Natural Gas. Each combustion turbine shall fire natural gas as the primary fuel, which shall contain no more than 2 grains of sulfur per 100 standard cubic feet of natural gas.
   (2) Ultra Low Sulfur Fuel Oil (ULSFO). As a restricted alternate fuel, the combustion turbine may fire ULSFO containing no more than 0.0015% sulfur by weight.

   Note: The fuel sulfur specifications effectively limit the potential emissions of sulfuric acid mist (SAM) and sulfur dioxide (SO_2) from the gas turbines and represents BACT for these pollutants. Compliance with the fuel sulfur specifications shall be determined by the ASTM methods or a certified fuel sulfur analysis from the fuel vendor for determination of fuel sulfur as detailed in Specific Condition **A.26.** of this permit.

[0310561-001-AC/PSD-FL-401, Specific Conditions 10 & 12]

A.4. Hours of Operation. Each combustion turbine shall not operate more than 3,500 hours during any consecutive 12 months, of which 500 hours may be on ULSFO. Each combustion turbine shall not operate more than 17 hours exclusively on ULSFO per calendar day, or with a combination of ULSFO burning of 12 hours with 12 hours of natural gas for compliance with regional haze impact thresholds. [0310561-001-AC/PSD-FL-401, Specific Condition 7]

Control Technology

A.5. DLN Combustion. The permittee shall operate and maintain the General Electric DLN 2.6 combustion system (or better) to control NO_X emissions from the combustion turbine when firing natural gas. The system shall be maintained and tuned in accordance with the manufacturer's recommendations or determined best practices. [Design and Rule 62-212.400(10)(BACT), F.A.C.]

A.6. Wet Injection. The permittee shall operate and maintain a water injection system to reduce NO_X emissions from the combustion turbine when firing ULSFO. The system shall be maintained and tuned in accordance with the manufacturer's recommendations or determined best practices. [Applicant request and Rule 62-212.400(10)(BACT), F.A.C.]

Emission Limitations and Standards

{Permitting Note: The attached Table 1, Summary of Air Pollutant Standards, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

{Permitting Notes: In combination with the annual restriction on hours of operation and fuel sulfur specifications, the following emissions standards effectively limit annual potential emissions from the combustion turbines to: 340.2 tons/year of NO_X, 71 tons/year of PM/PM_{10} and 28.81 tons/year of SO_2. Emissions of particulate matter, volatile organic compounds and sulfur dioxides/sulfuric acid are minimized by good combustion of low sulfur fuels.}

Unless otherwise specified, the averaging times for Specific Conditions **A.7.** – **A.9.** are based on the specified averaging time of the applicable test method.

A.7. Visible Emissions (VE). As determined by stack testing, visible emissions from the combustion turbines (CTs) shall not exceed 10% opacity, on a 6-minute block average. [0310561-001-AC/PSD-FL-401, Specific Condition 12]

A.8. Nitrogen Oxides (NO_X). As determined by the continuous emissions monitoring system (CEMS), emissions of NO_X from the CTs shall not exceed:

a. *From the combustion of gas*. 9.0 parts per million by volume dry (ppmvd), corrected to 15% oxygen (O_2), on a 24-hour block average. (BACT)

b. *From the combustion of oil*. 42.0 ppmvd, corrected to 15% O_2, on a 4-hour rolling average. (NSPS)

[0310561-001-AC/PSD-FL-401, Specific Condition 12 and 0310561-004-AC/PSD-FL-401A, Specific Condition 2]

*{Permitting Note: For informational purposes, the NO_X mass emissions rates (*defined as oxides of nitrogen expressed as NO_2*) at International Organization for Standardization (ISO) conditions, based on a turbine inlet condition of 59° F and using the higher heating value (HHV) of the fuel at full load, are equivalent to 58.5 pounds per hour (lb/hr) for gas and 329.4 lb/hr for oil.}*

A.9. [Reserved.]

Excess Emissions

{Permitting Note: The following conditions mainly apply to the State Implementation Plan (SIP)-based emissions standards specified in the emission limitations and standards above. Rule 62-210.700 (Excess Emissions), F.A.C. cannot vary any requirement of an NSPS, NESHAP or Acid Rain program provision.}

A.10. Excess Emissions Prohibited. Excess emissions caused entirely or in part by poor maintenance, poor operation or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. All such preventable emissions shall be included in any compliance determinations based on CEMS data. [Rule 62-210.700(4), F.A.C.; and, Permit No. 0310561-001-AC, Specific Condition 21]

A.11. Definitions.

a. *Startup* is defined as the commencement of operation of any emissions unit which has shut down or ceased operation for a period of time sufficient to cause temperature, pressure, chemical or pollution control device imbalances, which result in excess emissions.

b. *Shutdown* is the cessation of the operation of an emissions unit for any purpose.

c. *Malfunction* is defined as any unavoidable mechanical and/or electrical failure of air pollution control equipment or process equipment or of a process resulting in operation in an abnormal or unusual manner.

[Rule 62-210.200(165, 242 and 258), F.A.C. and Permit No. 0310561-001-AC/PSD-FL-401, Specific Condition 20]

{Permitting Note: The applicant has described startup of this unit as the period from 0 to just less than 50% load, and shutdown as the period beginning at just less than 50 % load to no load operation}. Dry Low NO_X Burners on the CTs firing gas are not able to keep emissions below the BACT emission standards until they are fully staged-in at about 50% of full load. Therefore at startup of the unit, from 0 load to about 50% of full load, and at shutdown (just less than 50% of full load down to no load), emissions could potentially be in excess of the BACT or NSPS emission limits because these operating modes are unavoidable.}

A.12. Data Exclusion Procedures for SIP Compliance. As per the procedures in this condition, limited amounts of CEMS emissions data, as specified in conditions below, may be excluded from the corresponding SIP-based compliance demonstration, provided that best operational practices to minimize emissions are adhered to, the duration of data excluded is minimized, and the procedures for data exclusion listed below are followed. As provided by the authority in Rule 62-210.700(5), F.A.C., these conditions replace the provisions in Rule 62-210.700(1), F.A.C.

a. *Limiting Data Exclusion*. If the compliance calculation using all valid CEMS emission data indicates that the emission unit is in compliance, then no CEMS data shall be excluded from the compliance demonstration.

b. *Event Driven Exclusion*. There must be an underlying event (startup, shutdown, malfunction, or fuel switching) in order to exclude data. If there is no underlying event, then no data may be excluded.

c. Continuous Exclusion. Data shall be excluded on a continuous basis for an underlying event. Data from discontinuous periods shall not be excluded for the same underlying event.

[Rule 62-210.700, F.A.C. and Permit No. 0310561-001-AC/PSD-FL-401, Specific Condition 22]

A.13. Allowable Data Exclusions. The following data may be excluded from the corresponding SIP-based compliance demonstration for each of the events listed below in accordance with the Data Exclusion Procedures of Specific Condition **A.12**.:

a. *Startup.* Up to 30 minutes of CEMS data may be excluded for each combustion turbine startup. For startups of less than 30 minutes in duration, only those minutes attributable to startup may be excluded.
b. *Shutdown.* Up to 30 minutes of CEMS data may be excluded for each combustion turbine shutdown. For shutdowns of less than 30 minutes in duration, only those minutes attributable to shutdown may be excluded.
c. *Malfunction.* Up to two hours (in any operating day) of CEMS data may be excluded due to a documented malfunction. A "documented malfunction" means a malfunction that is documented within one working day of detection by contacting the Compliance Authority by telephone, facsimile transmittal, or electronic email.
d. *DLN Tuning.* CEMS data collected during initial or other major DLN tuning sessions may be excluded from the compliance demonstrations provided the tuning session is performed in accordance with the manufacturer's specifications or determined best practices. A "major tuning session" would occur after completion of initial construction, a combustor change-out, a major repair or maintenance to a combustor, or other similar circumstances. Prior to performing any major tuning session, the permittee shall provide the Compliance Authority with an advance notice of at least one (1) day that details the activity and proposed tuning schedule. The notice may be by telephone, facsimile transmittal, or electronic mail.
e. *Fuel Switching.* Up to 60 minutes of CEMS data may be excluded for each fuel switch. For fuel switches of less than 60 minutes in duration, only those minutes attributable to fuel switching may be excluded.

All valid emissions data (including data collected during startup, shutdown, malfunction, DLN tuning, and fuel switching) shall be used to report emissions for the Annual Operating Report. [Rules 62-210.200(BACT), 62-210.370 and 62-210.700, F.A.C.; and, Permit No. 0310561-001-AC/PSD-FL-401, Specific Condition 23]

A.14. Notification Requirements. The owner or operator shall notify the Compliance Authority within one working day of discovering any emissions that demonstrate non-compliance for a given averaging period. Within one working day of occurrence, the owner or operator shall notify the Compliance Authority of any malfunction resulting in the exclusion of CEMS data. The notice may be by telephone, facsimile transmittal, or electronic mail (See also Specific Condition **A.29.** [Rule 62-4.070, F.A.C. and Permit No. 0310561-001-AC/PSD-FL-401, Specific Condition 24]

A.15. NSPS Reporting. NSPS Excess emissions reporting that specifically apply to Units 1 and 2 from 40 CFR 60 Subpart KKKK are listed in Appendix NSPS, Subpart KKKK (See also Specific Condition **A.29.c.**) [40 CFR 60.4350 & 60.4375 & 60.4380]

{Permitting Note: For reporting excess emissions above the NSPS limits in Subpart KKKK, no CEMS data shall be excluded from startup, shutdown or malfunction.}

Continuous Monitoring Requirements

A.16. CEM Systems. Subject to the following, the permittee shall calibrate, operate, and maintain a continuous emission monitoring system (CEMS) to measure and record the emissions of NO_X from the combustion turbine in terms of the applicable standards.

a. *NO_X Monitor.* Each NO_X monitor shall be certified pursuant to the specifications of 40 CFR 75. Quality assurance procedures shall conform to the requirements of 40 CFR 75. The annual and required RATA tests required for the NO_X monitor shall be performed using EPA Method 20 or 7E in Appendix A of 40 CFR 60.

b. *Diluent Monitor*. The oxygen (O_2) or carbon dioxide (CO_2) content of the flue gas shall be monitored at the location where NO_X is monitored to correct the measured emissions rates to 15% oxygen. If a CO_2 monitor is installed in the future, the oxygen content of the flue gas shall be calculated using F-factors that are appropriate for the fuel fired. Each monitor shall comply with the performance and quality assurance requirements of 40 CFR 75.

[Rules 62-4.070(3) & 62-210.200(BACT), F.A.C.; 40 CFR 60 & 40 CFR 75; and, Permit Nos. 0310561-001-AC/PSD-FL-401, Specific Condition 25 & 0310561-005-AC/PSD-FL-401B, Specific Condition 7]

A.17. CEMS Data Requirements for BACT Standards.

a. *Data Collection*. Emissions shall be monitored and recorded at all times including startup, operation, shutdown, and malfunction except for continuous monitoring system breakdowns, repairs, calibration checks, and zero and span adjustments. The CEMS shall be designed and operated to sample, analyze, and record data evenly spaced over an hour. If the CEMS measures concentration on a wet basis, the CEM system shall include provisions to determine the moisture content of the exhaust gas and an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). Alternatively, the owner or operator may develop through manual stack test measurements a curve of moisture contents in the exhaust gas versus load, and use these typical values in an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). Final results of the CEMS shall be expressed as ppmvd corrected to 15% oxygen. The CEMS shall be used to demonstrate compliance with the CEMS emission standards for NO_X as specified in this permit. For purposes of determining compliance with the CEMS emissions standards of this permit, missing (or excluded) data shall not be substituted. Upon request by the Department, the CEMS emissions rates shall be corrected to ISO conditions.

b. *Valid Hour*. Hourly average values shall begin at the top of each hour. Each hourly average value shall be computed using at least one data point in each fifteen-minute quadrant of an hour, where the unit combusted fuel during that quadrant of an hour. Notwithstanding this requirement, an hourly value shall be computed from at least two data points separated by a minimum of 15 minutes (where the unit operates for more than one quadrant of an hour). If less than two such data points are available, the hourly average value is not valid. The permittee shall use all valid measurements or data points collected during an hour to calculate the hourly average values.

c. *24-hour Block Averages*. A 24-hour block shall begin at midnight of each operating day and shall be calculated from 24 consecutive hourly average emission rate values. If a unit operates less than 24 hours during the block, the 24-hour block average shall be the average of all available valid hourly average emission rate values for the 24-hour block. For purposes of determining compliance with the 24-hour CEMS standards, the missing data substitution methodology of 40 CFR Part 75, Subpart D, shall not be utilized. Instead, the 24-hour block average shall be determined using the remaining hourly data in the 24-hour block. [Rule 62-212.400(BACT), F.A.C.]

d. *4-hour Rolling Average*. Compliance with this rolling average is as described in 40 CFR 60.4380(b)(1).

e. *Data Exclusion*. Each CEMS shall monitor and record emissions during all operations including episodes of startup, shutdown, malfunction and DLN tuning. Some of the CEMS emissions data recorded during these episodes may be excluded from the corresponding CEMS compliance demonstration subject to the provisions of Specific Conditions **A.12.** and **A.13.** All periods of data excluded shall be consecutive for each such episode and only data obtained during the described episodes (startup, shutdown, malfunction, DLN tuning) may be used for the appropriate exclusion periods. The permittee shall minimize the duration of data excluded for such episodes to the extent practicable. Data recorded during such episodes shall not be excluded if the episode was caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure, which may reasonably be prevented. Best operational practices shall be used to minimize hourly emissions that occur during such episodes.

f. *Availability*. Monitor availability for the CEMS shall be based on performance standards as set forth in 40 CFR 75.

[Rules 62-4.070(3) & 62-212.400(BACT), F.A.C.; and, Permit No. 0310561-001-AC/PSD-FL-401, Specific Conditions 26 & 27 and 0310561-005-AC/PSD-FL-401B, Specific Condition 8]

A.18. CEMS Requirement for Annual Emissions. The owner or operator shall use data from the NO_X CEMS when calculating annual emissions for purposes of computing actual emissions, baseline actual emissions, and net emissions increase, as defined at Rule 62-210.200, F.A.C., and for purposes of computing emissions pursuant to the reporting requirements of Rule 62-210.370(3), F.A.C. In computing the emissions of a pollutant, the owner or operator shall account for the emissions during periods of startup and shutdown of the emissions unit. [Rules 62-210.200 & 62-210.370(3), F.A.C.; and, Permit Nos. 0310561-001-AC/PSD-FL-401, Specific Condition 28 & 0310561-005-AC/PSD-FL-401B, Specific Condition 9]

Test Methods and Procedures

{Permitting Note: The attached Table 2, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

A.19. Test Methods. Required tests shall be performed in accordance with the following reference methods:

Method	Description of Method and Comments
7E	Determination of Nitrogen Oxide Emissions from Stationary Sources
9	Visual Determination of the Opacity of Emissions from Stationary Sources
20	Determination of Nitrogen Oxides, Sulfur Dioxide and Diluent Emissions from Stationary Gas Turbines

The above methods are described in 40 CFR 60, Appendix A, and adopted by reference in Rule 62-204.800, F.A.C. No other methods may be used unless prior written approval is received from the Department. [Rule 62-297.401, F.A.C.; and, Permit Nos. 0310561-001-AC/PSD-FL-401, Specific Condition 14 & 0310561-005-AC/PSD-FL-401B, Specific Condition 5]

A.20. Common Testing Requirements. Unless otherwise specified, tests shall be conducted in accordance with the requirements and procedures specified in Appendix TR, Facility-Wide Testing Requirements, of this permit. [Rule 62-297.310, F.A.C.]

A.21. Annual Compliance Tests Required. During each federal fiscal year (October 1st to September 30th), each CT shall be tested to demonstrate compliance with the emissions standards for visible emissions while firing natural gas. Visible emissions tests shall also be performed while firing fuel oil if fuel oil was fired for more than 400 hours during the federal fiscal year. RATA tests shall be conducted while the affected facility is operating at more than 50 percent of normal load. [Rule 62-297.310(7), F.A.C.; 40 CFR 60 Appendix A Performance Specification 2 Section 8.4.1; and, Permit Nos. 0310561-001-AC/PSD-FL-401, Specific Condition 15 & 0310561-004-AC/PSD-FL-401A, Specific Condition 2]

A.22. Continuous Compliance. The permittee shall demonstrate continuous compliance with the 24-hour block and 4-hour rolling average NO_X emission standards based on data collected by the certified CEMS. Within 45 days of conducting any RATA on a CEMS, the permittee shall submit a report to the Compliance Authority summarizing results of the RATA. [Rules 62-4.070 and 62-210.200 (BACT), F.A.C.; and Permit Nos. 0310561-001-AC/PSD-FL-401, Specific Condition 18 & 0310561-005-AC/PSD-FL-401B, Specific Condition 6]

Recordkeeping and Reporting Requirements

A.23. Reporting Schedule. The following reports and notifications shall be submitted to the Compliance Authority:

Report	Reporting Deadline	Related Condition(s)
Notification of Non-compliance	Within 1 working day	**A.14.**
RATA Summary Report	Within 45 days	**A.22.**

Report	Reporting Deadline	Related Condition(s)
Notice of Excess Emissions BACT standards	Quarterly	**A29.b.**
Notice of Excess Emissions NSPS standards	Semi-annual	**A.29.c.**

[Rule 62-213.440, F.A.C. and 40 CFR 60.7]

A.24. Other Reporting Requirements. See Appendix RR, Facility-Wide Reporting Requirements, for additional reporting requirements. [Rule 62-213.440, F.A.C.]

A.25. Monitoring of Capacity. The permittee shall monitor and record the operating rate of the combustion turbine on a daily average basis, considering the number of hours of operation during each day (including the times of startup, shutdown, malfunction, DLN tuning, and fuel switching). Such monitoring shall be made by monitoring daily rates of consumption and heat content of each allowable fuel in accordance with the provisions of 40 CFR 75 Appendix D. [Rules 62-4.070(3) & 62-210.200(BACT), F.A.C.; and, Permit No. 0310561-001-AC/PSD-FL-401, Specific Condition 29]

A.26. Monthly Operations Summary. By the 15th calendar day of each month, the permittee shall record the following for each fuel in a written or electronic log for the combustion turbine for the previous month of operation: fuel consumption, hours of operation on each fuel, and the updated calendar year totals for each. Information recorded and stored as an electronic file shall be available for inspection and printing within at least three days of a request by the Department. The fuel consumption shall be monitored in accordance with the provisions of 40 CFR 75 Appendix D. [Rules 62-4.070(3) & 62-210.200(BACT), F.A.C.; and, Permit No. 0310561-001-AC/PSD-FL-401, Specific Condition 30]

A.27. Fuel Sulfur Records. The permittee shall demonstrate compliance with the fuel sulfur limits specified in this permit by maintaining the following records of the sulfur contents.

a. *Natural Gas Sulfur Limit*. Compliance with the fuel sulfur limit for natural gas shall be demonstrated by keeping reports obtained from the vendor indicating the average sulfur content of the natural gas being supplied from the pipeline for each month of operation. Methods for determining the sulfur content of the natural gas shall be ASTM methods D4084-82, D4468-85, D5504-01, D6228-98 and D6667-01, D3246-81 or more recent versions.

b. *Distillate Fuel Oil Sulfur Limit*. Compliance with the distillate fuel oil sulfur limit shall be demonstrated by taking a sample, analyzing the sample for fuel sulfur, and reporting the results to each Compliance Authority before initial startup. Sampling the fuel oil sulfur content shall be conducted in accordance with ASTM D4057-88, Standard Practice for Manual Sampling of Petroleum and Petroleum Products, and one of the following test methods for sulfur in petroleum products: ASTM methods D5453-00, D129-91, D1552-90, D2622-94, D4294-90, or D7039. More recent versions of these methods may be used. For each subsequent fuel delivery, the permittee shall maintain a permanent file of the certified fuel sulfur analysis from the fuel vendor. At the request of the Compliance Authority, the permittee shall perform additional sampling and analysis for the fuel sulfur content.

The above methods shall be used to determine the fuel sulfur content in conjunction with the provisions of 40 CFR 75 Appendix D. [Rules 62-4.070(3), 62-4.160(15) & 62-213.440, F.A.C.; and, Permit No. 0310561-001-AC/PSD-FL-401, Specific Condition 31]

A.28. Emissions Performance Test Reports. A report indicating the results of any required emissions performance test shall be submitted to the Compliance Authority no later than 45 days after completion of the last test run. The test report shall provide sufficient detail on the tested emission unit and the procedures used to allow the Department to determine if the test was properly conducted and if the test results were properly computed. At a minimum, the test report shall provide the applicable information listed in Rule 62-297.310(8)(c), F.A.C. and in Appendix D of this permit. [Rule 62-297.310(8), F.A.C. and Permit No. 0310561-001-AC/PSD-FL-401, Specific Condition 32]

A.29. Excess Emissions Reporting.

a. *Malfunction Notification.* If emissions in excess of a standard (subject to the specified averaging period) occur due to malfunction, the permittee shall notify the Compliance Authority within one working day of: the nature, extent, and duration of the excess emissions; the cause of the excess emissions; and the actions taken to correct the problem. In addition, the Department may request a written summary report of the incident.

b. *SIP Quarterly Report*. Within 30 days following the end of each calendar-quarter, the permittee shall submit a report to the Compliance Authority summarizing periods of NO_X emissions in excess of the BACT permit standard following the NSPS format in 40 CFR 60.7(c), Subpart A. A summary of data excluded from SIP compliance calculations should also be provided. In addition, the report shall summarize the NO_X CEMS system monitor availability for the previous quarter.

c. *NSPS Reporting*. Within 30 days following the calendar semi-annual period, the permittee shall submit the written reports required by 40 CFR 60 Subpart KKKK (Standards of Performance for Stationary Combustion Turbines) for the previous semi-annual period to the Compliance Authority.

[Rules 62-4.130, 62-204.800, 62-210.700(6) & 62-212.400(BACT), F.A.C.; 40 CFR 60.7 & 60.4375; and, Permit No. 0310561-001-AC/PSD-FL-401, Specific Condition 33]

{Note: If there are no periods of excess emissions as defined in 40 CFR, Part 60, Subpart KKKK, a statement to that effect may be submitted with the SIP Quarterly Report to suffice for the NSPS Semi-Annual Report.}

Federal Requirements

A.30. NSPS Requirements. The combustion turbines shall comply with the applicable New Source Performance Standards (NSPS) in 40 CFR 60, including: Subpart A (General Provisions) and Subpart KKKK (Standards of Performance for Stationary Combustion Turbines for which Construction is Commenced after February 18, 2005). See Appendix NSPS, Subpart A – General Provisions and Appendix NSPS, Subpart KKKK – Standards of Performance for Stationary Combustion Turbines Constructed after February 18, 2005. The BACT emissions standards for NO_X and the fuel sulfur specifications for SO_2 are as stringent as, or more stringent than the NO_X and SO_2 limits imposed by the applicable NSPS provisions. Some separate reporting and monitoring may be required by the individual subparts. [Rule 62-204.800(7)(b), F.A.C.; 40 CFR 60, Subparts A and KKKK; and, Permit No. 0310561-001-AC/PSD-FL-401, Specific Condition 2]

The specific conditions in this section apply to the following emissions unit:

EU No.	Brief Description
004	One Emergency Fire Pump engine rated at 197 hp with associated 550 gallon fuel tank

This emergency fire pump engine was manufactured in 2010 and certified to EPA Tier 3 emission limits for stationary non road engines. It is subject to 40 CFR 63, Subpart ZZZZ, National Emission Standards for Reciprocating Internal Combustion Engines, as an area source of hazardous air pollutants which meets/exceeds the emission standards in Table 4 of 40 CFR 60 Subpart IIII, Standards of Performance for Stationary Compression Ignition Internal Combustion Engines.

The following table provides important details for this emissions unit:

E.U. ID No.	Engine Brake HP	Date of Construction	Model Year	Primary Fuel	Type of Engine	Displacement liters/cylinder (l/c)	Serial #
004	197	April 1, 2010	2010	Diesel	Emergency Fire Pump	1.1	PE6068L077020

{Permitting Note: This compression ignition (CI) reciprocating internal combustion engine (RICE) is regulated under 40 CFR 63, Subpart ZZZZ, NESHAP for Stationary RICE adopted in Rule 62.204.800(11)(b), F.A.C. and 40 CFR 60, Subpart IIII, NSPS. This RICE is used for fire pump service. This permit section addresses a fire pump engine manufactured as a certified National Fire Protection Association (NFPA) fire pump after July 1, 2006}

Essential Potential to Emit (PTE) Parameters

B.1. Allowable Fuel. The Stationary RICE must use diesel fuel that meets the following requirements:
a. *Sulfur Content.* The sulfur content shall not exceed 15 parts per million (ppm).
b. *Cetane and Aromatic*. The fuel must have a minimum cetane index of 40 or must have a maximum aromatic content of 35 volume percent.
[40 CFR 60.4207(b) and 80.510(b)]

B.2. Hours of Operation.
a. *Emergency Situations*. There is no time limit on the use of emergency stationary RICE in emergency situations.
b. *Maintenance and Testing.* This unit is authorized to operate for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by federal, state, or local government, the manufacturer, the vendor, or the insurance company associated with the engine. Maintenance checks and readiness testing of the unit is limited to 100 hours per year.
c. *Non-emergency Situations*. This engine is authorized to operate up to 50 hours per year in non-emergency situations, but those 50 hours are counted towards the 100 hours per year provided for maintenance and testing.
[40 CFR 60.4211(f)]

Control Technology

B.3. The owner shall operate and maintain the engine and controls according to the manufacturer's emission-related written instructions. [40 CFR 60.4211(a)(1)]

Emission Limitations and Standards

B.4. The following emissions limits must be met over the entire life of the engine:

a. *Nonmethane hydrocarbons (NMHC) plus Nitrogen Oxides (NO_X).* NMHC + NO_X shall not exceed 4.0 grams/kW-hr (3.0 grams/HP-hr).

b. *Particulate Matter (PM).* PM shall not exceed 0.20 grams/kW-hr (0.15 grams/HP-hr).

[40 CFR 60.4203, 40 CFR 60.4205(c) & 40 CFR 60 Subpart IIII, Table 4]

Test Methods and Procedures

B.5. Compliance. Compliance with the emissions limits in Specific Condition **B.4.** is met by purchasing an engine certified by the manufacturer to meet the emission standards specified in 40 CFR 60.4205(c). [40 CFR 60.4211(c)]

{Permitting Note: The emergency fire pump engine installed meets the more stringent limitations of EPA Tier 3 emission standards for stationary non road engines.}

General Provisions

B.6. The owner or operator must comply with the general provisions in 40 CFR 60 Subpart A (except 40 CFR 60.11) contained in Appendix NSPS Subpart A – General Provisions. [40 CFR 60.4218]

Operated by: JEA
Plant: Greenland Energy Center
ORIS Code: 56799

The emissions units listed below are regulated under Acid Rain, Phase II.

EU No.	EPA Unit ID#	Brief Description
001	1	Simple Cycle Combustion Turbine
002	2	Simple Cycle Combustion Turbine

A.1. The Phase II Acid Rain Part application submitted for this facility, as approved by the Department, is a part of this permit. The owners and operators of these Phase II acid rain units must comply with the standard requirements and special provisions set forth in the application listed below:
DEP Form No. 62-210.900(1)(a), dated 05/12/11, received 07/12/11.
[Chapter 62-213, F.A.C. and Rule 62-214.320,F.A.C.]

A.2. Sulfur dioxide (SO_2) Emission Allowances. SO_2 emissions from sources subject to the Federal Acid Rain Program (Title IV) shall not exceed any allowances that the source lawfully holds under the Federal Acid Rain Program. Allowances shall not be used to demonstrate compliance with a non-Title IV applicable requirement of the Act.

a. No permit revision shall be required for increases in emissions that are authorized by allowances acquired pursuant to the Federal Acid Rain Program, provided that such increases do not require a permit revision pursuant to Rule 62-213.400(3), F.A.C.
b. No limit shall be placed on the number of allowances held by the source under the Federal Acid Rain Program.
c. Allowances shall be accounted for under the Federal Acid Rain Program.

[Rule 62-213.440(1)(c)1., 2. & 3., F.A.C.]

A.3. Comments, Notes, and Justifications: The Acid Rain Application form that was submitted by JEA is below.

Acid Rain Part Application

For more information, see instructions and refer to 40 CFR 72.30, 72.31, and 74; and Chapter 62-214, F.A.C.

This submission is: ☐ New ☑ Revised ☐ Renewal

STEP 1

Identify the source by plant name, state, and ORIS or plant code.

Plant name: Greenland Energy Center	State: FL	ORIS/Plant Code: 56799

STEP 2
Enter the unit ID# for every Acid Rain unit at the Acid Rain source in column "a."

If unit a SO_2 Opt-in unit, enter "yes" in column "b".

For new units or SO_2 Opt-in units, enter the requested information in columns "d" and "e."

a	b	c	d	e
Unit ID#	SO_2 Opt-in Unit? (Yes or No)	Unit will hold allowances in accordance with 40 CFR 72.9(c)(1)	New or SO_2 Opt-in Units Commence Operation Date	New or SO_2 Opt-in Units Monitor Certification Deadline
1	No	Yes	June 2011	
2	No	Yes	June 2011	
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		

DEP Form No. 62-210.900(1)(a) – Form
Effective: 3/16/08

1

Plant Name (from STEP 1): Greenland Energy Center

STEP 3

Read the standard requirements.

Acid Rain Part Requirements.

(1) The designated representative of each Acid Rain source and each Acid Rain unit at the source shall:
(i) Submit a complete Acid Rain Part application (including a compliance plan) under 40 CFR Part 72 and Rules 62-214.320 and 330, F.A.C., in accordance with the deadlines specified in Rule 62-214.320, F.A.C.; and
(ii) Submit in a timely manner any supplemental information that the DEP determines is necessary in order to review an Acid Rain Part application and issue or deny an Acid Rain Part;
(2) The owners and operators of each Acid Rain source and each Acid Rain unit at the source shall:
(i) Operate the unit in compliance with a complete Acid Rain Part application or a superseding Acid Rain Part issued by the DEP; and
(ii) Have an Acid Rain Part.

Monitoring Requirements.

(1) The owners and operators and, to the extent applicable, designated representative of each Acid Rain source and each Acid Rain unit at the source shall comply with the monitoring requirements as provided in 40 CFR Part 75, and Rule 62-214.420, F.A.C.
(2) The emissions measurements recorded and reported in accordance with 40 CFR Part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
(3) The requirements of 40 CFR Part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.
(4) For applications including a SO_2 Opt-in unit, a monitoring plan for each SO_2 Opt-in unit must be submitted with this application pursuant to 40 CFR 74.14(a). For renewal applications for SO_2 Opt-in units include an updated monitoring plan if applicable under 40 CFR 75.53(b).

Sulfur Dioxide Requirements.

(1) The owners and operators of each source and each Acid Rain unit at the source shall:
(i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)), or in the compliance subaccount of another Acid Rain unit at the same source to the extent provided in 40 CFR 73.35(b)(3), not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and
(ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
(2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
(3) An Acid Rain unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
(i) Starting January 1, 2000, an Acid Rain unit under 40 CFR 72.6(a)(2); or
(ii) Starting on the later of January 1, 2000, or the deadline for monitor certification under 40 CFR Part 75, an Acid Rain unit under 40 CFR 72.6(a)(3).
(4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
(5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
(6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain Part application, the Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
(7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

Nitrogen Oxides Requirements. The owners and operators of the source and each Acid Rain unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

Excess Emissions Requirements.

(1) The designated representative of an Acid Rain unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR Part 77.
(2) The owners and operators of an Acid Rain unit that has excess emissions in any calendar year shall:
(i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR Part 77; and
(ii) Comply with the terms of an approved offset plan, as required by 40 CFR Part 77.

Recordkeeping and Reporting Requirements.

(1) Unless otherwise provided, the owners and operators of the source and each Acid Rain unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the EPA or the DEP:
(i) The certificate of representation for the designated representative for the source and each Acid Rain unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with Rule 62-214.350, F.A.C.; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;
(ii) All emissions monitoring information, in accordance with 40 CFR Part 75, provided that to the extent that 40 CFR Part 75 provides for a 3-year period for recordkeeping, the 3-year period shall apply;
(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and,

Plant Name (from STEP 1): Greenland Energy Center

STEP 3, Continued.

Recordkeeping and Reporting Requirements (cont)

(iv) Copies of all documents used to complete an Acid Rain Part application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.

(2) The designated representative of an Acid Rain source and each Acid Rain unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR Part 72, Subpart I, and 40 CFR Part 75.

Liability.

(1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain Part application, an Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.
(2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.
(3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.
(4) Each Acid Rain source and each Acid Rain unit shall meet the requirements of the Acid Rain Program.
(5) Any provision of the Acid Rain Program that applies to an Acid Rain source (including a provision applicable to the designated representative of an Acid Rain source) shall also apply to the owners and operators of such source and of the Acid Rain units at the source.
(6) Any provision of the Acid Rain Program that applies to an Acid Rain unit (including a provision applicable to the designated representative of an Acid Rain unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR 72.44 (Phase II repowering extension plans) and 40 CFR 76.11 (NO_x averaging plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR Part 75 (including 40 CFR 75.16, 75.17, and 75.18), the owners and operators and the designated representative of one Acid Rain unit shall not be liable for any violation by any other Acid Rain unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative.
(7) Each violation of a provision of 40 CFR Parts 72, 73, 74, 75, 76, 77, and 78 by an Acid Rain source or Acid Rain unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

Effect on Other Authorities.

No provision of the Acid Rain Program, an Acid Rain Part application, an Acid Rain Part, or an exemption under 40 CFR 72.7or 72.8 shall be construed as:
(1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an Acid Rain source or Acid Rain unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;
(2) Limiting the number of allowances a unit can hold; *provided*, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Act;
(3) Requiring a change of any kind in any state law regulating electric utility rates and charges, affecting any state law regarding such state regulation, or limiting such state regulation, including any prudence review requirements under such state law;
(4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,
(5) Interfering with or impairing any program for competitive bidding for power supply in a state in which such program is established.

STEP 4
For SO_2 Opt-in units only.

In column "f" enter the unit ID# for every SO_2 Opt-in unit identified in column "a" of STEP 2.

For column "g" describe the combustion unit and attach information and diagrams on the combustion unit's configuration.

In column "h" enter the hours.

f	g	h (not required for renewal application)
Unit ID#	Description of the combustion unit	Number of hours unit operated in the six months preceding initial application

DEP Form No. 62-210.900(1)(a) – Form
Effective: 3/16/08

3

Plant Name (from STEP 1): Greenland Energy Center

STEP 5

For SO_2 Opt-in units only.
(Not required for SO_2 Opt-in renewal applications.)

In column "i" enter the unit ID# for every SO_2 Opt-in unit identified in column "a" (and in column "f").

For columns "j" through "n," enter the information required under 40 CFR 74.20-74.25 and attach all supporting documentation required by 40 CFR 74.20-74.25.

i	j	k	l	m	n
Unit ID#	Baseline or Alternative Baseline under 40 CFR 74.20 (mmBtu)	Actual SO_2 Emissions Rate under 40 CFR 74.22 (lbs/mmBtu)	Allowable 1985 SO_2 Emissions Rate under 40 CFR 74.23 (lbs/mmBtu)	Current Allowable SO_2 Emissions Rate under 40 CFR 74.24 (lbs/mmBtu)	Current Promulgated SO_2 Emissions Rate under 40 CFR 74.25 (lbs/mmBtu)

STEP 6

For SO_2 Opt-in units only.

Attach additional requirements, certify and sign.

A. If the combustion source seeks to qualify for a transfer of allowances from the replacement of thermal energy, a thermal energy plan as provided in 40 CFR 74.47 for combustion sources must be attached.
B. A statement whether the combustion unit was previously an affected unit under 40 CFR 74.
C. A statement that the combustion unit is not an affected unit under 40 CFR 72.6 and does not have an exemption under 40 CFR 72.7, 72.8, or 72.14.
D. Attach a complete compliance plan for SO_2 under 40 CFR 72.40.
E. The designated representative of the combustion unit shall submit a monitoring plan in accordance with 40 CFR 74.61. For renewal application, submit an updated monitoring plan if applicable under 40 CFR 75.53(b).
F. The following statement must be signed by the designated representative or alternate designated representative of the combustion source: "I certify that the data submitted under 40 CFR Part 74, Subpart C, reflects actual operations of the combustion source and has not been adjusted in any way."

Signature	Date

STEP 7

Read the certification statement; provide name, title, owner company name, phone, and e-mail address; sign, and date.

Certification (for designated representative or alternate designated representative only)

I am authorized to make this submission on behalf of the owners and operators of the Acid Rain source or Acid Rain units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name: Athena T. Mann	Title: Vice President, Environmental Services
Owner Company Name: JEA	
Phone: (904) 665-6252	E-mail address: mannat@jea.com
Signature: A T Mann	Date: 5/12/10

DEP Form No. 62-210.900(1)(a) – Form
Effective: 3/16/08

4

Clean Air Interstate Rule (CAIR).

Operated by: JEA
Plant: Greenland Energy Center
ORIS Code: 56799

The emissions units below are regulated under the Clean Air Interstate Rule.

EU No.	EPA Unit ID#	Brief Description
001	1	Simple Cycle Combustion Turbine
002	2	Simple Cycle Combustion Turbine

1. Clean Air Interstate Rule Application. The Clean Air Interstate Rule Part Form submitted for this facility is a part of this permit. The owners and operators of these CAIR units as identified in this form must comply with the standard requirements and special provisions set forth in the CAIR Part Form (DEP Form No. 62-210.900(1)(b)) dated May 12, 2010, which is below. [Chapter 62-213, F.A.C. and Rule 62-210.200, F.A.C.]
2. The CAIR Application form that was submitted by JEA is below.

Clean Air Interstate Rule (CAIR) Part

For more information, see instructions and refer to 40 CFR 96.121, 96.122, 96.221, 96.222, 96.321 and 96.322; and Rule 62-296.470, F.A.C.

This submission is: ✓ New ☐ Revised ☐ Renewal

STEP 1

Identify the source by plant name and ORIS or EIA plant code

Plant Name: Greenland Energy Center	State: Florida	ORIS or EIA Plant Code: 56799

STEP 2

In column "a" enter the unit ID# for every CAIR unit at the CAIR source.

In columns "b," "c," and "d," indicate to which CAIR program(s) each unit is subject by placing an "X" in the column(s).

For new units, enter the requested information in columns "e" and "f.

a	b	c	d	e	f
Unit ID#	Unit will hold nitrogen oxides (NO_x) allowances in accordance with 40 CFR 96.106(c)(1)	Unit will hold sulfur dioxide (SO_2) allowances in accordance with 40 CFR 96.206(c)(1)	Unit will hold NO_x Ozone Season allowances in accordance with 40 CFR 96.306(c)(1)	New Units Expected Commence Commercial Operation Date	New Units Expected Monitor Certification Deadline
1	X	X	X	June 2011	
2	X	X	X	June 2011	

DEP Form No. 62-210.900(1)(b) – Form
Effective: 3/16/08

1

Plant Name (from STEP 1)	Greenland Energy Center

STEP 3

Read the standard requirements.

CAIR NO_X ANNUAL TRADING PROGRAM

CAIR Part Requirements.

(1) The CAIR designated representative of each CAIR NO_X source and each CAIR NO_X unit at the source shall:
(i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.122 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
(ii) [Reserved];
(2) The owners and operators of each CAIR NO_X source and each CAIR NO_X unit at the source shall have a CAIR Part included in the Title V operating permit issued by the DEP under 40 CFR Part 96, Subpart CC, and operate the source and the unit in compliance with such CAIR Part.

Monitoring, Reporting, and Recordkeeping Requirements.

(1) The owners and operators, and the CAIR designated representative, of each CAIR NO_X source and each CAIR NO_X unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96, Subpart HH, and Rule 62-296.470, F.A.C.
(2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HH, shall be used to determine compliance by each CAIR NO_X source with the following CAIR NO_X Emissions Requirements.

NO_X Emission Requirements.

(1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO_X source and each CAIR NO_X unit at the source shall hold, in the source's compliance account, CAIR NO_X allowances available for compliance deductions for the control period under 40 CFR 96.154(a) in an amount not less than the tons of total NO_X emissions for the control period from all CAIR NO_X units at the source, as determined in accordance with 40 CFR Part 96, Subpart HH.
(2) A CAIR NO_X unit shall be subject to the requirements under paragraph (1) of the NO_X Requirements starting on the later of January 1, 2009, or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.170(b)(1) or (2) and for each control period thereafter.
(3) A CAIR NO_X allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the NO_X Requirements, for a control period in a calendar year before the year for which the CAIR NO_X allowance was allocated.
(4) CAIR NO_X allowances shall be held in, deducted from, or transferred into or among CAIR NO_X Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FF and GG.
(5) A CAIR NO_X allowance is a limited authorization to emit one ton of NO_X in accordance with the CAIR NO_X Annual Trading Program. No provision of the CAIR NO_X Annual Trading Program, the CAIR Part, or an exemption under 40 CFR 96.105 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
(6) A CAIR NO_X allowance does not constitute a property right.
(7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart EE, FF, or GG, every allocation, transfer, or deduction of a CAIR NO_X allowance to or from a CAIR NO_X unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR NO_X unit.

Excess Emissions Requirements.

If a CAIR NO_X source emits NO_X during any control period in excess of the CAIR NO_X emissions limitation, then:
(1) The owners and operators of the source and each CAIR NO_X unit at the source shall surrender the CAIR NO_X allowances required for deduction under 40 CFR 96.154(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and
(2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AA, the Clean Air Act, and applicable state law.

Recordkeeping and Reporting Requirements.

(1) Unless otherwise provided, the owners and operators of the CAIR NO_X source and each CAIR NO_X unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the DEP or the Administrator.
(i) The certificate of representation under 40 CFR 96.113 for the CAIR designated representative for the source and each CAIR NO_X unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 96.113 changing the CAIR designated representative.
(ii) All emissions monitoring information, in accordance with 40 CFR Part 96, Subpart HH, of this part, provided that to the extent that 40 CFR Part 96, Subpart HH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.
(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO_X Annual Trading Program.
(iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR NO_X Annual Trading Program or to demonstrate compliance with the requirements of the CAIR NO_X Annual Trading Program.
(2) The CAIR designated representative of a CAIR NO_X source and each CAIR NO_X unit at the source shall submit the reports required under the CAIR NO_X Annual Trading Program, including those under 40 CFR Part 96, Subpart HH.

STEP 3, Continued

Liability.

(1) Each CAIR NO_X source and each CAIR NO_X unit shall meet the requirements of the CAIR NO_X Annual Trading Program.
(2) Any provision of the CAIR NO_X Annual Trading Program that applies to a CAIR NO_X source or the CAIR designated representative of a CAIR
NO_X source shall also apply to the owners and operators of such source and of the CAIR NO_X units at the source.
(3) Any provision of the CAIR NO_X Annual Trading Program that applies to a CAIR NO_X unit or the CAIR designated representative of a CAIR NO_X unit shall also apply to the owners and operators of such unit.

Effect on Other Authorities.

No provision of the CAIR NO_X Annual Trading Program, a CAIR Part, or an exemption under 40 CFR 96.105 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO_X source or CAIR NO_X unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

CAIR SO_2 TRADING PROGRAM

CAIR Part Requirements.

(1) The CAIR designated representative of each CAIR SO_2 source and each CAIR SO_2 unit at the source shall:
(i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.222 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
(ii) [Reserved];
(2) The owners and operators of each CAIR SO_2 source and each CAIR SO_2 unit at the source shall have a CAIR Part included in the Title V operating permit issued by the DEP under 40 CFR Part 96, Subpart CCC, for the source and operate the source and each CAIR unit in compliance with such CAIR Part.

Monitoring, Reporting, and Recordkeeping Requirements.

(1) The owners and operators, and the CAIR designated representative, of each CAIR SO_2 source and each SO_2 CAIR unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96 ,Subpart HHH, and Rule 62-296.470, F.A.C.
(2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HHH, shall be used to determine compliance by each CAIR SO_2 source with the following CAIR SO_2 Emission Requirements.

SO_2 Emission Requirements.

(1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR SO_2 source and each CAIR SO_2 unit at the source shall hold, in the source's compliance account, a tonnage equivalent in CAIR SO_2 allowances available for compliance deductions for the control period, as determined in accordance with 40 CFR 96.254(a) and (b), not less than the tons of total sulfur dioxide emissions for the control period from all CAIR SO_2 units at the source, as determined in accordance with 40 CFR Part 96, Subpart HHH.
(2) A CAIR SO_2 unit shall be subject to the requirements under paragraph (1) of the Sulfur Dioxide Emission Requirements starting on the later of January 1, 2010 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.270(b)(1) or (2) and for each control period thereafter.
(3) A CAIR SO_2 allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the SO_2 Emission Requirements, for a control period in a calendar year before the year for which the CAIR SO_2 allowance was allocated.
(4) CAIR SO_2 allowances shall be held in, deducted from, or transferred into or among CAIR SO_2 Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FFF and GGG.
(5) A CAIR SO_2 allowance is a limited authorization to emit sulfur dioxide in accordance with the CAIR SO_2 Trading Program. No provision of the CAIR SO_2 Trading Program, the CAIR Part, or an exemption under 40 CFR 96.205 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
(6) A CAIR SO_2 allowance does not constitute a property right.
(7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart FFF or GGG, every allocation, transfer, or deduction of a CAIR SO_2 allowance to or from a CAIR SO_2 unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR SO_2 unit.

Excess Emissions Requirements.

If a CAIR SO_2 source emits SO_2 during any control period in excess of the CAIR SO_2 emissions limitation, then:
(1) The owners and operators of the source and each CAIR SO_2 unit at the source shall surrender the CAIR SO_2 allowances required for deduction under 40 CFR 96.254(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and
(2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AAA, the Clean Air Act, and applicable state law.

Plant Name (from STEP 1) Greenland Energy Center

STEP 3, Continued

Recordkeeping and Reporting Requirements.

(1) Unless otherwise provided, the owners and operators of the CAIR SO_2 source and each CAIR SO_2 unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Department or the Administrator.

(i) The certificate of representation under 40 CFR 96.213 for the CAIR designated representative for the source and each CAIR SO_2 unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 96.213 changing the CAIR designated representative.

(ii) All emissions monitoring information, in accordance with 40 CFR Part 96, Subpart HHH, of this part, provided that to the extent that 40 CFR Part 96, Subpart HHH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR SO_2 Trading Program.

(iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR SO_2 Trading Program or to demonstrate compliance with the requirements of the CAIR SO_2 Trading Program.

(2) The CAIR designated representative of a CAIR SO_2 source and each CAIR SO_2 unit at the source shall submit the reports required under the CAIR SO_2 Trading Program, including those under 40 CFR Part 96, Subpart HHH.

Liability.

(1) Each CAIR SO_2 source and each CAIR SO_2 unit shall meet the requirements of the CAIR SO_2 Trading Program.

(2) Any provision of the CAIR SO_2 Trading Program that applies to a CAIR SO_2 source or the CAIR designated representative of a CAIR SO_2 source shall also apply to the owners and operators of such source and of the CAIR SO_2 units at the source.

(3) Any provision of the CAIR SO_2 Trading Program that applies to a CAIR SO_2 unit or the CAIR designated representative of a CAIR SO_2 unit shall also apply to the owners and operators of such unit.

Effect on Other Authorities.

No provision of the CAIR SO_2 Trading Program, a CAIR Part, or an exemption under 40 CFR 96.205 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR SO_2 source or CAIR SO_2 unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

CAIR NO_x OZONE SEASON TRADING PROGRAM

CAIR Part Requirements.

(1) The CAIR designated representative of each CAIR NO_X Ozone Season source and each CAIR NO_X Ozone Season unit at the source shall:

(i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.322 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and

(ii) [Reserved];

(2) The owners and operators of each CAIR NO_X Ozone Season source required to have a Title V operating permit or air construction permit, and each CAIR NO_X Ozone Season unit required to have a Title V operating permit or air construction permit at the source shall have a CAIR Part included in the Title V operating permit or air construction permit issued by the DEP under 40 CFR Part 96, Subpart CCCC, for the source and operate the source and the unit in compliance with such CAIR Part.

Monitoring, Reporting, and Recordkeeping Requirements.

(1) The owners and operators, and the CAIR designated representative, of each CAIR NO_X Ozone Season source and each CAIR NO_x Ozone Season unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96, Subpart HHHH, and Rule 62-296.470, F.A.C.

(2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HHHH, shall be used to determine compliance by each CAIR NO_X Ozone Season source with the following CAIR NO_X Ozone Season Emissions Requirements.

NO_x Ozone Season Emission Requirements.

(1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO_X Ozone Season source and each CAIR NO_X Ozone Season unit at the source shall hold, in the source's compliance account, CAIR NO_X Ozone Season allowances available for compliance deductions for the control period under 40 CFR 96.354(a) in an amount not less than the tons of total NO_X emissions for the control period from all CAIR NO_X Ozone Season units at the source, as determined in accordance with 40 CFR Part 96, Subpart HHHH.

(2) A CAIR NO_X Ozone Season unit shall be subject to the requirements under paragraph (1) of the NO, Ozone Season Emission Requirements starting on the later of May 1, 2009 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.370(b)(1),(2), or (3) and for each control period thereafter.

(3) A CAIR NO_X Ozone Season allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the NO_X Ozone Season Emission Requirements, for a control period in a calendar year before the year for which the CAIR NO_X Ozone Season allowance was allocated.

(4) CAIR NO_X Ozone Season allowances shall be held in, deducted from, or transferred into or among CAIR NO_X Ozone Season Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FFFF and GGGG.

(5) A CAIR NO_X Ozone Season allowance is a limited authorization to emit one ton of NO_X in accordance with the CAIR NO_X Ozone Season Trading Program. No provision of the CAIR NO_X Ozone Season Trading Program, the CAIR Part, or an exemption under 40 CFR 96.305 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.

(6) A CAIR NO_X Ozone Season allowance does not constitute a property right.

(7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart EEEE, FFFF or GGGG, every allocation, transfer, or deduction of a CAIR NO_X Ozone Season allowance to or from a CAIR NO_X Ozone Season unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR NO_X Ozone Season unit.

Plant Name (from STEP 1) Greenland Energy Center

STEP 3, Continued

Excess Emissions Requirements.

If a CAIR NO_X Ozone Season source emits NO_X during any control period in excess of the CAIR NO_X Ozone Season emissions limitation, then:
(1) The owners and operators of the source and each CAIR NO_X Ozone Season unit at the source shall surrender the CAIR NO_X Ozone Season allowances required for deduction under 40 CFR 96.354(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and
(2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AAAA, the Clean Air Act, and applicable state law.

Recordkeeping and Reporting Requirements.

(1) Unless otherwise provided, the owners and operators of the CAIR NO_X Ozone Season source and each CAIR NO_X Ozone Season unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the DEP or the Administrator.
(i) The certificate of representation under 40 CFR 96.313 for the CAIR designated representative for the source and each CAIR NO_X Ozone Season unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 96.113 changing the CAIR designated representative.
(ii) All emissions monitoring information, in accordance with 40 CFR Part 96, Subpart HHHH, of this part, provided that to the extent that 40 CFR Part 96, Subpart HHHH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.
(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO_X Ozone Season Trading Program.
(iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR NO_X Ozone Season Trading Program or to demonstrate compliance with the requirements of the CAIR NO_X Ozone Season Trading Program.
(2) The CAIR designated representative of a CAIR NO_X Ozone Season source and each CAIR NO_X Ozone Season unit at the source shall submit the reports required under the CAIR NO_X Ozone Season Trading Program, including those under 40 CFR Part 96, Subpart HHHH.

Liability.

(1) Each CAIR NO_X Ozone Season source and each CAIR NO_X Ozone Season unit shall meet the requirements of the CAIR NO_X Ozone Season Trading Program.
(2) Any provision of the CAIR NO_X Ozone Season Trading Program that applies to a CAIR NO_X Ozone Season source or the CAIR designated representative of a CAIR NO_X Ozone Season source shall also apply to the owners and operators of such source and of the CAIR NO_X Ozone Season units at the source.
(3) Any provision of the CAIR NO_X Ozone Season Trading Program that applies to a CAIR NO_X Ozone Season unit or the CAIR designated representative of a CAIR NO_X Ozone Season unit shall also apply to the owners and operators of such unit.

Effect on Other Authorities.

No provision of the CAIR NO_X Ozone Season Trading Program, a CAIR Part, or an exemption under 40 CFR 96.305 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO_X Ozone Season source or CAIR NO_X Ozone Season unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

STEP 4

Read the certification statement; provide name, title, owner company name, phone, and e-mail address; sign, and date.

Certification (for designated representative or alternate designated representative only)

I am authorized to make this submission on behalf of the owners and operators of the CAIR source or CAIR units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name: Athena T. Mann	Title: Vice President, Environmental Services
Company Owner Name: JEA	
Phone: (904) 665-6252	E-mail Address: mannat@jea.com
Signature *A T Mann*	Date *5/12/10*

SECTION VI. APPENDICES.

The Following Appendices Are Enforceable Parts of This Permit:

Appendix A	Glossary of Terms.
Appendix A1	40 CFR 60, NSPS Subpart A - General Conditions.
Appendix A2	40 CFR 63, NESHAP Subpart A - General Conditions.
Appendix I	List of Insignificant Emissions Units and/or Activities.
Appendix KKKK	40 CFR 60, NSPS Subpart KKKK - Standards of Performance for Stationary Combustion Turbines
Appendix RR	Facility-wide Reporting Requirements.
Appendix TR	Facility-wide Testing Requirements.
Appendix TV	Title V General Conditions.

Referenced Attachments

Figure 1, Summary Report-Gaseous and Opacity Excess Emission and Monitoring System Performance (40 CFR 60, July, 1996).

Table H, Permit History.

Table 1, Summary of Air Pollutant Standards.

Table 2, Summary of Compliance Requirements.