



# Department of Environmental Protection

# FILE COPY

*Minor*

Lawton Chiles  
Governor

Northwest District  
160 Governmental Center  
Pensacola, Florida 32501-5794

Virginia B. Wetherell  
Secretary

I.D. Number: 0330064  
Air Permit Number: 0330064001AO  
Date of Issue: March 29, 1997  
Expiration Date: March 29, 2001  
Amended: March 18, 1997  
County: Escambia  
Project: Four Boilers Nos. 1, 2, 5 and 6

**ENTERED**

**MAR 19 1997**

Earl Smith  
Director, Plant Operation, Maintenance and Engineering Services  
University of West Florida  
11000 University Parkway  
Pensacola, Florida 32514-5750

Dear Mr. Smith:

This is in response to the letter from Johnnie Cordeiro dated January 28, 1997 requesting changes in the operating permit for Boilers 1, 2, 5 and 6 at your Pensacola, Florida campus. This is done to allow for operational flexibility of the aging units and to compensate for additional loading due to the facility-wide HVAC changeout. The increase in hours allows UWF to "take back" some of the operating hours which UWF gave up in their previous permit applications.

By this letter, Four Boilers Nos. 1, 2, 5 and 6, Air Operating Permit Number: 0330064001AO, source I.D. Numbers 0330064001, 002, 003 and 004, are amended as follows:

**Specific Condition 2 From:**

2. The maximum allowable hours of operation and maximum allowable operating rates, Heat Inputs, are listed below:

Boiler No.	Source ID #	Maximum Hours/Yr	Max. Heat Input Million Btu/hr
1	001	2688	63.5
3	002	5376	33.5
5	003	336	4.5
6	004	2688	1.6

These are the operating rates at which compliance with standards shall be demonstrated. [FAC Rule 62-4.070 and construction and renewal permit applications]

To:


2. The maximum allowable hours of operation and maximum allowable operating rates, Heat Inputs, are listed below:

<u>Boiler No.</u>	<u>Source ID #</u>	<u>Maximum Hours/Yr</u>	<u>Max. Heat Input Million Btu/hr</u>
1	001	8,760	63.5
3	002	8,760	33.5
5	003	2,688	4.5
6	004	4,464	1.6

These are the operating rates at which compliance with standards shall be demonstrated. [FAC Rule 62-4.070 and construction and renewal permit applications, and letter of January 28, 1997]

All other permit conditions remain in effect. This letter shall be attached to, and become a part of, air operating permit 0330064001AO.

Sincerely,



Ed K. Middleswart, P.E.  
Air Program Administrator

EKM:asc