

Robert B. Williams  
Hospital Administrator  
Florida State Hospital  
P O Box 1000  
Chattahoochee FL 32324-1000

AIRS I.D. Number: 0390004  
Air Permit Number: 0390004-002-AO  
Date of Issue: February 28, 1997  
Amended: February 2, 1998  
Expiration Date: February 1, 2002

Dear Mr. Williams:

This is in response to your letter dated December 4, 1997 requesting a permit amendment to require testing by the end of February. By this letter, permit 0390004-002-AO is amended.

Specific Condition 10 is replaced with:

10. Visible emissions tests are required to show compliance with the standards of the Department. The test results must provide reasonable assurance that the source is capable of compliance at the permitted maximum operating rate. [Rule 62-297.310(2), F.A.C.] Tests shall be conducted in accordance with DEP Method 9 for one (1) hour. Such tests shall be scheduled for a boiler forty-five (45) days after the initial No. 6 fuel oil change for that boiler is completed, or at the minimum, by the end of February each year. The Department shall be notified at least fifteen (15) days prior to testing to allow witnessing. Results shall be submitted to the Department within forty-five (45) days after testing.

The Department can require special compliance tests in accordance with Rule 62-297.310(7)(b), F.A.C. Other test methods and alternate compliance procedures may be used only after prior Departmental approval has been obtained in writing.

Testing of emissions shall be conducted with the source operating at capacity. Capacity is defined as 90-100% of rated capacity. If it is impractical to test at capacity, then sources may be tested at less than capacity. In this case, subsequent source operation is limited to 110% of the test load until a new test is conducted. Once the unit is so limited, then operation at higher capacities is allowed for no more that fifteen (15) days for purposes of notification to the Department. [Rule 62-297.310(2), F.A.C.]

This letter shall be attached to and made a part of permit 0390004-002-AO.

Sincerely,

Ed K. Middleswart, P.E.  
Air Program Administrator

EKM:cmc

cc: DEP Northwest District Branch Office, Tallahassee