Appendix I-1: List of Insignificant Emissions Units and/or Activities.

The facilities, emissions units, or pollutant-emitting activities listed in Rule 62-210.300(3)(a), F.A.C., Categorical Exemptions, are exempt from the permitting requirements of Chapters 62-210 and 62-4, F.A.C.; provided, however, that exempt emissions units shall be subject to any applicable emission limiting standards and the emissions from exempt emissions units or activities shall be considered in determining the potential emissions of the facility containing such emissions units. Emissions units and pollutant-emitting activities exempt from permitting under Rule 62-210.300(3)(a), F.A.C., shall not be exempt from the permitting requirements of Chapter 62-213, F.A.C., if they are contained within a Title V source; however, such emissions units and activities shall be considered insignificant for Title V purposes provided they also meet the criteria of Rule 62-213.430(6)(b), F.A.C. No emissions unit shall be entitled to an exemption from permitting under Rule 62.210.300(3)(a), F.A.C., if its emissions, in combination with the emissions of other units and activities at the facility, would cause the facility to emit or have the potential to emit any pollutant in such amount as to make the facility a Title V source.

The below listed emissions units and/or activities are considered insignificant pursuant to Rule 62-213.430(6), F.A.C.

Brief Description of Emissions Units and/or Activities

1. One 637 BHP natural gas fired emergency generator operated less than 500 hours per year. Records shall be maintained and available for Department inspection showing the hours of operation.

2. Lube Oil Storage Tanks - one 3,000-gallon and one 10,000-gallon horizontal lube oil (0.02 psia true vapor pressure) storage tanks.

3. Used Lube Oil Tank - one 3,780-gallon used lube oil storage tank.

4. Oily Water Tanks - two 210-barrel wastewater with used lube oil (0.02 psia true vapor pressure) storage tanks.

5. Pipeline Condensate Tank - one 210-barrel pipeline condensate (organic liquid with 1.4 psia Reid vapor pressure) storage tank.

6. Lube Oil Rundown Tank - one 1,000-gallon lube oil (0.02 psia true vapor pressure) storage tank.

7. One 350-gallon diesel fuel storage tank.

8. One 250-gallon gasoline fuel storage tank.

9. Parts Cleaners - parts cleaners used to clean engine parts with naphtha containing cleaning fluid.

10. Paint Cleaner - paint cleaner used to clean painting materials with naphtha containing cleaning fluid.

11. Blow-down Stacks - stacks used for emergency or maintenance to blow-down natural gas.

12. Fugitive Component Leaks - leaks from valves, flanges and other components.

13. Emergency Generators FGTC GEN04 and FGTC GEN05