Appendix I-1: List of Insignificant Emissions Units and/or Activities.

Eastern Associated Terminals Company, LLC
Fertilizer Product Material Handling Facility

Draft Permit No.: 0570014-020-AV
Facility ID No.: 0570014

The facilities, emissions units, or pollutant-emitting activities listed in Rule 62-210.300(3)(a), F.A.C., Categorical Exemptions, or that meet the criteria specified in Rule 62-210.300(3)(b)1., F.A.C., Generic Emissions Unit Exemption, are exempt from the permitting requirements of Chapters 62-210, 62-212 and 62-4, F.A.C.; provided, however, that exempt emissions units shall be subject to any applicable emission limiting standards and the emissions from exempt emissions units or activities shall be considered in determining the potential emissions of the facility containing such emissions units. Emissions units and pollutant-emitting activities exempt from permitting under Rules 62-210.300(3)(a) and (b)1., F.A.C., shall not be exempt from the permitting requirements of Chapter 62-213, F.A.C., if they are contained within a Title V source; however, such emissions units and activities shall be considered insignificant for Title V purposes provided they also meet the criteria of Rule 62-213.430(6)(b), F.A.C. No emissions unit shall be entitled to an exemption from permitting under Rules 62-210.300(3)(a) and (b)1., F.A.C., if its emissions, in combination with the emissions of other units and activities at the facility, would cause the facility to emit or have the potential to emit any pollutant in such amount as to make the facility a Title V source.

The below listed emissions units and/or activities are considered insignificant pursuant to Rule 62-213.430(6), F.A.C.

Brief Description of Emissions Units and/or Activities

1. Cold parts washer using only kerosene and mineral spirits.
2. Maintenance painting.
3. Thinners used during maintenance painting.
4. Kerosene powered steam cleaner.
5. Gas welder.
6. Lubricating oils.
7. Above ground fuel tank with 500 gallon diesel and 500 gallon gasoline compartments.
8. Spillage building. (Small metal structure used to store spilled product until it is hauled off site.)
9. Two 4500 ACFM 64S-8-20 Mikro-Pulsaire, Model No. 64S-8-20, controlling emissions from the C4 to C4A transfer point and the C10 to C4A transfer point. These baghouses vent indoors.