Table 2-1, Summary of Compliance Requirements

Dudley Tarlton/TPSI Terminal, LLP
Tampa

PERMIT NO.:
Facility ID No.:

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
001	**Truck Loading Rack**
002	**Distillate Tank Group**
005	**Gasoline Tank Group**
008	**Additive Tank Group**

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**
VOC		Method 21 and 27		every tank truck		
VOC		Recordkeeping	Daily, Monthly			
Back-up Flare						
Opacity		Method 22	5 years	120 days prior to expiration	2 hours	
VOC		Heating Value	5 years	120 days prior to expiration		
VOC		Flare Tip Velocity	5 years	120 days prior to expiration		
			(or annual if flare used for more than 10% of total loadout)			
VCU Total Gaseous Organic Concentration		Method 25A and 25B Method 2A,2B	annual	8/1/2006	6 hours	

Notes:
* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
**CMS [=] continuous monitoring system

0570081-016-AV
0570081

See permit condition(s)
B.7, B.8
B.14, B.15, B.16, B.17, B.18
B.8, B.9
B.8, B.9
B.8, B.9
B.9