REQUIREMENTS FOR INTERNAL COMBUSTION ENGINES

This Title V facility contains stationary internal combustion engines that have been exempted from the requirement to obtain an air construction permit because they qualify for one of the categorical exemptions listed in Rule 62-210.300(3)(a), Florida Administrative Code (F.A.C.). However, they are included in this permit as regulated emissions units because they are subject to one or more of the following federal rules:

- 40 CFR 60 Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines.
- 40 CFR 63 Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.

The below listed engine(s) is subject to the specified federal rules.

E.U. ID No.	**Brief Description of Engine**	**Year Built**	**Displacement or Horsepower**	**Rule Applicability**
-018	175 HP Clarke fire pump	2007	175 HP	IIII and ZZZZ

Per 40 CFR 63.6590(a)(2)(iii), EU No. 018 is a new stationary RICE because the facility commenced construction or reconstruction of the stationary RICE on or after June 12, 2006. In accordance with 40 CFR 63.6590(c)(i), EU No. 018 meets the requirements of 40 CFR 63 Subpart ZZZZ by meeting the requirements of 40 CFR 60 Subpart IIII. No further requirements apply for this engine under 40 CFR 63 Subpart ZZZZ.