December 11, 2012

Peter Haid
Hess Corporation
1 Hess Plaza
Woodbridge, NJ 07095

Re: Title V Air Operation Permit Renewal
PROPOSED Permit Project No.: 0570123-031-AV
Hess Corporation

Dear Mr. Haid:

One copy of the "PROPOSED Determination" for the Title V Air Operation Permit Renewal for Hess Corporation located at 504 North 19th Street, Tampa, Hillsborough County, is enclosed. This letter is only a courtesy to inform you that the DRAFT Permit has become a PROPOSED Permit.

An electronic version of this determination has been posted on the Division of Air Resources Management's world wide web site for the United States Environmental Protection Agency (USEPA) Region 4 office's review. The web site address is:

"http://www.dep.state.fl.us/air/emission/apds/default.asp"

Pursuant to Section 403.0872(6), Florida Statutes, if no objection to the PROPOSED Permit is made by the USEPA within 45 days, the PROPOSED Permit will become a FINAL Permit no later than 55 days after the date on which the PROPOSED Permit was mailed (posted) to USEPA. If USEPA has an objection to the PROPOSED Permit, the FINAL Permit will not be issued until the permitting authority receives written notice that the objection is resolved or withdrawn.

If you should have any questions, please contact Jeff Sims at 813/627-2600 ext. 1285.

Sincerely,

Richard D. Garrity, Ph.D.
Executive Director

RDG/JDS/jds

Enclosures

copy furnished to:
Ms. Veronica Sgro, Koogler and Associates: vsgro@kooglerassociates.com
Ms. Ana Oquendo, EPA Region 4: oquendo.ana@epamail.epa.gov
Ms. Natasha Hazziez, U.S. EPA Region 4: hazziez.natasha@epa.gov
Ms. Barbara Friday, DEP BAR: barbara.friday@dep.state.fl.us (for posting with U.S. EPA, Region 4)

PROPOSED Determination

Title V Air Operation Permit Renewal
PROPOSED Permit Project No.: 0570123-031-AV
Renewal to Title V Air Operation Permit No.: 0570123-030-AV

I. Public Notice.

An "INTENT TO ISSUE A TITLE V AIR OPERATION PERMIT RENEWAL" to Hess Corporation for their facility located at 504 North 19th Street, Tampa in Hillsborough County was clerked on October 16, 2012. The "PUBLIC NOTICE OF INTENT TO ISSUE AIR PERMIT" was published in the Tampa Bay Times on November 10, 2012. The DRAFT Permit was available for public inspection at the Environmental Protection Commission of Hillsborough County in Tampa. Proof of publication of the "PUBLIC NOTICE OF INTENT TO ISSUE AIR PERMIT" was received on November 13, 2012.

II. Public Comment(s).

One comment was received and the DRAFT Permit was changed. The comments were not considered significant enough to reissue the DRAFT Permit and require another Public Notice. Comments were received from one respondent during the public comment period. Listed below is the comment and its corresponding response. The comment(s) will not be restated. Where duplicative comments exist, the original response is referenced.

A. E-mail(s) from Martha Maloney of Hess Corporation received on October 26, 2012 (and November 2, 2012).

1. COMMENT: The applicant provided updated information regarding the manufacturer of the emergency generator, and requested that it be updated in the Appendix ICE from the permit.

   RESPONSE: Appendix ICE was updated based on the information provided to identify Doosan as the manufacturer of the engine.

2. COMMENT: The heading on pages 10-15 should be changed to Subsection A.

   RESPONSE: The permit heading was corrected as requested.

3. COMMENT: Specific Condition C.5 should be moved from the "Emission Limitations and Standards" section to the "Monitoring of Operations" section since these are monitoring indicators and not emission standards directly required by state or federal rules.

   RESPONSE: The requirements from Specific Condition C.5 were relocated as requested. In order to minimize the changes to the condition numbers, Specific Condition C.5 was changed to "Reserved", and the requirements from former Specific Condition C.5 were inserted as Specific Condition No. C.17.

4. COMMENT: The permittee requested that Facility-Wide Condition FW16(a) be amended regarding monthly leak inspections to clarify that pressure relief devices is a more accurate description than pressure/vacuum vents and to specify that exhaust ports and stacks are not included as part of the leak inspections, as defined in 40 CFR 63.11100. The permittee also requested that the definition for gasoline from 40 CFR 63.11100 (Subpart BBBBBB) be included as part of the permit.

RESPONSE: The requested changes to the condition were made as requested. The definition of gasoline as found in 40 CFR 63.11100 (Subpart BBBBBB) was added as a Permit Note following the condition.

B. Documents on file with the permitting authority:

- Comments on DRAFT permit received October 26, 2012 (and November 2, 2012), from Martha Maloney of Hess Corporation.

III. Conclusion.

The permitting authority hereby issues the PROPOSED Permit, with any changes noted above.