Table 2-1, Summary of Compliance Requirements

Hillsborough County — Draft Permit No. **0570261-012-AV**

Hillsborough County Resource Recovery Facility — Facility ID No. 0570261

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
[-001]	150 MMBtu/hr (nom) Municipal Waste Combustor & Auxiliary Burner - Unit 1
[-002]	150 MMBtu/hr (nom) Municipal Waste Combustor & Auxiliary Burner - Unit 2
[-003]	150 MMBtu/hr (nom) Municipal Waste Combustor & Auxiliary Burner - Unit 3

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
Particulate Matter	all	Method 5	Annual	TBE	60 min.		**C.38.**
Sulfur Dioxide	all	Method 19 & 6, 6A or 6C	Annual	TBE	60 min.	Yes	**C.41.**
Nitrogen Oxides	all	Method 19 & 7, 7A, 7C, 7D or 7	Annual	TBE	60 min.	Yes	**C.44.**
Lead	all	Method 29	Annual	TBE	60 min.		**C.39.**
Fluoride	all	Method 13 or 13A	Annual	TBE	60 min.		**C.45.**
Mercury	all	Method 29	Annual	TBE	60 min.		**C.39.** & **C.40.**
Beryllium	all	Method 29	Annual	TBE	60 min.		**C.46.**
Cadmium	all	Method 29	Annual	TBE	60 min.		**C.39.**
Hydrogen Chloride	all	Method 26 or 26A	Annual	TBE	60 min.		**C.42.**
Dioxins/Furans	all	Method 23	Annual	TBE	60 min.		**C.43.**
Carbon Monoxide	all	Method 10, 10A or 10B	Annual	TBE	60 min.	Yes	**C.47.**
Visible Emissions	all	Method 9	Annual	TBE	30 min.	Yes	**C.38.**
Volatile Organic Compounds	all	Method 18, 25 or 25A	Initial	TBE	60 min.		**C.48.**
Sulfuric Acid Mist	all	Method 8	Initial	TBE	60 min.		**C.49.**

Notes:

* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C., this date is to be established (TBE) by the initial compliance test.

**CMS [=] continuous monitoring system

Table 2-1, Summary of Compliance Requirements

Hillsborough County
Hillsborough County Resource Recovery Facility

Draft Permit No. **0570261-012-AV**
Facility ID No.: 0570261

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
[-100]	Ash Building and Handling System

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
Visible Emissions	N/A	Method 22	Annual	TBE	1 hr.		**D.9.**
Particulate Matter	N/A	Method 5	Renewal	TBE	1 hr.		**D.11.** & **D.13.**
Visible Emissions	N/A	Method 9	Annual	TBE	1 hr.		**D.12.**

Notes:
* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C., this date is to be established (TBE) by the initial compliance test.
**CMS [=] continuous monitoring system

[electronic file name: 05702612.xls]

Table 2-1, Summary of Compliance Requirements

Hillsborough County
Hillsborough County Resource Recovery Facility

Draft Permit No. **0570261-012-AV**
Facility ID No.: 0570261

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
[-101]	Lime Storage Silo
[-106]	Dolomitic Lime Storage Silo

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
Particulate Matter	N/A	Method 5	Renewal	TBE	60 min.		**E.6.** & **E.8.**
Visible Emissions	N/A	Method 9	Annual	TBE	30 min.		**E.7.**

Notes:
* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C., this date is to be established (TBE) by the initial compliance test.
**CMS [=] continuous monitoring system

[electronic file name: 05702612.xls]

Table 2-1, Summary of Compliance Requirements

Hillsborough County
Hillsborough County Resource Recovery Facility

Draft Permit No. **0570261-012-AV**
Facility ID No.: 0570261

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
[-102]	Activated Carbon Storage Silo

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
Particulate Matter	N/A	Method 5	Renewal	TBE	60 min.		**F.6.** & **F.8.**
Visible Emissions	N/A	Method 9	Annual	TBE	30 min.		**F.7.**

Notes:
* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C., this date is to be established (TBE) by the initial compliance test.
**CMS [=] continuous monitoring system

[electronic file name: 05702612.xls]